

# **New York State Clean Heat**

*Con Edison Heat Pump Program Manual*



*Version 4*

*March 1, 2024*

# Current Version Description of Revisions: Con Edison Clean Heat Program Manual

This table reflects the changes made to Version 4 of this Program Manual which have been published and made effective on March 1, 2024. For complete record of changes between all versions see Appendix 2: Version History and Description of Revisions: Con Edison Clean Heat Program Manual.

<b>Topic</b>	<b>Description of Change</b>	<b>Section</b>
Incentive Category Addition	Addition of incentive Category 2e <i>Air-to-Water Heat Pump</i> (“AWHP”), with revisions in numerous sections to reflect this addition	Sections 2-4
Incentive Category Update	Category 5 renamed to Category 5 <i>Midstream HPWH</i> , and clarifications to category specifications	Sections 2-4
Limited-Time 2024 Promotion Incentives	Addition of limited-time promotional incentives for Residential ASHP, Residential GSHP, Multifamily, SMB, and C&I sectors	Sections 2 & 4
Incentive Category Addition	Addition of incentive Category 6a: <i>Prescriptive Domestic Hot Water</i> (“DHW”) in the Multifamily sector	Sections 2.3, 4.3.2
Financing	Removal of Con Edison Clean Heat Financing offering	Section 2.9
Financing	Removal of reference to Companion Loans funded by New York Green Bank	Section 2.9.1
Eligibility	Allow projects to receive incentives for replacement of non-cold climate heat pumps or non-full load heat pumps	Section 3.2
Eligibility – Full Load Heating	Update definition of full load heating systems	Sections 3.2.1
Design Temperature Tool	Reference added to new online tool to identify design temperature, available on Contractor Resources webpage.	Section 3.2.1
Program Eligibility	Customers or projects participating in Utility Thermal Energy Network projects are not eligible for Clean Heat Program incentives	Section 3.2.4
Eligibility	Addition of incentives and eligibility criteria for non-residential GSHP Thermal Conductivity Testing	Section 3.2.4
Multifamily Eligibility	Allow buildings with up to 100 units to be eligible for category 2c and buildings of any size to be eligible for partial load custom projects in category 10	Section 4.3.2
Eligibility	Clarification of NEEP listed eligible equipment in non-residential sectors	Sections 4.3.2 - 4.3.4
Program Compliance	Revised SMB Documentation Requirements	Section 4.3.3.5
Glossary	Glossary has updates to reflect Program updates.	Section 7

Contents

- 1. Introduction.....5**
  - 1.1 The New York State Clean Heat Statewide Heat Pump Program ..... 5
  - 1.2 The NYS Clean Heat Program in Con Edison’s Service Territory ..... 6
- 2. NYS Clean Heat Program for Con Edison Summary .....6**
  - 2.1 Available Incentive Funding ..... 8
  - 2.2 Residential Incentives ..... 10
  - 2.3 Multifamily (“MF”) Incentives..... 12
  - 2.4 Small and Medium Business Incentives ..... 13
  - 2.5 Commercial and Industrial Incentives..... 15
  - 2.6 Non-Pipe Solutions Clean Heat Adder Incentives ..... 16
    - 2.6.1 NPA Eligibility Coverage Map..... 17
  - 2.7 Modifications to Incentives..... 17
  - 2.8 Coordination with NYSERDA Programs ..... 18
  - 2.9 Financing Options ..... 18
    - 2.9.1 Green Jobs – Green New York Financing ..... 18
- 3. Eligibility and Requirements .....19**
  - 3.1 Site Eligibility ..... 19
  - 3.2 Eligible Technologies ..... 20
    - 3.2.1 System Sizing ..... 21
    - 3.2.2 Equipment Installation ..... 24
    - 3.2.3 Air-Source Heat Pumps ..... 25
    - 3.2.4 Ground Source Heat Pumps ..... 29
    - 3.2.5 Heat Pump Water Heaters and Ground Source Water-to-Water Heat Pumps ..... 39
    - 3.2.6 Energy Recovery Ventilators (ERVs) and Heat Recovery Ventilators (HRVs)..... 41
    - 3.2.7 Heat Recovery Chillers and Heat Pump Chillers ..... 41
    - 3.2.8 Envelope Measures (for Category 4A: Heat Pump + Envelope) ..... 42
    - 3.2.9 Heat Pump Dedicated Outdoor Air Systems (HP-DOAS) ..... 43
    - 3.2.10 Advanced Controls for Heating Electrification..... 44
    - 3.2.11 Additional Project Eligibility Criteria ..... 44
  - 3.3 Warranty Requirements ..... 45
  - 3.4 Operation and Maintenance Requirements ..... 45
  - 3.5 Engineering Savings Analysis Requirements for Custom Categories 4, 4A, 6 and 10 ..... 46
    - 3.5.1 Statewide Custom Clean Heat Program Savings Calculator ..... 46

3.5.2 Energy Modeling .....	47
3.5.3 Establishing Baselines .....	47
3.6 Additional Requirements for New Construction and Gut Rehab.....	49
3.6.1 New Construction and Gut Rehab Eligibility.....	49
3.6.2 Energy Code Compliance .....	49
3.6.3 New Construction and Gut Rehab Energy Savings Analysis.....	50
3.7 Early Replacement Projects .....	50
3.7.1 Required Project Documentation .....	51
3.8 Special Circumstance .....	51
3.8.1 Age Rule .....	51
3.8.2 Energy Use Rule .....	52
3.8.3 Required Project Documentation .....	52
<b>4. Participating in the Program .....</b>	<b>53</b>
4.1 Become a Participating Contractor .....	53
4.1.1 Residential Contractor Verification “Attestation” Form.....	55
4.2 Residential Program Requirements and Application Process.....	55
4.2.1 Residential Contractor Allocations.....	55
4.2.2 Incentive Eligibility .....	56
4.2.3 Incentives .....	57
4.2.4 Residential Application Process .....	62
4.2.5 Residential Savings Calculations .....	66
4.3 Non-Residential Program Requirements and Application Process.....	67
4.3.1 Supporting Documentation Description .....	71
4.3.2 Multifamily Program Eligibility and Requirements.....	76
4.3.3 Small and Medium Business Program Eligibility and Requirements .....	80
4.3.4 Commercial & Industrial Program Eligibility and Requirements .....	86
4.4 Midstream Heat Pump Water Heater (HPWH).....	90
4.4.1 Wholesale Channel .....	90
4.4.2 Retail Channel .....	92
<b>5. Field Inspections and Oversight .....</b>	<b>94</b>
5.1 Field Inspection Categories .....	95
5.2 Residential Inspections .....	95
5.2.1 Post-Installation Inspections: ASHP, AWHP and GSHP Projects.....	95
5.2.2 QAQC Inspections .....	96
5.2.3 Inspection Sampling Rates .....	96

5.3	Non-Residential Inspections .....	96
5.4	Disciplinary Process.....	97
5.5	Disciplinary Exceptions .....	98
<b>6.</b>	<b>Contact Information .....</b>	<b>99</b>
<b>7.</b>	<b>Glossary .....</b>	<b>100</b>
	<b>Appendix 1: Calculating Sizing Ratios in the New York State Clean Heat Program Guide.....</b>	<b>106</b>
	<b>Appendix 2: Version History and Description of Revisions: Con Edison Clean Heat Program Manual.</b>	<b>112</b>

## List of Tables

Table 1: Time at which projects draw down Sectoral Allocation.....	8
Table 2: Residential ASHP Incentives.....	10
Table 3: Residential GSHP Incentives.....	10
Table 4: Residential ASHP Limited-Time 2024 Promotion Incentives .....	11
Table 5 Residential GSHP Limited-Time 2024 Promotion Incentives .....	11
Table 6: Multifamily Incentives.....	12
Table 7: Multifamily Limited-Time 2024 Promotion Incentives .....	13
Table 8: SMB Incentives.....	13
Table 9: SMB Limited-Time 2024 Promotion Incentives.....	14
Table 10: C&I Incentives Summary .....	15
Table 11: C&I Limited-Time 2024 Promotion Incentives .....	16
Table 12: Non-Pipes Alternative Incentives.....	16
Table 13: Space Heating Eligibility by Technology and Category.....	20
Table 14: Dry Bulb Design Temperatures .....	24
Table 15: Maximum Allowable and Good Practice Pumping Power for Closed-Loop GSHP Systems in watts (W) per AHRI rated full-load heating or cooling capacity of the installed system.....	31
Table 16: Maximum Allowable and Good Practice Pumping Power for Open-Loop GSHP Systems in watts (W) per AHRI rated full-load heating or cooling capacity of the installed system.....	32
Table 17: Efficiency Requirements for Console Units.....	37
Table 18: Efficiency requirements for non-console units with AHRI-rated cooling capacities < 24,000 Btu/h .....	37
Table 19: Efficiency requirements for GSVRF .....	38
Table 20: Efficiency requirements for GSVRF heat pumps tested under AHRI 1230 groundwater source configuration, however intended to be used in a ground source configuration.....	38
Table 21: Efficiency requirements for Water Source VRF heat pumps tested under AHRI 1230 water source configuration, however intended to be used in a ground source configuration.....	39
Table 22: Eligibility Tiers for Category 4a.....	43
Table 23: Infiltration Guidance .....	43
Table 24: Residential ASHP Incentives.....	58
Table 25: ASHP incentive rates for premises that previously received a partial load incentive .....	58
Table 26: Residential GSHP Incentives.....	59
Table 27: Residential ASHP Limited-Time 2024 Promotion Incentives .....	60
Table 28 Residential GSHP Limited-Time 2024 Promotion Incentives .....	60
Table 29: Residential Single-Family Building Type Examples.....	61
Table 30: Recommended BHL/SF Ranges by Building Age .....	65
Table 31: Installation Timelines .....	69
Table 32: Multifamily incentive Rates.....	77
Table 33: Multifamily Limited-Time 2024 Promotion Incentives .....	78
Table 34: Recommended Range BH/SF for SMB Projects.....	81
Table 35: SMB Incentive Rates.....	82
Table 36: SMB Limited-Time 2024 Promotion Incentives.....	82
Table 37: Required Documentation for SMB Projects.....	85
Table 38: C&I Incentives Summary .....	87
Table 39: C&I Limited-Time 2024 Promotion Incentives .....	88
Table 40: Critical Facilities Exempt from Decommissioning .....	89

# 1. Introduction

## 1.1 The New York State Clean Heat Statewide Heat Pump Program

Heat pumps have been an efficient source of heating and cooling for many years, but advances in technology now allow them to effectively address heating needs in cold climates, helping customers reduce greenhouse gas emissions. To achieve statewide heat pump goals and build the market infrastructure for a low-carbon future, the New York State (“NYS”) Clean Heat Statewide Heat Pump Program (“NYS Clean Heat Program”) including the NYS Clean Heat Program for Con Edison (or the “Program” as defined below) offers incentives to a wide range of customer segments in coordination with a portfolio of market development initiatives to build market capacity and deliver building electrification solutions. The NYS Clean Heat Program, a collaborative effort between the New York Electric Utilities<sup>1</sup> and the New York State Energy Research & Development Authority (“NYSERDA”) (collectively, “Joint Efficiency Providers”<sup>2</sup>), is designed to provide customers, contractors, and other heat pump solution providers with a consistent experience and business environment throughout New York State.

The NYS Clean Heat Program includes a range of initiatives to advance the adoption of efficient electric heat pump systems that are designed and used for space and water heating. Core to the NYS Clean Heat Program is the suite of incentives that support customer adoption of eligible heat pump technologies, which includes air source heat pump (“ASHP”), air-to-water heat pump (“AWHP”), heat pump water heaters (“HPWH”), and ground source heat pump (“GSHP”) systems, through promotion and pricing discounts offered by contractors and other heat pump solution providers. In addition, the program offers incentives for envelope improvements, heat pump controls, heat recovery chillers (“HRC”) and heat pump chillers (“HPC”), and energy recovery ventilators/heat recovery ventilators (“ERV/HRV”) when paired with an eligible heat pump system. Market development efforts include support for training and qualification of contractors, processes to assure quality installations, and marketing and education to help customers understand and select among options and to operate systems optimally.

For information about incentives and programs particulars in the service territories of Central Hudson, National Grid, NYSEG/RG&E, and Orange and Rockland, please refer to the Program Manual applicable to these utilities.<sup>3</sup> In addition to some information that relates generally to the NYS Clean Heat Program, the information in this Program Manual (the NYS Clean Heat Program for Con Edison Program Manual) is specific to Con Edison, and as more particularly provided below.

---

<sup>1</sup> The New York Electric Utilities consist of Central Hudson Gas & Electric Corporation (“Central Hudson”), Consolidated Edison Company of New York, Inc. (“Con Edison”), Niagara Mohawk Power Corporation d/b/a National Grid (“National Grid”), New York State Electric & Gas Corporation (“NYSEG”), Orange and Rockland Utilities, Inc. (“Orange & Rockland”), and Rochester Gas and Electric Corporation (“RG&E”) (collectively, “Electric Utilities”).

<sup>2</sup> The New York Electric Utilities and NYSEDA are referred to as “Joint Efficiency Providers” for purposes of their partnership in the NYS Clean Heat Program.

<sup>3</sup> The Statewide Program Manual can be found at: <https://cleanheat.ny.gov/contractor-resources/>.

## 1.2 The NYS Clean Heat Program in Con Edison's Service Territory

Due to accelerated program achievement, Con Edison filed a petition with the Commission for additional program funding in February 2022. On May 9, 2022, after reaching its cumulative 2020-2025 program targets, Con Edison paused accepting ASHP heat pump incentive applications. On July 11, 2022, Con Edison announced that it would place all new GSHP incentive applications in non-residential categories on a waitlist pending additional program funding. On August 11, 2022, the Commission authorized additional funding for the program and required the Company to work with Staff, stakeholders and market participants to implement necessary changes to relaunch the program, including limiting monthly expenditures to \$10 million until the New Efficiency New York proceeding Interim Review concludes.<sup>4</sup>

As discussed in coming Sections, to better control expenditures, provide market participants certainty regarding incentive availability, and foster fairness, Con Edison adopted revised incentive levels and structures, Sectoral Allocations to distribute limited funding across customer segments, and monthly allocations for residential contractors that reserve a pre-defined quantity of incentives for each contractor in January 2023.

To capture changes that were not adopted by the non-Con Edison utilities, this Program Manual covers the NYS Clean Heat Program as implemented in Con Edison's service territory (the "NYS Clean Heat Program for Con Edison" or the "Program"). The updated version (v11) of the Statewide Program Manual for the non-Con Edison utilities has been released concurrently with the release of this Program Manual.

On January 17, 2023, Con Edison ended the program pause and began accepting new applications for ASHP projects installed after that date, issued confirmation letters for GSHP projects on the waitlist and continued accepting applications for residential GSHP installations under a modified incentive structure and program design.

## 2. NYS Clean Heat Program for Con Edison Summary

The New York Public Service Commission has authorized budgets for the NYS Clean Heat Program, including the NYS Clean Heat Program for Con Edison. The Program offers incentives for ASHPs, AWHPs, and GSHPs for both space heating and cooling as well as for HPWHs for water heating. Envelope improvements, heat pump controls, HRC/HPC, and ERV/HRV may also be eligible for incentives when paired with an eligible heat pump system.

For space heating and custom domestic hot water ("DHW") projects, incentives are paid directly to Participating Contractors. For the midstream HPWH Program, incentives are paid to the Participating Distributors. The project incentive amount, less any applicable Contractor Reward, is required to be passed along to the customer. Depending on the customer segment,

---

<sup>4</sup> Case 18-M-0084, *In the Matter of a Comprehensive Energy Efficiency Initiative* ("NENY Proceeding"), Order Approving Funding for Clean Heat Program (issued August 11, 2022) ("Con Edison Clean Heat Order).



Participating Contractors may request that the project incentive be paid to an alternate payee.

Only Participating Contractors are allowed to apply for space heating Clean Heat incentives in residential and small-and-medium business (“SMB”) segments. To become a Participating Contractor, applicants must submit a Participating Contractor Application including a Participating Contractor Agreement for the NYS Clean Heat Program for Con Edison<sup>5</sup>. Upon approval, the applicant will receive an approval notification from Con Edison and become eligible to apply for incentives in the Program. In the multifamily and commercial and industrial (“C&I”) segments, either Participating Contractors or customers may apply for Clean Heat incentives.

Each GSHP installation that requires a driller must be completed by a Participating Driller. Participating Drillers are not eligible to submit for and receive incentives. Contractors who wish to become Participating Drillers must each submit an updated Participating Contractor Application.

Distributors participating in the Midstream HPWH Program must each submit an application to become Participating Distributors.

Contractors who only install HPWHs do not have to become Participating Contractors in order to submit an incentive application on behalf of a customer.

To be eligible for incentives, heat pump projects must comply with the requirements described in this document.

The Joint Efficiency Providers recommend that site owners contact a heat pump professional to assess and implement energy efficiency opportunities related to building envelope and HVAC distribution system prior to, or in coordination with, installing a heat pump system. Common thermal efficiency upgrades include attic and wall insulation, air sealing, and duct sealing. These types of improvements can help reduce energy costs and enable the installation of an efficiently sized cold-climate heat pump. Site owners can elect to receive incentives for a “Heat Pump + Envelope” project under Category 4a (see [Section 3: Eligibility and Requirements](#) for more details). Site owners can also access additional building envelope incentive programs and assistance through NYSERDA or their local utility.

The Joint Management Committee (“JMC”), which is responsible for reviewing and maintaining the NYS Clean Heat Program, follows a process for making ongoing changes to program areas including incentive structure, eligible technologies, program rules, and other features in order to be responsive to technology and market developments and to maintain market confidence and stability. In appropriate circumstances, Con Edison also reserves the right to implement necessary changes on its own. Participating Contractors will be notified electronically of any program modification or change, and reference documents are publicly available on the NYS Clean Heat Resources webpage.<sup>6</sup>

Starting in May 2021, the JMC began a regularly recurring Participating Contractors and Industry Partners (“PC&IP”) Working Group Series webinar that is open to all industry program participants. This quarterly webinar is a public forum for stakeholders to introduce topics for

---

<sup>5</sup> Participating Contractor Applications and Contractor Participation Agreements are available at <https://cleanheat.ny.gov/contractor-resources/>.

<sup>6</sup> <https://cleanheat.ny.gov/contractor-resources/>

discussion for a larger audience and provide specific program and project feedback, as well as for the JMC members to share key program updates and changes. Stakeholders that wish to be included in this quarterly forum or propose topics for discussion can do so by emailing [NYSCleanHeat@ceadvisors.com](mailto:NYSCleanHeat@ceadvisors.com). Details on participation and prior discussions can also be found on the NYS Clean Heat Resources webpage<sup>7</sup> under the “Working Group Series” heading.

While the PC&IP webinars will serve as the primary avenue for Statewide stakeholder engagement, Con Edison also hosts broad and targeted sessions for market participants and stakeholders. We invite you to reach out to the Program Administrators directly for specific issues as well. Contact information is included in Section 6 of this Program Manual.

This NYS Clean Heat Resources webpage (available at: <https://cleanheat.ny.gov/contractor-resources/>) includes other important information and resources.

## 2.1 Available Incentive Funding

The NYS Clean Heat Program for Con Edison offers incentives that are specific to the technology and sector, including residential, multifamily (“MF”), small and medium business (“SMB”) and commercial and industrial (“C&I”), with additional incentives available for HPWHs through both custom categories and the midstream program.

Until further notice, the NYS Clean Heat Program for Con Edison is limited to \$10 million of expenditures per month. Con Edison will divide up the budget and publish sectoral allocations. The budget will be allocated into six categories: residential ASHP, residential GSHP, non-residential ASHP, non-residential GSHP, HPWH, and funds retained to administer the programs. Con Edison publishes a dashboard twice-monthly with a summary of expenditures and available funding on its website<sup>8</sup>.

Con Edison will accept applications up to the sectoral allocation for each sector in a given month. However, when program expenditures fall short of \$10 million in a given month, the unused portion rolls forward and will be available to the Program in subsequent months. Such funds allow Con Edison to increase funding for segments that exceed their monthly allocation. Applications that are submitted after the sectoral allocation is reached may be waitlisted subject to the discretion of Con Edison.

Projects will draw down their sectoral allocation funding with timing specific to sector and technology as summarized in Table 1.

*Table 1: Time at which projects draw down Sectoral Allocation*

<b>Project Sector and Technology</b>	<b>Date a Projects Draws Down its Sectoral Allocation</b>
Residential ASHP or AWHP	Con Edison receives a complete post-installation incentive application
Residential GSHP	Con Edison receives a pre-installation application with signed customer agreement

<sup>7</sup> Ibid.

<sup>8</sup> <https://www.coned.com/en/our-energy-future/electric-heating-and-cooling-equipment/clean-heat-program-funding?facettab=dd8aae5b-1629-4865-b4e6-0afe5f1f91e2>

All non-residential space heating	Con Edison issues a Preliminary Incentive Offer Letter (“PIOL”)
Midstream HPWH	Con Edison receives a complete incentive application

In general, across all sectors, incentives are limited to the listed rates or 50% of project costs, whichever is lower.<sup>9</sup> However, incentives for Residential ASHP and Residential GSHP projects located within a Disadvantaged Community (“DAC”) will be limited to 70% of project costs.

Existing buildings, including gut renovations, are eligible for incentives for ASHP, AWHP, GSHP and HPWH. New construction is not eligible to receive incentives for ASHP or AWHP for heating. New construction is only eligible to receive incentives for GSHP for space heating, GSHP paired with other custom water solutions, GSHP paired with envelope improvements, hot water heating solutions for domestic hot water usage, or HPWH incentives through the midstream program.

All residential ASHP must be on the Northeast Energy Efficiency Partnership (“NEEP”) Cold Climate Air Source Heat Pump (ccASHP) Product List (“NEEP List”)<sup>10</sup>. All residential AWHP must be on the NYS Clean Heat AWHP Qualified Product List (QPL).

The NYS Clean Heat Program for Con Edison provides incentives under 12 categories differentiated by sector. The incentive categories are as follows:

- Category 2a — *ccASHP: Residential Full Load Heating with Integrated Controls*
- Category 2b — *ccASHP: Residential Full Load Heating with Decommissioning*
- Category 2c — *ASHP MF Full Load Heating with Decommissioning*
- Category 2d — *ASHP SMB Full Load Heating with Decommissioning*
- Category 2e — *AWHP: Residential Full Load Heating with Decommissioning*
- Category 3 — *GSHP: Residential Full Load Heating*
- Category 4 — *Custom Space Heating Applications*
- Category 4a — *Custom Space Heating Applications + Envelope*
- Category 5 — *Midstream HPWH*
- Category 6 — *Custom Hot Water Heating Applications*
- Category 6a — *Prescriptive Hot Water Heating Applications*
- Category 10 — *Custom Partial Load Space Heating Applications*

---

<sup>9</sup> Customers participating in a non-pipes alternative (“NPA”) may receive incentives from the NPA that, when aggregated with Clean Heat incentives, exceed 50% of project costs.

<sup>10</sup> NEEP. Northeast Energy Efficiency Partnership (“NEEP”) Cold Climate Air Source Heat Pump (ccASHP) Product List. Available at ASHP (neep.org).

## 2.2 Residential Incentives

Residential incentives are available for projects in buildings with at one to four Dwelling Units or when a project covers up to four dwelling units in a building with five or more units. There are four categories of incentives available for residential space heating in the Con Edison service territory: Category 2a – ccASHP: Residential Full Load Heating with Integrated Controls, Category 2b – ccASHP: Residential Full Load Heating with Decommissioning, Category 2e AHP: Residential Full Load Heating with Decommissioning and Category 3 – GSHP: Residential Full Load Heating.

There are two rates offered for ASHP categories as summarized in Table 2 – installations in single family homes, and another for installations in individual apartments. For GSHP projects, the incentives are offered for whole building applications and are summarized in Table 3.

Table 2: Residential ASHP Incentives

Category Number	Description	Non-DAC		DAC	
		Single Family Home	Apartment	Single Family Home	Apartment
2a	ccASHP: Full load heating with integrated controls	\$2,500	\$1,000	\$4,500	\$2,000
2b	ccASHP: Full load heating with decommissioning	\$8,000	\$4,000	\$10,000	\$5,000
2e	AHP: Full load heating with decommissioning				

Table 3: Residential GSHP Incentives

Category Number	Description	Non-DAC	DAC
		Whole Building	Whole Building
3	GSHP: Full Load Heating	\$25,000	\$35,000

Con Edison has introduced new incentive rates for decommissioning projects as part of a Limited-Time 2024 Promotion in the Residential sector. ASHP projects installed on or after December 5, 2023, with applications submitted on or before May 31, 2024 are eligible for the 2024 Promotion Rates. ASHP project applications submitted after May 31, 2024 will be eligible for base incentive rates. ASHP incentive rates for the 2024 Promotion can be found in Table 4 below.

Table 4: Residential ASHP Limited-Time 2024 Promotion Incentives

Category Number	Description	Non-DAC		DAC	
		Single Family Home	Apartment	Single Family Home	Apartment
2b	ccASHP: Full load heating with decommissioning	\$10,000	\$6,000	\$12,000	\$7,000
2e	AWHP: Full load heating with decommissioning				

Residential GSHP projects will be eligible for the 2024 Promotion Rates if they are installed on or after December 5, 2023, and submit signed customer commitments before May 31, 2024. Signed commitments and incentive applications submitted after May 31, 2024, will be eligible for base incentive rates. GSHP incentive rates for the 2024 Promotion can be found in Table 5 below.

Table 5 Residential GSHP Limited-Time 2024 Promotion Incentives

Category Number	Description	Non-DAC	DAC
		Whole Building	Whole Building
3	GSHP: Full Load Heating	\$35,000	\$45,000

For Category 2a, the integrated controls package must be connected to existing fossil fuel heating equipment and must operate the heat pump as the first stage/primary heating system. To be eligible for Category 2a incentives, the integrated control system must be listed on the NYS Clean Heat Integrated Controls Qualified Product list located under the ASHP tab on the NYS Clean Heat Resources webpage<sup>11</sup>. For further eligibility specifications, see Section 4.2 of this Program Manual on the Residential incentive offerings.

Categories 2b, 2e and 3 require the projects decommissioning of all existing fossil-fueled units for space heating.

Projects in DAC are eligible to receive incentives that cover up to 70% of project costs, while incentives for projects outside of DACs remain capped at 50% of project costs. Contractors can determine whether a project is in a DAC by searching the address at:

<https://www.nyserda.ny.gov/ny/Disadvantaged-Communities>.

<sup>11</sup> <https://cleanheat.ny.gov/contractor-resources>

## 2.3 Multifamily (“MF”) Incentives

Multifamily incentives are available for projects in buildings with at least five Dwelling Units. Multifamily incentives require decommissioning over the scope of the project for categories 2c, 4 and 4a. Incentives will be capped at \$1 million per project or 50% of project costs, whichever is lower.

Table 6 shows incentive rates for all Multifamily offerings. Existing Buildings include gut renovations.

Table 6: Multifamily Incentives

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
<b>2c</b>	Multifamily Full Load ASHP Heating with Decommissioning	N/A	\$5,000/dwelling unit	\$5,000/dwelling unit
<b>4</b>	Custom Space Heating Applications	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope – Tier 1	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu
	Custom Space Heating Applications + Envelope – Tier 2	\$150/MMBtu	\$225/MMBtu	\$225/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu
<b>6a</b>	Prescriptive Domestic Hot Water (“DHW”)	N/A	N/A	\$1,000/dwelling unit
<b>S10</b>	Custom Partial Load Space Heating Applications	N/A	\$100/MMBtu	\$70/MMBtu

Category 2c incentives are available to buildings with 100 Dwelling Units or fewer. See Section 4.3 of this Program Manual for more details on the relevant application process, and Section 4.4 for more details on the Multifamily Program.

Con Edison has introduced new incentive rates as part of a Limited-Time 2024 Promotion for Multifamily projects. To be eligible for the 2024 Promotion Rates, multifamily projects must submit completed applications between December 5, 2023, and May 31, 2024 and be installed by the following deadlines by category:

- Categories 2c and 6: October 1, 2024;
- Categories 4, 4a, and 10: September 1, 2025.

To be eligible for the LTO rates, GSHP projects in Categories 4 and 4a must be fully installed and pass post-inspection no later than November 1, 2025.

Projects for which completed applications are not submitted by, or which are not installed by the specified dates, will be eligible for base incentive rates. Incentive rates for the 2024 Promotion can be found in Table 7 below.

Table 7: Multifamily Limited-Time 2024 Promotion Incentives

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
2c	Multifamily Full Load ASHP Heating with Decommissioning	N/A	N/A	\$7,000/dwelling unit
4	Custom Space Heating Applications	\$150/MMBtu	\$300/MMBtu	\$225/MMBtu
4a	Custom Space Heating Applications + Envelope – Tier 1	\$150/MMBtu	\$300/MMBtu	\$225/MMBtu
	Custom Space Heating Applications + Envelope – Tier 2	\$175/MMBtu	\$325/MMBtu	\$250/MMBtu
6	Custom Domestic Hot Water (“DHW”)	\$150/MMBtu	\$300/MMBtu	\$225/MMBtu
10	Custom Partial Load Space Heating Applications	N/A	N/A	\$95/MMBtu

## 2.4 Small and Medium Business Incentives

Commercial customers with an average annual peak demand of 300 kW or less are eligible for SMB incentives. All SMB incentives require decommissioning over the scope of the project. Partial load projects are not eligible. New construction is not eligible for incentives for ASHPs.

Incentives will be capped at \$200,000 per project or 50% of project costs, whichever is lower.

Incentives for SMB projects can be found in Table 8 below. Existing buildings include gut renovations.

Table 8: SMB Incentives

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
2d	SMB Full Load Heating with Decommissioning (<1,000 square feet)	N/A	N/A	\$5,000/project
	SMB Full Load Heating with Decommissioning (1,001-1,500 square feet)	N/A	N/A	\$7,500/project
	SMB Full Load Heating with Decommissioning (1,501-2,000 square feet)	N/A	N/A	\$10,000/project
	SMB Full Load Heating with Decommissioning (2,001-2,500 square feet)	N/A	N/A	\$12,500/project
4	Custom Space Heating Applications	\$125/MMBtu	\$200/MMBtu	\$150/MMBtu

<b>4a</b>	Custom Space Heating Applications + Envelope	\$125/MMBtu	\$200/MMBtu	\$150/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu

Con Edison has introduced new incentive rates as part of a Limited-Time 2024 Promotion for SMB projects. To be eligible for the 2024 Promotion Rates, SMB projects must submit completed applications between December 5, 2023 and May 31, 2024 and complete installation by October 1, 2024. Projects for which completed applications are not submitted by, or are not installed by, the above dates will be eligible for base incentive rates. GSHP projects in Categories 4 and 4a must be fully installed and pass post-inspection no later than November 1, 2025.

Prescriptive projects in Category 2d located within a DAC will be eligible for the 2024 Promotion DAC Rates and the incentives will be capped at 60% of project costs. 2024 Promotion incentives for custom projects in Category 4 and 4a will be capped at \$400,000. Incentive rates for the 2024 Promotion can be found in Table 9 below.

*Table 9: SMB Limited-Time 2024 Promotion Incentives*

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
<b>2d</b>	SMB Full Load Heating with Decommissioning (<1,000 square feet)	N/A	N/A	\$6,000/project
	SMB Full Load Heating with Decommissioning (1,001-1,500 square feet)	N/A	N/A	\$8,500/project
	SMB Full Load Heating with Decommissioning (1,501-2,000 square feet)	N/A	N/A	\$11,000/project
	SMB Full Load Heating with Decommissioning (2,001-2,500 square feet)	N/A	N/A	\$13,500/project
<b>4</b>	Custom Space Heating Applications	\$150/MMBtu	\$300/MMBtu	\$175/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope	\$175/MMBtu	\$325/MMBtu	\$200/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$175/MMBtu	\$300/MMBtu	N/A



## 2.5 Commercial and Industrial Incentives

Con Edison Commercial customers with an average peak demand above 100 kW on a rolling 12-month basis are eligible for C&I Clean Heat incentives, excluding Multifamily buildings. Commercial customers between 100-300 kW may also choose to participate with Con Edison through the Small to Medium Business (SMB) sector of the Program.

Clean Heat incentives cannot exceed 50% of the project costs of the eligible Clean Heat measure(s) or 100% of each eligible measure's cost. Total Clean Heat incentives are capped at \$1,000,000 for all projects, per account per year.

Incentives for ASHP in Table 10 includes all non-GSHP technologies. Existing Buildings include gut renovations.

*Table 10: C&I Incentives Summary*

Category Number	Description	GSHP		ASHP
		<i>New Construction (\$/MMBtu)</i>	<i>Existing Buildings (\$/MMBtu)</i>	<i>Existing Buildings (\$/MMBtu)</i>
<b>4</b>	Custom Space Heating Applications	\$125	\$200	\$120
<b>4a</b>	Custom Space Heating Applications + Envelope - Tier 1	\$125	\$200	\$120
	Custom Space Heating Applications + Envelope - Tier 2	\$150	\$225	\$150
<b>6</b>	<i>Custom Hot Water Heating Applications</i>	\$125	\$200	\$200
<b>10</b>	Custom Partial Load Space Heating Applications	N/A	\$100	\$70

Con Edison has introduced new incentive rates as part of a Limited-Time 2024 Promotion for C&I projects. To be eligible for the 2024 Promotion Rates, C&I projects must submit completed applications by May 31, 2024 and complete installation by October 1, 2024. C&I Projects must also pass post-inspection no later than November 1, 2024. Projects for which completed applications are not submitted by, or are not installed by, the above dates will be eligible for base incentive rates.

*Table 11: C&I Limited-Time 2024 Promotion Incentives*

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
<b>4</b>	Custom Space Heating Applications	\$150/MMBtu	\$300/MMBtu	\$195/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope – Tier 1	\$150/MMBtu	\$300/MMBtu	\$195/MMBtu
	Custom Space Heating Applications + Envelope – Tier 2	\$175/MMBtu	\$325/MMBtu	\$225/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$150/MMBtu	\$300/MMBtu	\$275/MMBtu
<b>10</b>	Custom Partial Load Space Heating Applications	N/A	N/A	\$145/MMBtu

## 2.6 Non-Pipe Solutions Clean Heat Adder Incentives

Con Edison’s Non-Pipeline Solutions team is offering a Non-Pipeline Alternative (NPA) Clean Heat adder incentive for eligible Residential, Multifamily and Small Business customers within the Soundview area of the Bronx, NY, which provide gas peak load reduction. These incentives avoid traditional gas infrastructure investments. Eligibility is determined through evaluation of a customer's service line location on Con Edison's gas distribution network.

Applicants installing eligible Clean Heat measures as described below may receive adder incentives that may exceed the Clean Heat project cost cap(s). Con Edison Program team’s approval is needed before customer commitment of adder incentives. NPA incentives will be paid after a final review has been completed by Con Edison. NPA payments will be provided to the project payee in a separate check than Clean Heat incentives. Under NPA, incentives are capped at 100% of project costs.

*Table 12: Non-Pipes Alternative Incentives*


Customer Segment	Category	Unit/Sq ft	Clean Heat Base Unit Incentive	NPA Adder Unit Incentive
ASHP Single Family Home/Whole Building	2b	Whole Building	\$8,000	\$16,000
ASHP Residential 2-4 Family Home &	2b	Dwelling Unit	\$3,000	\$6,000

Apartment				
GSHP Residential	3	Building/Peak Dth/dy	\$25,000 outside DAC \$35,000 within DAC	\$8,240
Multi-Family	2c	Dwelling Unit	\$5,000	\$6,000
Small Business	2d	<= 1,000	\$5,000	\$3,000
		1,001 - 1,500	\$7,500	\$4,000
		1,501 – 2,000	\$10,000	\$5,000
		2,001 – 2,500	\$12,500	\$5,500
	4	MMBTU/Peak Dth/dy	\$150	\$8,240

2.6.1 NPA Eligibility Coverage Map

The following map highlights the general eligible areas in Soundview. For eligibility questions, contact the NPA team at npa@coned.com.

Figure 1: Non-Pipe Solutions Eligibility Map



2.7 Modifications to Incentives

In the event of a future reduction in incentives, Con Edison will generally honor the previous higher rate for projects that have a signed customer commitment as of the date of the announcement of the lower incentive rates. To be eligible for such treatment, Participating Contractors must submit signed contracts and additional supporting documentation as required, within two weeks of announcement of reduced incentives.

Con Edison may change the incentive offerings (including but not limited to total incentive amount, Participating Contractor Reward, timing, recipient, incentive structure, and cap) at any time. Con Edison may further limit the number of incentives per Participating Contractor, site owner, site, or meter.

Program changes could result in changes to this Program Manual. Changes will be e-mailed to Participating Contractors and posted at the Clean Heat Contractor Resources Page<sup>12</sup>. The incentive amount for any project will be based on the incentive offering and program rules that are in effect at the time of application except in cases where alternative incentive rates are being honored as described above. Participating Contractors are prohibited from cancelling submitted incentive applications and re-applying if the new incentive payment results in a higher amount. Con Edison may structure incentive payments differently to accommodate unique situations.

## 2.8 Coordination with NYSERDA Programs

NYSERDA implements programs to promote the adoption of electric heat pump technologies, such as through its NYS Clean Heat Market Enablement portfolio. When projects are eligible for both NYS Clean Heat program incentives as well as NYSERDA program funding sources, projects may be eligible to receive funding from both – provided that each program supports achievement of distinct outcomes.

In each project scenario, total combined funding from the NYS Clean Heat program and NYSERDA programs shall not exceed:

- 70% of total heat pump project cost, for market rate participants
- 85% of total heat pump project cost, for most Low-to-Moderate Income (“LMI”) participants as defined by the Statewide LMI Program Manual.<sup>13</sup>

Additional specific guidance may apply to a specific NYSERDA program and shall be made clear in the respective program’s description.

Con Edison may limit total combined funding for any project at any time.

## 2.9 Financing Options

### 2.9.1 Green Jobs – Green New York Financing

NYSERDA administers the Green Jobs – Green New York (“GJGNY”) Residential Financing Program, which was authorized by Title 9-A of Article 8 of the Public Authorities Law of the State of New York, as amended (known as the Green Jobs – Green New York Act) to finance energy audits and energy efficiency retrofits or improvements, including solar energy and other renewable installations, for the owners of residential one- to four-family buildings (“GJGNY Loan”).

The GJGNY Residential Financing Program offers three types of GJGNY Loans, which are unsecured loans up to twenty-five thousand (\$25,000) dollars for one- to four-family residential energy efficiency improvements or renewable energy system projects. The Smart Energy Loan (“SEL”) requires the Customer to make monthly loan payments directly to NYSERDA’s loan servicer, Concord Servicing Corporation (“Concord”). The On-Bill Recovery (“OBR”) Loan allows Customers to repay the GJGNY Loan through an installment charge on a bill from one of the involved electric or gas utilities (Central Hudson,

---

<sup>12</sup> NYS Clean Heat Contractor Resources, <https://cleanheat.ny.gov/contractor-resources/>

<sup>13</sup> New York State Affordable Multifamily Energy Efficiency Program, Program Manual Version 1.5, p 15 (Filed October 17, 2022). Available at <https://www.nyserdera.ny.gov/-/media/0E28A40DFFC94FFD9501280DC4700311.ashx>

Con Edison, Long Island Power Authority, National Grid – Upstate, New York State Electric and Gas Corporation, Rochester Gas and Electric Corporation, or Orange and Rockland Utilities). The utilities then remit repayments to Concord, who coordinates data communications with each utility. The Renewable Energy Tax Credit Bridge Loan (“Bridge Loan”) is a short-term loan product that enables customers to finance federal and state tax credits and New York City (“NYC”) Real Property Tax Abatement for eligible renewable energy system costs. Customers will make a balloon payment of principal and interest at loan maturity via statement billing/check or automatic clearing house (“ACH”) payment.

Complete details of these residential financing options can be found on the NYSERDA Residential Financing Options webpage.<sup>14</sup>

The ability to provide access to GJGNY and Companion Loans through the GJGNY Residential Financing Program is reserved exclusively for Participating Contractors, including the NYS Clean Heat Program Participating Contractors. At no time may a non-participating subcontractor of a Participating Contractor represent itself as having the ability to access GJGNY or Companion Loans. The Participating Contractor shall ensure that the GJGNY and Companion Loans are utilized only for the installation of those eligible measures and accessories identified in the supporting documentation submitted to, and satisfactorily approved by, the GJGNY Residential Financing Program.

The participation enrollment requirements, roles, and responsibilities of a Participating Contractor offering a GJGNY Loan can be found in the Green Jobs – Green New York Residential Program Manual, hereby incorporated in this Program Manual by reference and located on NYSERDA’s Become a Loan-offering Contractor homepage.<sup>15</sup> Participating Contractors are required to additionally execute the GJGNY Participation Agreement to participate in the GJGNY Residential Financing Program.

If a Participating Contractor wishes to offer financing other than GJGNY financing, they will need to comply with all applicable NYS and federal laws and regulations including NYS Banking Law.

## 3. Eligibility and Requirements

Projects and Participating Contractors must meet the requirements in this Program Manual for incentive eligibility.

### 3.1 Site Eligibility

Eligible sites include new and existing buildings owned or controlled by an active Con Edison customer where an eligible heat pump system for space heating, hot water heating, and/or process heating is being installed. Clean Heat incentives are not available to entities who do not participate in the System Benefits Charge (SBC).<sup>16</sup>

---

<sup>14</sup> NYSERDA Residential Financing Programs, <https://www.nyserdera.ny.gov/All-Programs/Residential-Financing-Programs>

<sup>15</sup> NYSERDA Become a Loan-offering Contractor, <https://www.nyserdera.ny.gov/All-Programs/Programs/Become-a-Contractor/Become-a-Loan-offering-Contractor>

<sup>16</sup> Case 18-M-0084, *In the Matter of a Comprehensive Energy Efficiency Initiative* (“NENY Proceeding”), P. 86, Order Authorizing Utility Energy Efficiency and Building Electrification Portfolios Through 2025 (issued and effective January 16, 2020).

## 3.2 Eligible Technologies

Eligible measures are grouped into several major categories:

- (1) Air Source Heat Pumps for space heating applications, including:
  - a. Cold Climate Air-to-Air Mini-Split Heat Pumps
  - b. Cold Climate Air-to-Air Single Packaged Heat Pumps
  - c. Air-to-Air Large Commercial Unitary Heat Pumps (single packaged or split system)
  - d. Air Source Variable Refrigerant Flow Heat Pumps
  - e. Packaged Terminal Heat Pumps
  - f. Single Package Vertical Heat Pumps
  - g. Air-to-Water Heat Pumps
- (2) Ground Source Heat Pumps for space and water heating applications
- (3) Heat Pump Water Heaters for domestic and service water heating applications, including:
  - a. Air-to-Water HPWHs
  - b. Ground Source Heat Pump Desuperheaters
  - c. Dedicated Water-to-Water Heat Pump added to Ground Loop
- (4) Energy Recovery Ventilators (ERVs) and Heat Recovery Ventilators (HRVs) paired with eligible heat pumps
- (5) Heat Recovery Chillers and Heat Pump Chillers
- (6) Building Envelope Upgrades paired with eligible heat pumps
- (7) Heat Pump Dedicated Outdoor Air Systems (HP-DOAS)
- (8) Advanced controls paired with eligible heat pumps

Heat pump systems used for space heating must be designed for either heating-only operations or both heating and cooling operations; cooling-only systems are not eligible for Clean Heat incentives. The eligibility of each group of technologies for incentives is summarized by category in Table 13.

*Table 13: Space Heating Eligibility by Technology and Category*

<b>Technology</b>	<b>Residential (2a, 2b, 2e, 3)</b>	<b>Non-Residential (2c, 2d, 4, 4a, 10)</b>
Mini-splits (MSHP)	Yes	Yes
Central ccASHP	Yes	Yes
Commercial Unitary (Split or Single)	No	Yes
ASVRF	Yes	Yes
ccPTHP	Yes	Yes
SPVHP	Yes	Yes
GSHP	Yes	Yes
GSVRF	Yes	Yes
Air-to-Water (AWHP)	Yes	Yes
Heat Recovery Chillers (HRC)	No	Yes
Heat Pump Chillers (HPC)	No	Yes
HP-DOAS	No	Yes

Technologies beyond those listed in Table 13 may be eligible to apply for Clean Heat incentives in the custom categories subject to Con Edison approval.

With the exception of Category 10 - Custom Partial Load Space Heating Applications, all heat pump systems shall be designed and sized for full-load heating as defined in Section 3.2.1 System Sizing.

The installation of used or refurbished equipment and components is not permitted under the program. For projects installed at new construction sites, all components installed as part of an approved GSHP or HPWH system must be new. For projects installed at existing sites, the heat pumps must be new and any system subcomponent or subassembly such as controls or ductwork that is replaced should be replaced by a new subcomponent or subassembly.

Heat pump projects are eligible for incentives when they replace other technologies and fuels (e.g., fuel oil, natural gas, propane, biomass, or electric resistance) in existing buildings. Projects which replace non-ccASHP units or non-Full Load ccASHP systems are also eligible for Clean Heat incentives.

All heat pumps must be installed by Participating Contractors and must be installed *after* January 17, 2023.

Refer to [Section 4](#) of this Program Manual for project application submission requirements including when to submit during a project's life cycle and required timeframes for heat pump installation.

### 3.2.1 System Sizing

The use of ASHPs in cold climates is growing rapidly, but system sizing and selection practices have not always kept up with the wide range of applications that are now available. System performance, comfort, and energy efficiency can be significantly impacted by poor sizing and system selection. The ASHP and any connected ductwork (if applicable) must be properly sized for the application to meet the building heat load requirements, ensure occupant comfort and satisfaction, and optimize system performance and energy savings. Participating Contractors must review and use the *NEEP Guide to Sizing and Selecting Air-Source Heat Pumps in Cold Climates*<sup>17</sup> to assist in sizing and selecting ccASHP equipment where applicable.

To be eligible for incentives, all heat pump systems must be sized in compliance with applicable state and municipal code.<sup>18</sup> Residential heating and cooling equipment and appliances shall be sized in accordance with ACCA Manual S or other approved sizing methodologies based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies.<sup>19</sup> Applicable exceptions shall apply.<sup>20</sup>

Participating Contractors are also encouraged to use additional design manuals as applicable to the system, including ACCA<sup>21</sup> Manual D: Duct Design,<sup>22</sup> ACCA Manual T: Air Distribution,<sup>23</sup> and ACCA Manual

---

<sup>17</sup> NEEP. "Guide to Sizing and Selecting Air-Source Heat Pumps in Cold Climates". Available at <https://neep.org/sites/default/files/Sizing%20%26%20Selecting%20ASHPs%20In%20Cold%20Climates.pdf>

<sup>18</sup> ECCCNY 2016, Section R403.7 and 2016 New York City Energy Conservation Code (NYCECC), Section R403.7. ECCCNY 2016 and 2016 NYCECC **require that** systems serving multiple dwelling units, where commercial code is applicable, follow Sections C403 and C404 of the respective codes. .

<sup>19</sup> 2020 Residential Code of NYS, Section 14, Section M1401.3 Equipment and appliance sizing

<sup>20</sup> One alternative sizing methodology resource, Alternate Methodology to Demonstrate Energy Code Compliance: Heat Pump Sized to Meet Heating Design Load, can be found under the Resources page of <https://cleanheat.ny.gov/contractors/>.

<sup>21</sup> Air Conditioning Contractors of America

<sup>22</sup> ACCA Manual D: Duct Design: Method used to determine the overall duct layout including the individual duct sizes.

<sup>23</sup> ACCA Manual T: Air Distribution: Method used to determine how to distribute airflow.

B: Test, Adjust and Balance.<sup>24</sup> All ASHP installers seeking to become Participating Contractors must provide documentation that they have completed a manufacturer-sponsored ASHP Sizing and Design Training course. Effective March 1, 2023, all existing participating ASHP contractors are required to take their preferred manufacturer's version of the ASHP Sizing and Design training and submit documentation of completion. Available trainings are posted on the Clean Heat Connect trainings calendar<sup>25</sup> and updated regularly.

Equipment installed in commercial buildings must be sized in accordance with heating and cooling load calculations following ANSI<sup>26</sup>/ASHRAE<sup>27</sup>/ACCA Standard 183-2007 (RA2017) or other code-approved equivalent computational procedure.<sup>28</sup> The output capacity of heating and cooling equipment shall not be greater than that of the smallest available equipment size that exceeds the calculated loads. A single piece of equipment providing both heating and cooling (such as a heat pump or heat pump system) shall satisfy this provision for one function with the capacity for the other function as small as possible, within available equipment options.<sup>29</sup>

All heat pump systems for full-load space heating shall be designed and sized to satisfy at least 100% of the building heating load ("BHL") at design conditions, with the ability to distribute heat adequately across all occupied spaces in the project scope. Heat pump systems for projects in categories that require decommissioning (e.g., Categories 2b, 2c, 2d, 2e, and 3) or include integrated controls (Category 2a) must be sized to meet 100% of the load over the project scope at design conditions and serve at least 80% of the building's total square footage. Projects in custom heating categories 4 and 4a shall be designed and sized to satisfy at least 90% of the building heating load ("BHL") at design conditions and are required to decommission legacy fossil fuel systems unless otherwise allowed by Con Edison. In cases where a building has a higher Building Cooling Load ("BCL") than BHL, the system must be sized to satisfy full BCL as required by relevant municipal or state code.

Category 10 - *Custom Partial Load Space Heating Applications* offers incentives for heat pump systems defined as a prioritized, first-stage heat pump systems installed alongside a supplemental, second-stage heating system for the purpose of providing heating. The supplemental heating system may be either a new or existing system. A partial load system has a total system heating capacity that satisfies less than 90% of the BHL at design conditions.

Category 6 - *Custom Hot Water Heating Applications* projects may also be considered for partial load heating, provided the incentive application sufficiently justifies this approach. If a proposed Category 6 *Custom Hot Water Heating Applications* project is a partial-load heating system, the project application must include an explanation as to:

---

<sup>24</sup> ACCA Manual B: Test, Adjust and Balance: Method designed to test and balance HVAC equipment in an order that speeds up and improves the balancing process.

<sup>25</sup> Clean Heat Connect trainings calendar, <https://cleanheatconnect.ny.gov/sizing-and-design-calendar/>

<sup>26</sup> American National Standards Institute

<sup>27</sup> American Society of Heating, Refrigerating, and Air-Conditioning Engineers

<sup>28</sup> ECCCNY 2016, Section C403.1.1 Calculation of heating and cooling loads

<sup>29</sup> ECCCNY 2016, Section C403.3.1. The intent of this section is to provide some flexibility in design for systems such as heat pumps that provide both heating and cooling. For a commercial building that has a higher building heating load ("BHL") than building cooling load ("BCL"), the heat pump system capacity shall be as small as possible so as to adequately satisfy the BHL, while minimizing oversizing for the cooling function to the extent possible with available equipment. For commercial buildings for which BCL is higher than BHL the heat pump system capacity shall be as small as possible so as to adequately satisfy the BCL, while minimizing oversizing for the heating function.



- Why additional electrification beyond the project’s proposed design is not feasible at the time of installation
- How a verifiable and reliable control strategy will be employed to ensure that the heat pump is prioritized for heating.

Each partial-load heating system will be subject to a review on a case-by-case basis.

The following examples match heat pump systems to the categories for which they are eligible to receive incentives:

- *Example 1, Category 4:* the heat pump system provides 110% of the heating load for an entire commercial building. Since the system provides more than 90% of the heating load for the building, it qualifies as a full load heating system and is eligible for incentives under category 4.
- *Example 2, Category 4:* the heat pump system is an independent heating system that satisfies 100% of the heating load of 3 floors of a 10-floor commercial building. The remaining 7 floors will be heated using the existing boilers. In this case, the program will consider the 3 floors in the scope of the project. Since the heat pumps satisfy more than 90% of the heating load for the areas they serve, they qualify as full load heating systems. The participating contractor has submitted justification for completing three of ten floors.
- *Example 3, Category 10:* the heat pump system offers over 4,000 MMBTU of savings, and serves 65% of the BHL in a full commercial building which retains its legacy fossil system.
- *Example 4, Category 3:* the heat pump system is a GSHP that serves 100% of the load in 80% of a residential house with the remaining 20% fulfilled by ASHP. The project will be eligible for full-load Category 3 incentives.

Equipment sizing may be determined using applicable equipment documentation, including:

- NEEP Cold Climate Air Source Heat Pump List product information sheet, if equipment is NEEP-listed.<sup>30</sup> For NEEP-listed equipment, the heating capacity shall be based on the equipment’s NEEP certificate maximum heating capacity values, while the cooling capacity shall be based on the equipment’s NEEP certificate minimum cooling capacity values. Project applications shall include the NEEP specification sheet with the corresponding version number of the NEEP equipment requirements, as applicable at the time of installation.
- AHRI certificate, where the product is not NEEP-listed
- Manufacturer engineering documentation, where the product is not NEEP-listed
- Manufacturer-developed software that is capable of assigning equipment capacity at entered design heating and cooling temperature, in accordance with ACCA Manual S, Standard 183, or other code-approved equivalent computational procedure

The Program reserves the right to request additional justification or documentation regarding heat pump system sizing, including for systems that have sizing ratios substantially greater than 120% BHL and 115% BCL.

Calculation of the BHL shall be at the 99% dry bulb heating design temperature for the most relevant ASHRAE (2021) location. Calculation of the BCL shall be at the 1% dry bulb cooling design temperature

---

<sup>30</sup> Information on performance of qualifying NEEP Cold Climate ASHPs is available at: ASHP (neep.org).

for the same ASHRAE location. Design temperature requirements in this Program Manual may be superseded by the local Authority Having Jurisdiction (“AHJ”). In such cases, contractors must provide documentation citing the applicable local requirement. ASHRAE design temperature requirements may also be superseded by manufacturer specific requirements. In such cases, Clean Heat applicants must provide documentation citing the applicable manufacturer’s requirement. Refer to Table 14 below for ASHRAE (2021) dry bulb heating and cooling design temperatures for various locations across New York State. The applicable location may be found in the Program’s Design Temperature Lookup Tool<sup>31</sup> by entering the project zip code.

*Table 14: Dry Bulb Design Temperatures*

City Name	2021 ASHRAE	
	99% Heating Dry Bulb (deg F)	1% Cooling Dry Bulb (deg F)
New York City - Central Park	17.3	87.9
New York City - JFK	17.5	86.7
New York City - LaGuardia	17.9	89.8
White Plains	12.9	86.4

Load calculations may use dry bulb temperatures that differ from those in Table 14, but in those cases, must be within five degrees (+/-) of the applicable values in Table 14.

### 3.2.2 Equipment Installation

To be eligible for Program incentives, Participating Contractors, or their agents, must install systems and system components in accordance with manufacturer specifications and installation requirements, and in compliance with all applicable laws, regulations, codes, licensing, and permit requirements including, but not limited to, the New York State Environmental Quality Review Act, the Statewide Uniform Fire Prevention and Building Code and State Energy Conservation Construction Code, the National Electric Code, Fire Codes, and all applicable state, city, town, or local ordinances and/or permit requirements. Participating Contractors and their agents must also follow best practices for all aspects of installation, including best practices for the appearance of the property upon project completion. Con Edison may verify adherence to these requirements and determine incentive eligibility based on its findings. Customers are allowed to submit Clean Heat applications for MF and C&I projects, subject to the approval of Con Edison.

Outdoor units should be installed above the local snow line. The appropriate corresponding snow line can be determined using the NYS Clean Heat Prescriptive Categories Incentive Calculator and Statewide Custom Clean Heat Calculator found on the NYS Clean Heat Resources webpage.<sup>32</sup> Systems must be installed to pass all requirements of the Con Edison Field Inspections and Oversight process detailed in Section 5, and its associated Inspection checklists.

<sup>31</sup> As available for download on the Contractor Resources webpage, under the Air Source Heat Pump (ASHP) section. <https://cleanheat.ny.gov/contractor-resources/>.

<sup>32</sup> <https://cleanheat.ny.gov/contractor-resources/>

### 3.2.3 Air-Source Heat Pumps

Air-source heat pumps transfer heat between the inside of a building and the outside air. A heat pump's refrigeration system consists of a compressor and two coils made of copper tubing (one inside and one outside), which are surrounded by aluminum fins to aid heat transfer. In the heating mode, liquid refrigerant in the outside coils extracts heat from the air and evaporates into a gas. The inside coils release heat from the refrigerant as it condenses back into a liquid. A reversing valve, near the compressor, can change the direction of the refrigerant flow for cooling as well as for defrosting the outside coils in winter.

Under the NYS Clean Heat Program, to be eligible for a program incentive, ASHP systems must either be listed on the NEEP Product List<sup>33</sup> or meet the criteria established in this Program Manual and the NYS Clean Heat Implementation Plan for equipment that is not covered by the NEEP Product List.

There are several categories of ASHPs eligible for the NYS Clean Heat Program, including:

- (1) Central ccASHPs that are identified on the NEEP Product List
- (2) Ductless or partially ducted mini-split heat pumps (“MSHP”) that are identified on the NEEP Product List and qualify as ccASHP. These include “single-head” (one indoor air handler per outdoor compressor) and “multi-head” or “multi-split” (more than one indoor air handler per outdoor compressor) units.
- (3) Commercial Unitary (i.e., Large Commercial) ASHPs (Split or Single Package)
- (4) Air Source Variable Refrigerant Flow (“ASVRF”)
- (5) Packaged Terminal Heat Pumps (“ccPTHP”)
- (6) Single Package Vertical Heat Pumps (“ccSPVHP”)
- (7) Air-to-water Heat Pumps (“AWHP”)

The heat pump system that is installed must be capable of operating year-round.

---

<sup>33</sup> The current specification and listed eligible units are available at <https://neep.org/ASHP-Specification>.

### 3.2.3.1 Central Cold Climate ASHPs

Central Air Source Heat Pumps listed by NEEP as ccASHPs have cooling capacities less than 65,000 Btu/h and are not contained within the same cabinet as a furnace with rated capacity greater than 225,000 Btu/h.<sup>34</sup> These units are typically sized to provide heating and cooling to the whole building through a central duct distribution system. They are generally a retrofit solution for existing buildings that are replacing central air conditioners, which were installed in conjunction with a separate heating system (typically a fossil fuel or electric furnace) that shares the same duct distribution system.

All individual heat pumps in the installed system must be listed by NEEP as ccASHPs, tested under AHRI test standard 210/240, powered by single-phase electricity, have cooling capacities <65,000 Btu/h, and may not be installed in the same cabinet as a furnace with heating capacity ≥225,000 Btu/h.

The Participating Contractor shall verify and document the system's operation with the equipment manufacturer's specifications.

### 3.2.3.2 Cold Climate Mini-Split Heat Pumps

Cold climate MSHPs are ccASHPs that can circulate refrigerant between an outdoor unit containing a variable capacity compressor and one or more indoor air handlers ("indoor units"). Cold climate MSHPs are often referred to as "ductless mini-splits" because they are typically ductless but can also be installed with short duct runs that enable single indoor units to serve more than one room at a time. For existing homes and businesses that have no central ductwork, cold climate MSHPs are a viable and energy efficient solution.

To be eligible for Clean Heat incentives, cold climate MSHPs must be on the NEEP ccASHP Product List and tested under AHRI test standard 210/240.

### 3.2.3.3 Commercial Unitary Systems/Large Commercial ASHPs

Large commercial ASHPs are systems that have either of the following characteristics:

- Include individual heat pump appliances that are powered by three-phase electricity or
- have rated cooling capacities ≥65,000 Btu/h

In addition, systems must consist of multi-speed or variable speed compressors. Constant speed systems are not eligible for incentives.

Large commercial ASHPs are a retrofit solution for businesses and multifamily buildings that currently have rooftop or central air conditioners, which were often installed in conjunction with a separate heating system.

Commercial ASHPs must meet the ENERGY STAR® specification for Light Commercial HVAC, which covers heat pumps with cooling capacity ranging from 65,000 Btu/h up to 240,000 Btu/h.<sup>35</sup> Systems with

---

<sup>34</sup> Code of Federal Regulations ("CFR") 10 CFR part 430, Subpart A, § 430.2 Definitions: definition of central air conditioner or central air conditioning heat pump: [https://www.ecfr.gov/cgi-bin/retrieveECFR?gp=&SID=29d99fa0a367f0166b9cc8528ad29023&mc=true&n=pt10.3.430&r=PART&ty=HTML#se10.3.430\\_12\\_](https://www.ecfr.gov/cgi-bin/retrieveECFR?gp=&SID=29d99fa0a367f0166b9cc8528ad29023&mc=true&n=pt10.3.430&r=PART&ty=HTML#se10.3.430_12_)

<sup>35</sup> ENERGY STAR Light Commercial HVAC specification:

individual heat pump appliance sizes of 240,000 Btu/h and above, must have efficiencies that exceed local energy code efficiency requirements. These systems are tested under AHRI Test Standard 340/360.

#### **3.2.3.4 Air Source Variable Refrigerant Flow Heat Pump Systems**

Air Source Variable Refrigerant Flow (ASVRF) systems are engineered direct exchange (DX) multi-split systems that circulate refrigerant between a variable capacity compressor and multiple indoor air handlers, each capable of individual zone temperature control. They provide some major advantages, including the ability for heat recovery that allows them to heat and cool different zones simultaneously, optimized performance across a range of zonal comfort levels and partial load conditions, and the avoidance of ductwork or the need for secondary circulation fluids such as chilled or heated water. Because they circulate refrigerant and allow for a separate outside air ventilation system, they require less ceiling space than conventional systems.

All ASVRF systems tested under AHRI standard 1230 are eligible. ASVRF systems up to 240,000 Btu/h cooling capacity must meet or exceed current ENERGY STAR® Light Commercial HVAC Key Product Criteria.<sup>36</sup> For systems with capacities greater than those covered by ENERGY STAR®, heat pump efficiencies must meet or exceed local energy code.

The Participating Contractor applying for incentives shall document that non-residential systems are sized according to the requirements of [Section 3.2.1](#).

ASVRF systems must comply with ASHRAE Standard 15-2019 Safety Standard for Refrigeration Systems and Designation and Classification of Refrigerants, which addresses refrigerant capacities and possible leakage, especially if the system serves small rooms, which could cause oxygen depletion. In addition, the ASVRF systems must comply with ASHRAE Standard 34-2019 Addendum L, which establishes the maximum refrigerant concentration limit ("RCL") of 26 lbs./1,000 ft<sup>3</sup> of room volume for occupied spaces. Systems must be installed to pass all requirements of the NYS Clean Heat quality control program and its associated Field Assessment checklists. More information on inspections can be found in Section 5.

#### **3.2.3.5 Cold Climate Packaged Terminal Heat Pumps (ccPTHP)**

A packaged terminal heat pump (PTHP) is a wall sleeve and a separate un-encased combination of heating and cooling assemblies specified by the builder, intended for a single zone and for mounting through the wall. It includes a prime source of refrigeration, separable outdoor louvers, forced ventilation, and heating availability by builder's choice of hot water, steam, or electricity. A PTHP utilizes reverse cycle refrigeration as its primary heat source and is equipped with supplementary heating via hot water, steam, or electric resistance heat.

Packaged terminal heat pumps are tested under AHRI standard 310/380. To be eligible for the program, each unit in the system must be listed on, or meet or exceed the criteria of, the NEEP Product List, i.e., be a ccPTHP (see also, NEEP Cold Climate PTHP Specification<sup>37</sup>).

---

[https://www.energystar.gov/products/heating\\_cooling/light\\_commercial\\_heating\\_cooling/light\\_commercial\\_hvac\\_key\\_product\\_criteria](https://www.energystar.gov/products/heating_cooling/light_commercial_heating_cooling/light_commercial_hvac_key_product_criteria)

<sup>36</sup> Like central ASHP, VRF systems are also covered under the ENERGY STAR Light Commercial HVAC specification: [https://www.energystar.gov/products/heating\\_cooling/light\\_commercial\\_heating\\_cooling/light\\_commercial\\_hvac\\_key\\_product\\_criteria](https://www.energystar.gov/products/heating_cooling/light_commercial_heating_cooling/light_commercial_hvac_key_product_criteria)

<sup>37</sup> The current specification and listed eligible units are available at <https://neep.org/ASHP-Specification>

### 3.2.3.6 Single Package Vertical Heat Pumps

A single package vertical heat pump (SPVHP) is an air-cooled commercial package air conditioning and heating equipment that is factory-assembled as a single package, has components that are arranged vertically, and is intended for exterior mounting on, adjacent interior to, or through an outside wall. These units may be powered by a single- or 3-phase current and may contain one or more separate indoor grilles, outdoor louvers, various ventilation options, indoor free air discharges, ductwork, well plenum or sleeves. SPVHPs utilize reverse cycle refrigeration as their primary heat source and may be equipped with supplementary heating via hot water, steam, gas, or electric resistance heat.

Single package vertical heat pumps are tested under AHRI standard 390. To be eligible for the program, SPVHP must meet or exceed the criteria listed in the NEEP Cold Climate SPVHP Specification<sup>38</sup>.

### 3.2.3.7 Air-to-Water Heat Pumps

Air-to-water heat pumps (AWHPs) are a type of ASHP that distributes heat in the form of hot water for hydronic heating systems. AWHPs can be reversible and provide chilled water for cooling by rejecting heat to the outside air. AWHPs generally cannot provide leaving water at the same temperatures as provided by boilers. To facilitate full-load heating with lower water temperatures, AWHP installations may require 1) additional baseboards, heat emitters, or hydronic air handler units (AHUs), or 2) a reduction in the heating load in the home by implementing significant weatherization improvements. Many AWHPs are reversible and can also provide chilled water for space cooling, usually via an AHU, and supply domestic hot water.

AWHPs can also be installed to meet some or all the domestic water heating load. Recognizing that mixed heat pump arrangements may be beneficial, the AWHP equipment can be sized and selected to meet only a portion of the building load if the remainder of the full load is served by a ASHP or a GSHP<sup>39</sup>. The combined unit sizes still must not exceed 120% of the BHL. Projects employing a mixed heat pump arrangement for AWHPs are eligible for only one program incentive.

The rating standard for air-to-water heat pump equipment is AHRI 550/590. However, a search of the AHRI directory in late 2021 revealed that no products were using this standard for product certification. To be eligible for an incentive under Category 2e, the AWHP equipment must be on the New York Clean Heat qualified product list ([AWHP QPL](#)<sup>40</sup>) or a list from Energy Star or NEEP, which are in development at the time of publication of this Program Manual.

For any manufacturer that wishes to have their product considered for addition to the [NYS Clean Heat AWHP QPL](#), please email the Clean Heat Program inbox at [nyscleanheat@ceadvisors.com](mailto:nyscleanheat@ceadvisors.com).

---

<sup>38</sup> The current specification and listed eligible units are available at <https://neep.org/ASHP-Specification>

<sup>39</sup> All GSHP systems must provide heating for 80% of square footage of the house

<sup>40</sup> To be on the QPL, the heating COP at 5°F ambient and 110°F leaving water temperature (A5W110) must be 1.7 or greater. Energy Star is building their “Heat Pump Boiler” specification due to be completed in 2024. Units larger than 72,000 Btu/h or not listed on the QPL, will be considered on a case-by-case basis.

### 3.2.4 Ground Source Heat Pumps

Ground source heat pumps (GSHPs), also known as geothermal heat pumps, achieve high efficiency by exchanging thermal energy with the ground or with groundwater instead of outside air. GSHP systems work well in cold climates because of their ability to maintain capacity at low ambient air temperature. GSHPs are installed in all building sectors and are expected to provide heat to the whole home or whole building.

GSHP systems also take advantage of the heat generated by the indoor compressor, particularly in cooling mode, by providing a desuperheater loop that pre-heats domestic hot water. GSHPs distribute heating and cooling in the building through a ducted air system, a water loop, refrigerant lines, or a combination of these. System performance depends on an effective ground heat exchanger design and proper installation. The ground heat exchanger design can be highly site-specific, given the variability of site conditions that affect ground conductivity or loop designs.

There are several categories of GSHPs eligible for the NYS Clean Heat Program, including:

- Open-Loop GSHPs
- Closed-Loop GSHPs
- Direct GeoExchange GSHPs
- Console GSHPs
- Non-Console GSHPs less than >24,000 Btu/h (2 tons)
- Ground-Source Variable Refrigerant Flow Systems (GSVRFs)

Customers or projects participating in Utility Thermal Energy Network ("UTEN") projects are not eligible for incentives in the NYS Clean Heat Program.<sup>41</sup>

#### **General Well/Borehole/Loop Field Requirements**

- All projects must comply with New York State Department of Environmental Conservation ("DEC") regulations for geothermal well drilling.<sup>42</sup>
- Projects in New York City must comply with NYC Department of Environmental Protection rules concerning drilling and excavation, including insurance requirements.
- For non-DX systems, only polyethylene piping is appropriate for underground loop field piping.
- For large scale systems, Participating Contractors must show rated walls and ceilings and specify firestopping of pipe penetrations.
- All well/bore fields must provide adequate well/bore spacing and thermal dispersion to accommodate the thermal load and thermal balance.
- For large GSHP systems, provide emergency eye washes on site during installation, as required by OSHA.
- Piping must be stored on site in a manner that prevents damage and the introduction of foreign matter. Piping shall be kept free from damage, debris, and foreign matter during installation.

---

<sup>41</sup> UTEN/ TEN projects are defined by the New York Department of Public Service in Case 22-M-0429, filing dated December 1, 2023.

<sup>42</sup> NYS DEC guidance for Geothermal Wells Deeper Than 500 Feet, <https://www.dec.ny.gov/energy/1748.html>, and NYS DEC Well Permitting Requirements, <https://www.dec.ny.gov/energy/1783.html>.

- Grout and admixtures must be received and stored in a way that protects them from moisture and contamination.
- Manifolds installed underground or in a buried enclosure must have proper valves, pressure, and temperature ports.
- All equipment and system parts should be labeled per IGSHPA and ASHRAE guidelines.
- Performance tests must be verifiable. Temperatures, pressures, flow rates, control valve operation, controls, balancing reports, sequence of operations, power measurements, software, start-up and commissioning efforts and reports are all subject to review and observation.
- Projects must meet all setback requirements enforced by the local authority having jurisdiction.
- It is also recommended that GSHP systems meet the ANSI/CSA C448 Series-16 standard.

### **Vertical-Loop Systems**

Any vertically bored, closed-loop GSHP system must have a borehole depth that is sufficient to provide a minimum entering water temperature to the heat pump of 30°F in heating mode and a maximum entering water temperature to the heat pump of 90°F in cooling mode. The system must be designed in accordance with manufacturer specifications and installation requirements.

Exception: Vertically bored ground loops designed for a minimum entering water temperature >25°F and <30°F in Department of Energy Climate Zones 5 and 6 shall be considered eligible provided they meet the following additional criteria:

1. Heat Pumps shall be designed to provide at least 100% of the building heating load without supplemental heating.
2. Requires submission of loop sizing documents signed off by a New York State Professional Engineer or Certified GeoExchange Designer.

### **Closed-Loop Systems**

Unless specifically superseded by the requirements detailed in this Program Manual, the design and installation of closed loop GSHP systems (including ground-loop and interior systems) must comply with the standards and practices outlined in the most recent edition of the Closed-Loop/Geothermal Heat Pump Systems: Design and Installation Standards edited by the IGSHPA Standards Committee and published by the International Ground Source Heat Pump Association. These standards are available online on the IGSHPA website.<sup>43</sup>

Table 15 presents program requirements for the maximum allowable rated pumping power at design conditions (based on duty point), as well as good-practice guidance based on an ASHRAE GSHP Design Guide<sup>44</sup> for large systems and field measurements for small systems.

---

<sup>43</sup> International Ground Source Heat Pump Association, <https://igshpa.org/manuals>

<sup>44</sup> Kavanaugh and Rafferty (2014). Geothermal Heating and Cooling: Design of Ground-Source Heat Pump Systems. American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE).



Table 15: Maximum Allowable and Good Practice Pumping Power for Closed-Loop GSHP Systems in watts (W) per AHRI rated full-load heating or cooling capacity of the installed system

GSHP System Size	Maximum Allowable Pumping Power in watts (W) per 10,000 Btu/h of full-load heating capacity OR in watts (W) per ton of full-load cooling capacity	Good Practice Pumping Power in watts (W) per 10,000 Btu/h of full-load heating capacity OR in watts (W) per ton of full-load cooling capacity
Individual GSHP units in residential and small commercial applications where each GSHP unit has its own dedicated loop pump	100	Less than 75
Large GSHP systems with multiple heat pump units served by centralized ground loop pumping	85	Less than 60

**Closed Loop Antifreeze Protection Requirements:** Propylene glycol (CAS No. 57-55-6), methanol (CAS No. 67-56-1) and ethanol (CAS No. 64-17-5) are the three presumptively acceptable antifreeze additives for use in the loop field. Use of any other antifreeze requires prior approval from the Joint Efficiency Providers. The acceptable denaturants for ethanol additives are denatonium benzoate (CAS No. 3734-33-6), ethyl acetate (CAS No. 141-78-6), isopropanol (CAS No. 67- 63-0), pine oil (CAS No. 8002-09-3), and tertiary butyl alcohol (CAS No. 75-65-0).

Large systems with ethanol and methanol must comply with Section 1207 of the 2020 Mechanical Code of New York State and, therefore, “the flash point of transfer fluid in a hydronic piping system shall be not less than 50°F above the maximum system operating temperature.”

The maximum allowable concentration of methanol is 12.5% by weight. The maximum allowable loop field temperature in small systems using methanol as an antifreeze is 75°F. In addition, the designer and installer should ensure the loop field operating temperature is at least 50°F lower than the flash point of methanol at all times.

The maximum allowable concentration of ethanol is 10% by weight. The maximum allowable loop field temperature in a small system using ethanol as an antifreeze is 70°F. In addition, the designer and installer should ensure that the loop field operating temperature is at least 50°F lower than the flash point of ethanol at all times.

For loop fields with glycol or organic antifreeze, the Participating Contractor must sterilize with a chlorine shocking protocol that is similar to what is required in potable water plumbing systems. If the manufacturer recommends specific disinfection, the Participating Contractor should follow the manufacturer’s protocols.

### Horizontal-Loop Systems

Horizontal loops must be installed below the frost line and have a surface area that is sufficient to provide a minimum entering water temperature of 30°F to the heat pump in heating mode and a maximum entering water temperature of 90°F to the heat pump in cooling mode. Systems must be designed in accordance with manufacturer specifications and installation requirements. Incentive applications must include the file from the horizontal-loop design software showing inputs and system design specifications.

Exception: Horizontal ground loops designed for a minimum entering water temperature >25°F and <30°F in Department of Energy Climate Zones 5 and 6 shall be considered eligible, provided that they meet the following additional criteria:

- Heat pumps shall be designed to provide at least 100% of the Building Heating Load without supplemental heating
- Requires submission of loop sizing documents signed off by a New York State Professional Engineer or Certified GeoExchange Designer

**Open-Loop Systems**

A standing column well must include a bleed circuit, drywell, or locally approved receptor to maximize thermal efficiency based on available water production.

Incentive applications must quantitatively explain the method for determining pressure and flow rate. All projects must comply with DEC regulations for geothermal well drilling, which can be found on the DEC website.<sup>45</sup>

All projects must comply with ANSI/CSA/IGSHPA C448.6, *Installation of open-loop systems ground water heat pump systems*. All standing column well projects must comply with ANSI/CSA C448.7, *Installation of standing column well heat pump system*.

Table 16 presents program requirements for the maximum allowable rated pumping power at design conditions (based on duty point), as well as good-practice guidance.

*Table 16: Maximum Allowable and Good Practice Pumping Power for Open-Loop GSHP Systems in watts (W) per AHRI rated full-load heating or cooling capacity of the installed system*

<b>GSHP System Size</b>	<b>Maximum Allowable Pumping Power in watts (W) per 10,000 Btu/h of full-load heating capacity OR in watts (W) per ton of full-load cooling capacity</b>	<b>Good Practice Pumping Power in watts (W) per 10,000 Btu/h of full-load heating capacity OR in watts (W) per ton of full-load cooling capacity</b>
Individual GSHP units in residential and small commercial applications where each GSHP unit has its own dedicated loop pump	140	Less than 105

<sup>45</sup> NYS DEC guidance for Geothermal Wells Deeper Than 500 Feet, <https://www.dec.ny.gov/energy/1748.html>, and NYS DEC Well Permitting Requirements, <https://www.dec.ny.gov/energy/1783.html>

Large GSHP systems with multiple heat pump units served by centralized ground loop pumping	120	Less than 90
--	-----	--------------

### Direct Exchange System

Direct exchange (DX) heat pumps, which circulate a refrigerant typically through a closed-loop copper pipe system (whereas most systems utilize plastic pipes that circulate water or a water-antifreeze mixture), must meet the following additional conditions:

- DX systems must have a minimum loop field length of 100 feet per 12,000 Btu/h of heating capacity.
- DX wells require cathodic protection ensuring a minimum expected well life of 25 years.
- DX system owners must certify that they will undergo an end-of-life decommissioning that includes full-refrigerant recovery.
- The refrigerant must be R-410A unless otherwise approved by the Joint Efficiency Providers.
- The entire well depth interval for DX wells is grouted with thermally enhanced grout with hydraulic conductivity below  $1 \times 10^{-7}$  centimeters/second.
- A permanent placard must be attached to the heat pump unit, detailing the following:
  - loop field refrigerant content, type, and volume
  - loop location description
  - loop piping material
  - required maintenance schedule on loop field, refrigerant, and heat pump
  - planned decommissioning date and process, consistent with loop field useful life
- DX systems must also comply with ANSI/CSA/IGSHPA C448.8, "Installation of direct expansion heat pump systems."
- DX GSHP systems must use only ACR B280 Copper Piping for Underground Loop Field.
- DX GSHP systems must conform to requirements of ASHRAE Standard 15-2019.

### Large GSHP System-Specific Requirements

- For large systems, a loop field design includes:
  - Loop/site plan
  - Loop sizing report (flexible)
  - Loop field pressure drop calculations
  - Antifreeze type and concentration
  - System documentation must include a piping schematic accurately representing below grade and above grade piping strategy
- Large systems with ethanol and methanol must comply with Section 1207 of the 2015 Mechanical Code of New York State and, therefore, "the flash point of transfer fluid in a hydronic piping system shall not be less than 50°F above the maximum system operating temperature."
- Large systems must implement the following:
  - Show rated walls and ceilings and specify firestopping of pipe penetrations
  - Detail cross connection control devices in the design
  - Conform to the requirements and standards of ASHRAE 15

## Thermal Conductivity Tests

Thermal conductivity test boreholes are required for all projects in which a ground heat exchanger with a system capacity greater than 300,000 Btu/hr is being installed. Additionally, thermal conductivity test boreholes are recommended for all projects in which a ground heat exchanger with a system capacity between 135,000 Btu/hr and 300,000 Btu/hr is being installed. Testing should conform to the requirements detailed in the latest edition of the ASHRAE Applications Handbook and must report undisturbed ground temperature.

## Thermal Conductivity Testing Incentives

Con Edison has introduced a Thermal Conductivity Testing (“TCT”) Incentive for non-residential GSHP projects to help customers pay for thermal conductivity testing. The TCT Incentive is \$40,000, or 50% of eligible thermal conductivity test project costs, whichever is lower.

Prior to testing, applicants must submit a pre-testing application package. Con Edison will review the pre-testing application package to determine eligibility. After review, Con Edison will provide written confirmation of eligibility to the applicant.

The pre-testing application package must contain:

- An executive summary of the prospective GSHP project, including
  - Project narrative and scope
  - Project type (e.g., new construction, gut renovation or retrofit)
  - Building type
  - Description of existing systems
  - Existing heating fuel type
  - Conditioned square footage
  - Number of dwelling units
  - Project timeline
- A completed TCT Incentive Application form
- An itemized list of expenses, including
  - Drilling
  - Thermal Conductivity Testing
  - Solids/fluid disposal
  - Site rehabilitation
  - Permitting
- A testing plan, including
  - Testing timeline
  - Drilling Program
  - Applicable drilling, excavation and waste handling permits
  - Site plan

After testing has been completed, the Participating Contractor must submit a post-testing application package. Con Edison will review the post-testing application package to determine the final incentive. Upon successful review, Con Edison will pay the incentive to the customer or the Participating Contractor as indicated on the TCT Incentive Application form.

The post-testing application package must contain:

- A final itemized TCT invoice
- Submission of thermal conductivity test results, well completion reports and any other associated findings
- The executive summary, updated based on the results of the TCT

Thermal conductivity testing must be conducted on the same site as a prospective GSHP project. The prospective project must be eligible for GSHP incentives under NYS Clean Heat Program Multifamily or C&I categories 4/4a/6/10. Applicants for the TCT Incentive must be Clean Heat Participating Contractors.

The TCT must adhere to the ASHRAE Handbook – HVAC Applications: Ground-Source Heat Pumps and Geothermal Energy, Thermal Property Testing.

Thermal conductivity tests must be performed after March 1st, 2024.

Each prospective GSHP project is eligible for a maximum of one TCT Incentive.

Con Edison shall have the right to disseminate the test results from projects which received a TCT Incentive publicly or privately, in aggregated and disaggregated form.

### 3.2.4.1 Open-Loop GSHPs, Closed-Loop GSHPs, and Direct GeoExchange GSHPs

To be eligible for program incentives, single phase GSHPs must meet or exceed Geothermal ENERGY STAR® specifications.<sup>46</sup> These systems must have a closed loop ground heat exchanger circulating a water/antifreeze solution, an open loop heat exchanger, or a direct expansion (DX) heat exchanger. ENERGY STAR® eligibility is based on the following test procedures to determine GSHP appliance Energy Efficiency Ratio (“EER”) and Coefficient of Performance (“COP”):

- Closed Loop Systems:
  - ISO 13256-1-1998 “Water-source heat pumps – Testing and rating for performance – Part 1: Water-to-air and brine-to-air heat pumps” for water to air models; OR
  - ISO 13256-2-1998 “Water-source heat pumps – Testing and rating for performance – Part 2: Water-to-water and brine-to-water heat pumps” for water-to-water models.
- Direct Exchange Systems: AHRI 870 (I-P/2016) and AHRI Standard 871 (SI) – 2016 “Performance Rating of Direct GeoExchange Heat Pumps”

Eligibility for any GSHP less than 135,000 Btu/h of cooling capacity may be obtained from an AHRI rating certificate. For units larger than 135,000 Btu/h cooling capacity, which are not rated by AHRI, manufacturer specification sheets may be used instead, provided the units have been tested in accordance with the applicable test procedure.

For multi-stage systems for which AHRI certificates are not available, the EER and COP must be calculated using the following equations:

- $EER = (\text{full load EER} + \text{part load EER})/2$
- $COP = (\text{full load COP} + \text{part load COP})/2$

Calculation of the EER and COP values must be determined using the following AHRI-rated data:

- Ground loop heat pump (GLHP) for closed-loop system
- Direct GeoExchange for DX systems

### 3.2.4.2 Console GSHPs

Console GSHP systems must meet or exceed the minimum efficiencies listed in Table 17 below. GSHP console units must have an AHRI-rated EER and an AHRI-rated COP. These systems do not need to meet or exceed the ENERGY STAR® Geothermal heat pump specification efficiency requirements.

---

<sup>46</sup> ENERGY STAR references:

[https://www.energystar.gov/products/heating\\_cooling/heat\\_pumps\\_geothermal/key\\_product\\_criteria](https://www.energystar.gov/products/heating_cooling/heat_pumps_geothermal/key_product_criteria)  
[https://www.energystar.gov/sites/default/files/specs//private/Geothermal\\_Heat\\_Pumps\\_Program\\_Requirements%20v3.1.pdf](https://www.energystar.gov/sites/default/files/specs//private/Geothermal_Heat_Pumps_Program_Requirements%20v3.1.pdf)  
<https://www.energystar.gov/productfinder/product/certified-geothermal-heat-pumps/results>

Table 17: Efficiency Requirements for Console Units

System Type	EER	COP
Water-to-Air		
Closed-Loop Water-to-Air	14.0	3.0
Open-Loop Water-to-Air	14.0	3.0
Water-to-Water		
Closed-Loop Water-to-Water	N/A	N/A
Open-Loop Water-to-Water	N/A	N/A
Direct Exchange		
Direct Exchange	N/A	N/A

The EER and COP must be calculated using the following equations:

- $EER = (full\ load\ EER + part\ load\ EER)/2$
- $COP = (full\ load\ COP + part\ load\ COP)/2$

### 3.2.4.3 Non-Console GSHPs less than >24,000 Btu/h (2 tons)

GSHP systems that are not console units and have AHRI-rated cooling capacities less than 24,000 Btu/h (2 tons) must have AHRI-rated EER and AHRI-rated COP efficiencies greater than the efficiencies shown in Table 18. These systems do not need to meet or exceed the ENERGY STAR® Geothermal heat pump specification efficiency requirements.

Table 18: Efficiency requirements for non-console units with AHRI-rated cooling capacities < 24,000 Btu/h

System Type	EER	COP
Water-to-Air		
Closed-Loop Water-to-Air	15.0	3.2
Open-Loop Water-to-Air	20.0	4.1
Water-to-Water		
Closed-Loop Water-to-Water	16.6	3.1
Open-Loop Water-to-Water	20.1	3.5
Direct Exchange		
Direct Exchange	N/A	N/A

### 3.2.4.4 Ground-Source Variable Refrigerant Flow Systems (GSVRFs)

GSVRFs must meet the applicable minimum efficiency requirements in the subsequent tables. These systems do not need to meet or exceed the ENERGY STAR® Geothermal heat pump specification efficiency requirements.

Table 19: Efficiency requirements for GSVRF

Equipment Type	Cooling Capacity (Btu/h)	Min. EER at 77F EWT	Min. COP at 32F EWT	Testing Procedure
Ground Source VRF multisplit system	<135,000	14.7	3.4	AHRI 1230
	≥135,000	12.1	3.1	AHRI 1230
Ground Source VRF multisplit system with heat recovery	<135,000	14.5	3.4	AHRI 1230
	≥135,000	11.9	3.1	AHRI 1230

Table 20: Efficiency requirements for GSVRF heat pumps tested under AHRI 1230 groundwater source configuration, however intended to be used in a ground source configuration

Equipment Type	Cooling Capacity (Btu/h)	Min. COP at 50F EWT	Testing Procedure
Groundwater Source VRF multisplit system	<135,000	3.6	AHRI 1230
	≥135,000	3.3	AHRI 1230



Table 21: Efficiency requirements for Water Source VRF heat pumps tested under AHRI 1230 water source configuration, however intended to be used in a ground source configuration.

Equipment Type	Cooling Capacity (Btu/h)	Min. EER at 86F EWT	Min. EER at 86F EWT (with heat recovery)	Min. COP at 68F EWT	Testing Procedure
Water Source VRF multisplit system	<65,000	13.2 EER 17.6 IEER	13 EER 17.4 IEER	4.7	AHRI 1230
	> 65,000 < 135,000	13.2 EER 17.6 IEER	13 EER 17.4 IEER	4.7	AHRI 1230
	≥ 135,000 < 240,000	11.0 EER 15.4 IEER	10.8 EER 15.2 IEER	4.4	AHRI 1230
	≥ 240,000	11 EER 13.2 IEER	10.8 EER 15.2 IEER	4.3	AHRI 1230

EER and COP calculations for such systems must be calculated using the full-load EER and full-load COP.

GSHPs may have additional requirements specific to the type of ground heat exchanger to which the GSHP system is coupled. Systems must be installed to pass all requirements of the Con Edison Field Inspections and Oversight program and its associated inspection checklists. More information on quality control is included in Section 5: Field Inspections and Oversight.

### 3.2.5 Heat Pump Water Heaters and Ground Source Water-to-Water Heat Pumps

In addition to space heating, the NYS Clean Heat Program for Con Edison also promotes the use of heat pump technology for heating domestic hot water, as a replacement or in new construction in lieu of common electric resistance or fossil fuel water heaters. As with space conditioning heat pump technologies, for retrofit applications, the program will require that applicants report the existing water heating fuel that is being replaced; for new construction, the replaced unit will be determined on a case-by-case basis, based on contemporary construction practice in the area.

As with space conditioning, heat pump water heaters can be air-source or ground-source technology and must be sized according to manufacturers' recommendations.

The Program offers incentives for residential HPWH through a Midstream Program discussed in Section 4.4. This Program incentivizes HPWH with a Uniform Energy Factor (UEF) rating, and a current rating  $\leq 24$  amps and voltage  $\leq 250$  volts<sup>47</sup> that meet or exceed ENERGY STAR Residential Water Heater requirements.<sup>48</sup>

<sup>47</sup> 10 CFR 430.2 – Definitions.

<sup>48</sup> See [energystar.gov: energystar.gov/products/water\\_heaters/residential\\_water\\_heaters\\_key\\_product\\_criteria](http://energystar.gov/products/water_heaters/residential_water_heaters_key_product_criteria)

Air Source HPWH without a UEF rating<sup>49</sup> shall receive incentives based on \$/MMBtu of annual energy savings, under Category 6 *Custom Hot Water Heating Applications*.

### **3.2.5.1 Air-to-Water Heat Pump Water Heater**

Air-to-Water HPWHs are water heater tanks that heat domestic hot water using an onboard air source heat pump that extracts heat from the air in the building surrounding the unit. They use a secondary electric resistance as a back-up to ensure that the water temperature meets the desired setpoint during times of high demand. Air source HPWH models come in two versions (integrated and split-system HPWH) and both versions are eligible for incentives under the Program.

Air-to-water HPWH having a Uniform Energy Factor (UEF) rating are eligible for Category 5 incentives. Larger systems and custom applications are eligible for Category 6 *Custom Hot Water Heating Applications*.

To be eligible for an incentive under the Program, an air-to-water HPWH must meet or exceed ENERGY STAR® water heater specifications.

### **3.2.5.2 Ground Source Desuperheaters and Dedicated DHW Water to Water Heat Pumps**

Ground source systems can reduce DHW energy consumption by two optional methods: 1) Using a GSHP unit with a desuperheater or 2) adding either a separate water-to-water heat pump (WWHP) to the ground loop that is dedicated to meeting the DHW load, or sizing a WWHP to meet the DHW as well as the space heating loads.

Desuperheaters are available on most GSHP models. A desuperheater recovers heat from the GSHP's compressor during both cooling and part-load heating mode and transfers it to the DHW tank. Thus, they satisfy a portion of the building's annual DHW load. They therefore require some form of complementary water heating.

Full-load DHW WWHPs can either be installed as a priority zone on a GSHP HVAC system, or as a stand-alone system. They are designed to provide all of the building's DHW needs.

Desuperheaters and WWHP are eligible for Category 6 *Custom Hot Water Heating Applications* incentives.

A full-load DHW WWHP must meet or exceed ENERGY STAR® Geothermal Heat Pump specification requirements<sup>50</sup> or the efficiency requirements listed in [Section 3.2.3](#) for Non-ENERGY STAR® Compliant Geothermal Heat Pumps to be eligible for incentives.

Dedicated Ground Source DHW WWHPs (>120 gallons) shall receive incentives based on \$/MMBtu of

---

<sup>49</sup>

[https://www.energystar.gov/products/water\\_heaters/commercial\\_water\\_heaters/key\\_product\\_criteria](https://www.energystar.gov/products/water_heaters/commercial_water_heaters/key_product_criteria)

<sup>50</sup> ENERGY STAR Program Requirements for Geothermal Heat Pumps. Current link:

[https://www.energystar.gov/sites/default/files/specs//private/Geothermal\\_Heat\\_Pumps\\_Program\\_Requirements](https://www.energystar.gov/sites/default/files/specs//private/Geothermal_Heat_Pumps_Program_Requirements)

energy savings under Category 6 *Custom Hot Water Heating Applications*.

#### Equipment Installation:

Ground Source HPWH loop requirements are the same as those for GSHP, described in [Section 3.2.3](#).

#### 3.2.6 Energy Recovery Ventilators (ERVs) and Heat Recovery Ventilators (HRVs)

Energy Recovery Ventilators (ERVs) and Heat Recovery Ventilators (HRVs) reduce heating and cooling loads while maintaining required ventilation rates by facilitating heat transfer between outgoing conditioned air and incoming outdoor air. ERVs and HRVs employ air-to-air heat exchangers to recover energy from exhaust air for the purpose of pre-conditioning outdoor air prior to supplying the conditioned air to the space, either directly or as part of an air-conditioning system. When paired with a heat pump system, the ERV/HRV can significantly reduce the size of the required HVAC system.

For the purposes of this measure, ERVs and HRVs are distinguished as follows:

- ERV: Transfers both sensible (heat content) and latent (moisture content) heat between supply and exhaust airstreams.
- HRV: Transfers sensible heat only between supply and exhaust airstreams.

Only ERV/HRVs that have efficiencies which meet or exceed federal, state, or municipal codes or standards paired with an eligible heat pump system are eligible for incentives. Incentive category and rate shall be the same as that given to the eligible heat pump system.

#### 3.2.7 Heat Recovery Chillers and Heat Pump Chillers

Heat recovery chillers ("HRC") and heat pump chillers ("HPC") are systems that provide space and water heating (hot water) to a building by recovering heat from a low temperature source. Low temperature sources may include air, water, or waste heat sources. These systems can also provide chilled water for cooling. Unlike HPCs, HRCs can provide simultaneous heating and cooling but do not have to do so at all times.

HRCs/HPCs eligible to receive Clean Heat incentives in custom space and hot water categories (4, 4a, 6 and 10) are subject to the same incentive limitations as all other heat pump projects. To be eligible for Clean Heat incentives, HRC/HPCs must be electrically operated and meet or exceed the minimum efficiency requirements at operating conditions set forth in ASHRAE Standard 90.1-2022 under AHRI 550/590. Heat recovery chillers and heat pump chillers are exempt from minimum annual baseline heating consumption displacement thresholds for Category 10 eligibility.

If AHRI certificates containing heating performance under AHRI standard 550/590 are not available, data must be presented by the manufacturer's representative that satisfy ASHRAE 90.1-2022, Table 6.8.1-16 calculated with parameters consistent with AHRI standard 550/590 under heating and cooling operation appropriate for the project.

The JMC has developed a tool, the Statewide Heat Recovery Chiller Calculator ("SHRCC"), available on the Contractor Resources webpage, to help applicants calculate the savings and incentives associated with Heat Recovery Chillers. The current iteration of the SHRCC calculates savings for water-to-water

HRC running nearly year-round (more than 6,000 EFLH).

Con Edison reserves the right to decline to offer incentives for HRC which are primarily used for cooling and do not meet the spirit of the Clean Heat Program.

### 3.2.8 Envelope Measures (for Category 4A: Heat Pump + Envelope)

The building envelope, which includes the walls, windows, roof, and foundation, forms the primary thermal barrier between the interior and exterior environments. The building envelope plays a key role in determining optimal comfort levels, ventilation, natural lighting, and energy needed for heating and cooling. Envelope improvements help regulate indoor climate (temperature control, air quality, etc.) and protect against the outdoor environment (drafts, condensation, etc.).

Without a properly insulated building envelope, the heating and cooling systems will not work as effectively, making this an essential element in creating a higher-performing building. Eligible building envelope upgrades or retrofits should be quantifiable and directly impact heat pump sizing and include locating and sealing air leaks, increasing wall/roof insulation, window replacement, and weatherstripping windows and doors.

The impact from the building envelope upgrades should be captured in the load calculations for pre- and post-conditions calculated per Manual J or ACCA 183.

Projects otherwise eligible for Category 4 *Custom Space Heating Applications* a significant envelope upgrade. The envelope upgrade must produce a quantifiable impact on the heat pump sizing to be eligible for a packaged approach (refer to [Section 3.2.6.1](#) below). When combined, the existing building envelope will be used as a baseline for calculating energy savings for existing buildings including those undergoing a gut rehab. New construction projects must use the New York State code as the baseline for savings analysis, and where applicable also comply with local code. Eligibility for Clean Heat incentives may be governed by compliance with applicable code. The incentives will be offered based on the MMBtu savings from both the envelope measures and the HP measures based on the tier for which a project qualifies. If an ERV/HRV is installed alongside an eligible heat pump plus envelope project, the ERV/HRV will also be incentivized at a Category 4a rate.

Eligible measures may include:

- Exterior: window replacements, window film
- Opaque shell: wall insulation, continuous insulation, window walls, curtain walls, exterior façade
- Air leakage sealing, air barrier continuity
- Roof insulation

#### **3.2.8.1 Eligibility Tiers for Category 4A: Custom Space Heating Applications + Envelope**

Category 4a offers incentives to projects that reduce their dominant load, either BHL or BCL, via improvements to the building envelope. To be eligible for Category 4a, projects must exceed the requirements captured in Table 22. To be eligible for Tier 1, existing buildings must lower their dominant load by at least 5%, while buildings undergoing a gut rehab or new construction must exceed applicable code, whichever is more stringent, by at least 5%. To be eligible for Tier 2, existing buildings must lower their dominant load by 30% from existing conditions, while buildings undergoing gut rehabs or new

construction must exceed the relevant code, whichever is more stringent, by 10%. The savings will be measured off the Incentive Baseline in the final column.

Table 22: Eligibility Tiers for Category 4a

Construction type	Eligibility Criteria	Tier 1 Requirement	Tier 2 Requirement	Incentive Baseline
Existing buildings	Exceed existing condition	> 5%	>30%	Existing condition
Existing buildings - Gut Rehab	Applicable code (NYSECC or NYCECC)	> 5%	>10%	Existing condition
New Construction (GSHP only)	Applicable code (NYSECC or NYCECC)	> 5%	>10%	Applicable code (NYSECC or NYCECC)

### 3.2.8.2 Infiltration Guidance

Projects should adhere to guidelines for natural (unpressurized) air changes per hour (ACH<sub>N</sub>) at heating design conditions.<sup>51</sup> Blower door testing should be used to verify rates of air exchange that are different from these guidelines, as described in the whitepaper. Pre-inspection can identify exceptions requiring justification and review. Please see Table 23 below for details.

Table 23: Infiltration Guidance

Infiltration Level by project type	Maximum Allowed ACH <sub>N</sub> at Design Heating Load <sup>52</sup>
New construction or gut rehabs Tight – Non-operating windows or best quality windows; sealed penetrations in envelope; vapor barrier	0.3
Existing building retrofit Average – Standard quality windows; major penetrations sealed; vapor barrier; glass less than 20% of wall area	0.7

### 3.2.9 Heat Pump Dedicated Outdoor Air Systems (HP-DOAS)

Heat pump dedicated outdoor air units (HP-DOAS) dehumidify 100% outdoor air to a low dew point in the cooling season and heat 100% outdoor air during heating season and deliver this conditioned air to the building interior. HP-DOAS efficiency can be increased by energy recovery wheels or plates, which transfer energy between exhaust and intake air streams. HP-DOAS may have low temperature lockouts and/or electric coil or fossil backup heating systems at low outside temperature.

HP-DOAS are eligible to receive Clean Heat incentives in custom categories 4, 4a and 10, and are subject

<sup>51</sup> Infiltration Guidance for Buildings at Design Conditions - For the NYS Clean Heat Program. Hugh Henderson, Bruce Harley. May 1, 2022. Accessible on the NYS Clean Heat Resources webpage: <https://cleanheat.ny.gov/contractor-resources/>.

<sup>52</sup> Listed maximum values cannot be exceeded unless written documentation justifying a higher value is provided and approved by the Program.

to the same incentive limitations and requirements within those categories. To be eligible for Clean Heat incentives, HP-DOAS must meet or exceed the minimum efficiency requirements set forth in ASHRAE Standard 90.1-2016 (or latest version of 90.1, whichever is stringent, as applicable) tables 6.8.1-15 and 6.8.1-16 under AHRI 920.

Since AHRI certificates with above parameters generated under AHRI 920 may not be available, the applicant must provide documentation from the manufacturer's representative demonstrating that the HP-DOAS meets above criteria.

For HP-DOAS with energy recovery, the applicant must also provide documentation defining if the energy recovery is required, or not required, by code per NYS ECC 2020 section C403.7.4 as well summer and winter efficiency parameters for energy recovery.

### 3.2.10 Advanced Controls for Heating Electrification

Advanced Controls are defined as those that provide automatic start, stop, adjustment, and optimization of eligible heat pump systems using two-way communication between control system and building equipment with sensors, controls logic, and algorithms.

Only controls that are paired with an eligible custom heat pump system can receive incentives under the Program. Eligible controls will be incentivized at the same rate as the corresponding heat pump it is controlling. As an example, if controls are installed to optimize operation of an eligible Category 4 heat pump, then the controls will receive a Category 4 incentive. Similarly, if controls are installed to optimize operation of an eligible Category 4A heat pump, then the controls will receive a Category 4A incentive.

### 3.2.11 Additional Project Eligibility Criteria

For scenarios in which project eligibility is not clearly defined, the following shall be used to determine eligibility:

- Fossil fuel (heating oil, natural gas, steam generated by fossil fuel, etc.) energy consumption must not be increased by the new electric technology or application.
- The heat pump technology must use staged, multi-speed or variable-speed heat pumps and must displace at least 50% of on-site fossil fuel consumption or result in at least 4,000 MMBTU of annual energy savings or alternative case fossil fuel consumption for Category 10 *Custom Partial Load Space Heating Applications*. Fuel savings cannot include fossil fuel system efficiency savings; in savings calculations, fossil fuel baseline efficiency (including distribution) must equal proposed (boiler) system efficiency.
- For categories with a decommissioning requirement, existing heating systems must be decommissioned.
- The new electric technology or application:
  - Must not increase the overall annual site energy consumption
  - Shall exceed applicable minimum efficiency specifications to meet applicable codes and standards

### **3.3 Warranty Requirements**

#### **All ASHPs, including ASVRF, and AWHP**

Each qualified residential and small commercial ASHP receiving an incentive under the Program must include a minimum five (5) year manufacturer's warranty for parts including the compressor.

#### **Full Load Residential Space Heating GSHP Systems**

##### *Category 3 GSHP: Full Load Heating*

For small GSHP systems, including desuperheaters and WWHPs, Participating Contractors must transfer to the system owner the manufacturer's/distributor's/dealer's warranty. At a minimum, such warranty must cover all parts and equipment against breakdown or malfunction and the warranty period must be no less than five (5) years. In addition, the warranty will cover the full costs, including labor and repair or replacement of components or systems.

The Participating Contractor must also provide additional warranty coverage that fully covers the labor and design services provided by the Participating Contractor (and any of its subcontractors). The warranty period must be no less than three (3) years. Participating Contractors must present to the site owner any optional extended warranty up to the maximum supported by the manufacturer.

#### **Custom GSHP Systems**

##### *Category 4 Custom Space Heating Applications*

For large GSHP systems, the minimum manufacturer's warranty must be at least one-year parts and labor, as required by law. Participating Contractors must present to the customer any optional extended warranty up to the maximum supported by the manufacturer.

#### **HPWH Systems**

##### *Category 5 HPWH*

Each air-to-water HPWH system receiving an incentive under the Program must include a minimum ten-year manufacturer's warranty for parts and tank.

##### *Category 6 Custom Hot Water Heating Applications*

Each HPWH system receiving an incentive under the Program must include a manufacturer's warranty for parts and tank.

### **3.4 Operation and Maintenance Requirements**

Electrified heating systems are often a new type of appliance for the site owner, so it is important that owners understand how to effectively operate and maintain their new systems. Participating Contractors must inform site owners about system operation and maintenance, including on the use of these systems in both heating and cooling modes. A detailed manufacturer's operation handbook as well as a maintenance manual containing information on the major components and a schedule of required system maintenance must be provided by the Participating Contractor.

The manual must include maintenance and testing requirements of antifreeze solutions used on the project. It must include any startup/commissioning documentation for the system(s). For large systems, the O&M manual must include as-built drawings.

For ccASHP and cold climate MSHP installations under incentive Categories 2a and 2b, the Program requires that Participating Contractors provide site owners with the “Get the Most Out of Your Air Source Heat Pump” tip sheet.<sup>53</sup>

The Program strongly recommends that GSHP systems include a performance monitoring system. Recommended best practices for performance monitoring of GSHP systems can be found at under the Ground Source Heat Pump (GSHP) drop-down menu.

Participating Contractors should strongly encourage system owners to purchase a maintenance agreement.

### **3.5 Engineering Savings Analysis Requirements for Custom Categories 4, 4A, 6 and 10**

Each application in the custom categories shall include a detailed engineering analysis showing energy savings in net MMBtu related to the project measures. Savings may be calculated through one of the following methods:

1. Statewide Custom Clean Heat Program Savings Calculator
2. Engineering Modeling
3. Temperature Bin Method

In the case of ERV/HRV installation measures, the latest version of the TRM Energy and Heat Recovery Measure may be used to calculate energy savings.

All calculations must be clear and transparent utilizing standard engineering methodologies, including a listing of source values. Energy savings analyses may be accepted in the following formats:

- Unlocked Microsoft Excel spreadsheet (PDFs not accepted) showing all equations, parameters, formulas, and assumptions used to calculate savings.
- Whole-building energy modeling using approved simulation software. The approved list of modeling software is based on current computational capabilities and familiarity of the respective utility and is therefore utility specific. Contact an account manager for a complete list of their pre-approved software.

#### **3.5.1 Statewide Custom Clean Heat Program Savings Calculator**

The Statewide Custom Clean Heat Program Savings Calculator (Clean Heat Calculator) is an Excel-based tool that has been developed to assist Participating Contractors applying to the NYS Clean Heat Program with calculating energy savings and incentives for various types of heat pump technologies. The

---

<sup>53</sup> [https://cleanheat.ny.gov/assets/pdf/CHC-ASHP-tips-fs-1-v1\\_acc.pdf](https://cleanheat.ny.gov/assets/pdf/CHC-ASHP-tips-fs-1-v1_acc.pdf).



Statewide Custom Clean Heat Program Savings Calculator user guide<sup>54</sup> contains an updated list of technologies for which the Clean Heat Calculator calculates savings and incentives.

The Clean Heat Calculator should be used as the default method to calculate energy savings for the custom categories (4, 4a, and 10).

Applicants may bypass using this calculator, opting instead to calculate savings using their own custom bin analysis or energy modeling approach.

The Program may request to use the statewide calculator to estimate savings if an applicant submits a model that is difficult to understand or ambiguous.

### 3.5.2 Energy Modeling

Whole-building energy models shall be prepared using an approved modeling software and shall be simulated following one of the compliance paths prescribed in NYS ECC 2020. The model shall be developed using a “Stacked” parametric approach, where energy savings are modeled by starting with the proposed design model, and gradually transforming this analysis into the minimally code compliant baseline design by subtracting the Energy Efficiency Measures (“EEMs”) one-by-one in the following order:

- HVAC measure(s)
- Base load measure(s) such as lighting, process loads, plug loads, etc.
- Envelope measure(s)
- Non-interactive measures such as service water heating

If there are several EEMs of the same type, for example several HVAC EEMs, the order in which they are modeled relative to each other is not prescribed to allow flexibility in supporting the specific project circumstances and may be determined by the entity performing the modeling based on communications with the customer. For example, if a design includes a high efficiency make-up air unit, and energy recovery is considered as a design alternative, the energy recovery EEM should be modeled (subtracted from the proposed design) first, to show the added energy savings for this option, with the unit efficiency EEM modeled (subtracted) second.

With the stacked approach, the difference between the sum of EEM savings and the total savings of the proposed design relative to the baseline is attributed entirely to the impact of components that differ between the baseline and proposed models but are not included in any EEM.

If a project involves new construction or gut rehab, review additional new construction and gut rehab criteria in [Section 3.7](#) below.

### 3.5.3 Establishing Baselines

Establishing the baseline’s equipment type or efficiency is necessary for calculating energy savings for any project, especially for a custom project. This section defines the types of baselines used by the Program and the general requirements for each baseline type. Baselines will depend on the facility’s type and vintage and scope of work.

---

<sup>54</sup> <https://cleanheat.ny.gov/assets/pdf/Calculator-User-Guide.pdf>

### 3.5.3.1 Baseline Equipment Types

Equipment baselines are defined as the type of equipment that would have been installed without the Program's influence. In other words, the savings baseline should represent customer choice in the absence of the Program, not optimal behavior, or policy goals.

#### 3.5.3.1.1 Existing Facilities

The default baseline equipment type for the existing facilities is the existing equipment type and efficiency compliant with the minimum code efficiency per ECCNYS (Energy Conservation Construction Code of New York State). However, the customer may instead choose to select a baseline in accordance with contemporary construction practice for the area and based on an evaluation of the technology's cost effectiveness. Suppose a baseline that differs from the existing system is selected. In that case, the applicant shall provide a separate analysis supporting its selection, showing that the baseline chosen aligns with contemporary construction standards and is cost-effective from both an installation and life cycle standpoint.

#### 3.5.3.1.2 New Construction and Gut Rehab

For all eligible new construction or gut rehab projects in the program, the default heating fuel type has been set to natural gas. Applicants shall select an alternative fuel if natural gas service is not available or if access is not economical in the project's area.

### 3.5.3.2 Baseline Efficiencies (except Category 4a) <sup>55</sup>

Baseline system efficiencies for all categories except Category 4a shall be based on minimally code-compliant equipment in accordance with the latest Energy Conservation Construction Code of New York State ("ECCCNYS") prescriptive code values. There are three exceptions to this requirement:

1. Project qualifies as a Special Circumstance Replacement in accordance with the TRM<sup>56</sup> requirements – i.e. Early Replacement or Extended Life. For Special Circumstance Replacements ([Section 3.8](#)), the existing equipment efficiency shall be used for the baseline condition in accordance with the TRM two step analysis method.
2. Projects involving new construction or gut rehab whose design demonstrates compliance with Section 406 of the latest ECCCNYS or the New York City Energy Conservation Code ("NYCECC") by providing more efficient HVAC performance shall set the baseline system efficiencies to exceed the minimum code efficiency requirements by 10%.
3. LMI projects should use the existing equipment type and efficiency as the baseline condition

---

<sup>55</sup> Refer to the statewide LMI Implementation Plan for more information on baseline efficiencies for Low- to Moderate Income projects:

<http://documents.dps.ny.gov/public/MatterManagement/CaseMaster.aspx?Mattercaseno=18-M-0084>

<sup>56</sup> The New York State TRM can be found on the Department of Public Service website here:

<https://www3.dps.ny.gov/W/PSCWeb.nsf/All/72C23DECF52920A85257F1100671BDD?OpenDocument>

### **3.5.3.3 Baseline Efficiencies – Category 4a**

Baseline system efficiencies for:

#### *3.5.3.3.1 Existing Facilities and Gut Rehab – Category 4a*

The energy savings from the package of envelope upgrades and heat pump installations are based on the existing conditions. The thermal performance of the building envelope, as well as the HVAC system type and efficiency, should reflect the current conditions found at the project. The participating contractor should provide separate analyses for the envelope upgrades and heat pumps. The documentation should clearly describe the existing building envelope and age and performance data for the existing HVAC system, such as cut sheets stipulating existing efficiency and boiler combustion tests.

The heat pump analysis should calculate incremental energy savings related to the heat pump equipment based on the upgraded building envelope conditions.

#### *3.5.3.3.2 New Construction – Category 4a*

The baseline for all eligible new construction projects in the program is code-compliant equipment per the latest ECCCNYC.

The default building envelope baseline shall be set to the ECCCNYC code minimum compliant performance.

The default heating fuel type has been set to natural gas at the minimum ECCCNYC code efficiency. Applicants shall select an alternative fuel when the new natural gas service is unavailable, or access is not economical in the project's area.

## **3.6 Additional Requirements for New Construction and Gut Rehab**

### **3.6.1 New Construction and Gut Rehab Eligibility**

New construction and gut rehab projects installing heat pump technologies complying with Program requirements are eligible for incentives. Incentives will apply to the portions of the scope of work related to heat pump installations. Additional requirements for new construction projects are outlined in this section.

When buildings undergo renovations that include an expansion of square footage, such as the addition of new floors, the newly added square footage will be considered new construction. Thus, the new square footage will only be eligible for GSHP and domestic hot water incentives. The square footage that existed before the renovation will be considered an existing building and are eligible for the relevant space and water incentives.

### **3.6.2 Energy Code Compliance**

New construction and gut rehab projects must demonstrate minimum compliance with the applicable local Energy Code 2020, e.g., Energy Conservation Construction Code of New York State (ECCCNYC) or New York City Energy Conservation Code (NYCECC) in one of the following ways:

- **Prescriptive:** Each discrete component complies with specific requirements

- **Component Performance Alternative:** Prescriptive approach that allows trade-offs between some components (some can be below code if others are above)
- **Total Building Performance:** Using an energy model, show the entire building's compliance with code. With this method, performance trade-offs are allowed, meaning that some components in the proposed design may be less efficient than the minimally code-compliant like component in the baseline. In these instances, a trade-off must be made to “make up” for a component that does not comply with code. For example, a building owner might choose to install a more energy efficient heat pump system to “make up” for putting in more window area than allowed by the code.

If trade-offs are taken, applicants must provide a side-by-side comparison table between proposed and baseline identifying the areas where trade-offs are made (i.e., building or system elements that do not comply with the prescriptive requirements of the code, elements exceeding requirements, and building elements or systems modeled to provide additional energy savings to offset the non-complying elements). The savings will be calculated based on the proposed heat pump design net of any trade-offs.

Projects that follow the total building performance path and whose design includes trade-offs must set their savings baselines per minimally code compliant ECCCNY prescriptive code values. While energy models created per Appendix G or Section 11 of ASHRAE 90.1 may be used for program eligibility, the Appendix G or Section 11 baselines shall not be used to calculate savings.

Con Edison reserves the right to modify energy savings baselines for buildings that make trade-offs on a case-by-case basis.

### 3.6.3 New Construction and Gut Rehab Energy Savings Analysis

New construction and gut rehab projects that follow a prescriptive approach, preparing a COMcheck or Tabular analysis, to demonstrate compliance with energy code may opt to submit an energy analysis using Excel calculations, *i.e.*, the statewide calculator, or a whole building energy model. The modeling methodology is discussed in [Section 3.6.2](#).

When a project uses a “Total Building Performance” compliance path or trade-offs, the applicant shall submit a whole building energy model for review. Excel calculations will not be accepted for these projects.

## 3.7 Early Replacement Projects

Projects may qualify for early replacement if they meet the criteria summarized below as defined in the Technical Resource Manual (“TRM”).<sup>57</sup> For full details, refer to Appendix M in the latest version of the TRM for guidelines for early replacement conditions.

For existing cooling and/or heating equipment to be eligible for early replacement under the Program:

---

<sup>57</sup> New York Standard Approach for Estimated Energy Savings from Energy Efficiency Programs – Residential, Multi-Family, and Commercial/Industrial Measures, (“TRM”) Version 10, effective January 1, 2023. See Appendices M & N.

1. Proposed work must involve a retrofit or substantial improvement to an existing facility and must include the entire portion of the building within project scope.
2. The savings baseline for calculating energy savings must be based on the existing heating and/or cooling equipment type installed at the facility.
3. At the time of application to the Program, the existing equipment cannot exceed its Effective Useful Life (“EUL”) and should have at least one year of its EUL remaining (Refer to Appendix P in the latest version of the TRM for EUL for various heating/cooling equipment).
4. The existing equipment must be fully functioning.

A facility’s existing cooling and heating systems shall be evaluated separately against the criteria noted above to determine whether each individually qualifies for early replacement. One or both systems may be eligible.

### 3.7.1 Required Project Documentation

In addition to the requirements listed in this Program Manual and any applicable supplementary guidelines issued for the proposed energy conservation measures, early replacement projects must submit the following documentation:

- Cooling/heating capacity of the existing equipment
  - Supported by manufacturer’s equipment data sheets or industry standard performance testing results for existing equipment
  - Supported by manufacturer’s equipment data sheets or AHRI certificate
- Age of the existing equipment
  - Supported by original invoice, bill of sale, construction permit, service log, or nameplate date

## 3.8 Special Circumstance

There are two criteria for existing cooling and/or heating equipment to be eligible for special circumstance replacement under the Program. Full details on special circumstance replacements are found in Appendix M of the latest version of the TRM.

1. Age Rule
2. Energy Use Rule

Special circumstance replacement does not change the incentive category for a project. Qualifying for special circumstance replacement may affect the project baseline, which affects the energy savings calculated for the project. Thus, special circumstance replacements may benefit projects whose incentive rates are calculated on a \$/MMBtu saved basis in custom categories.

Only projects in existing buildings can be eligible for special circumstance replacement. New Construction projects do not qualify for special circumstance replacement.

### 3.8.1 Age Rule

1. The savings baseline for calculating energy savings must be based on the existing heating and/or cooling equipment type installed at the facility.

2. At the time of application, existing cooling and/or heating equipment must exceed its EUL by at least 25% (Refer to Appendix P in the latest version of the TRM for EUL for various heating/cooling equipment).
3. If the equipment is determined to be less than 125% of its EUL, it is not eligible for special circumstance extended life treatment regardless of consumption or any other factor.
4. There must be a history of significant repair or replacement with existing equipment.
5. Existing equipment must be fully functioning.

### 3.8.2 Energy Use Rule

1. For cases in which the age of the existing equipment cannot be determined relative to 125%, the Energy Use Rule may be considered for eligibility; existing equipment energy consumption must exceed that of the new high efficiency model by at least 35% for chillers, and 20% for all other HVAC types to do the same amount of work.

A facility's existing cooling and heating systems shall be evaluated separately against the criteria noted above to determine whether each individually qualifies for extended life replacement. It is noted that one or both systems may be eligible.

### 3.8.3 Required Project Documentation

The minimum documentation required for all special circumstance projects is listed below. These requirements are in addition to the requirements listed in this Program Manual and any applicable supplementary guidelines issued for the proposed energy conservation measures.

1. Cooling/heating capacity and performance of the existing equipment:
  - Supported by manufacturer's equipment data sheets or industry standard performance testing results for existing equipment
  - Supported by manufacturer's equipment data sheets or AHRI certificate
2. Age of the existing equipment
  - Supported by original invoice, bill of sale, construction permit, service log, or nameplate date
3. Actual repair cost, including component replacement for at least the past 3 years
  - Supported by invoices or proof of payment
  - Total repair cost must be added and summarized in a document

Incentives for projects applying for prescriptive incentives in Categories 2a, 2b, 2c, 2d or 3 are not affected by early replacement/extended life (ER/EL).

## 4. Participating in the Program

### 4.1 Become a Participating Contractor

To participate in the NYS Clean Heat Program in Con Edison's service territory, ASHP installers, ASHP designers, AWHP installers, GSHP installers, GSHP designers, and GSHP drillers<sup>58</sup> must first become Participating Contractors in the NYS Clean Heat Participating Contractor Network. Contractors who only install HPWH do not need to become Participating Contractors to submit an incentive application on behalf of a customer through the midstream HPWH program. When a contractor is accepted as a Participating Contractor, they will receive approval notification emails and be eligible to apply for incentives in the program.

To become a Participating Contractor, contractors must submit the following completed documents via the NYS Clean Heat Participating Contractor Portal:

- Con Edison Participating Contractor Agreement
- NYS Participating Contractor Application
- IRS Form W-9
- Certificate of Insurance Policy (minimum \$1 million)
- Sector-specific documentation

For additional information on the NYS Clean Heat Program Contractor enrollment, visit Become a Participating Contractor: NYS Clean Heat<sup>59</sup> webpage.

Contractors working in the following segments are required to submit the additional technology or sectoral specific documentation.

---

<sup>58</sup> GSHP Drillers must also be approved by the Electric Utilities through this process to become Participating Drillers, but only participating installers and designers may submit incentive applications.

<sup>59</sup> <https://cleanheat.ny.gov/become-participating-contractor/>

Sector	Required Documentation
ASHP installer	<ul style="list-style-type: none"> <li>- U.S. Environmental Protection Agency Section 608 Technician Certification<sup>60</sup></li> <li>- ASHP Manufacturer-sponsored Installation Training Certificate (or comparable)</li> <li>- ASHP Manufacturer-sponsored Cold Climate Air Source Heat Pump Sizing and Design Training<sup>61</sup></li> </ul>
ASHP Designer	<ul style="list-style-type: none"> <li>- An active NYS Professional Engineering license OR active NYS Registered Architect license</li> </ul>
AWHP Installers	<ul style="list-style-type: none"> <li>- A copy of the U.S. Environmental Protection Agency Section 608 Technician Certification that is appropriate for the size of the systems the installer will install.<sup>62</sup></li> <li>- AWHP Manufacturer-sponsored Installation Training Certificate or comparable (e.g. Heatspring’s Application of Air-to-Water Heat Pumps for Hydronic Heating and Cooling course <sup>63</sup>or Heatspring’s Heat Pump System Design &amp; Installation course. <sup>64</sup>)</li> <li>- Attestation that the installer holds, or will hold, all necessary plumbing licenses for their installation locations</li> </ul>
GSHP Contractor	<ul style="list-style-type: none"> <li>- A copy of a current (and in good standing) International Ground-Source Heat Pump Association (“IGSHPA”) accredited installer certificate</li> </ul>
GSHP Designer (Category 3)	<ul style="list-style-type: none"> <li>- A current (and in good standing) IGSHPA accredited installer certificate OR an active Certified GeoExchange Designer (“CGD”) certificate from the Association of Energy Engineers (“AEE”)/IGSHPA</li> </ul>
GSHP Designer (Category 4)	<ul style="list-style-type: none"> <li>- A current CGD certificate from AEE/IGSHPA OR an active NYS Professional Engineering license OR active NYS Registered Architect license</li> </ul>
GSHP Driller (Vertical Loop Field)	<ul style="list-style-type: none"> <li>- Active registration (in good standing) and certification for open-loop geothermal well drilling by the NYS Department of Environmental Conservation OR</li> <li>- National Ground Water Association Certified Vertical Closed-Loop Driller (CVCLD) certificate</li> </ul>
GSHP Driller (Direct Exchange “DX”)	<ul style="list-style-type: none"> <li>- Training certificate from a DX Ground Source Heat Pump manufacturer</li> </ul>
Weatherization Contractors	<ul style="list-style-type: none"> <li>- Home Improvement License (where applicable)</li> </ul>
Residential Contractor	<ul style="list-style-type: none"> <li>- Contractor Verification Attestation Form</li> </ul>

Effective March 1, 2023, all ASHP Participating Contractors are required to take their preferred manufacturer’s version of the ASHP Sizing and Design training and submit documentation of completion.

<sup>60</sup> <https://www.epa.gov/section608/section-608-technician-certification-0>

<sup>61</sup> <https://cleanheatconnect.ny.gov/calendar/>

<sup>62</sup> <https://www.epa.gov/section608/section-608-technician-certification-0>

<sup>63</sup> <https://www.heatspring.com/courses/application-of-air-to-water-heat-pumps-for-hydronic-heating-cooling>

<sup>64</sup> <https://www.heatspring.com/courses/heat-pump-system-design-installation#instructors>



A grace period of three months following the effective date allows additional time for compliance with the existing Participating Contractor training requirement. Available trainings are posted on the Clean Heat Connect trainings calendar<sup>65</sup> and updated regularly.

In addition to the steps noted above, each Participating Contractor must have two attendees from their company attend one of Con Edison's in-person Clean Heat Program training sessions. In lieu of in-person attendance, Contractors may complete a 10-question assessment with a passing grade of 70%. Multifamily and SMB contractors are required to attend a sector-specific training. All Participating Contractors should be prepared to submit a full application to become a Participating Contractor on Relaunch.

A Contractor's access to monthly incentive allocations, as described in [Section 4.2](#) of this Program Manual and access to Con Edison's Online Intake Tool, will be restricted until contractors complete the assessment and upload updated documentation.

#### 4.1.1 Residential Contractor Verification "Attestation" Form

The Con Edison Residential Contractor Participation Agreement specifies that all projects must be installed in accordance with manufacturer specifications and installation requirements and compliance with all applicable laws, regulations, codes, licensing, and permit requirements, including, but not limited to, the New York State Environmental Quality Review Act, the Statewide Uniform Fire Prevention and Building Code and State Energy Conservation Construction Code, the National Electric Code, Fire Codes, and all applicable State, city, town, or local ordinances and/or permit requirements.

All Participating Contractors must verify that the projects installed in Con Edison's service territory are in accordance with the aforementioned requirements by signing a Contractor Verification Attestation form. Contractors who contest or fail to sign a verification form will be required to provide a copy of permits for each job submitted through the Program.

## 4.2 Residential Program Requirements and Application Process

This Section of this Program Manual covers the residential sector of the Clean Heat Program. The residential program supports both cold climate air-source heat pump (ASHP) and ground-source heat pump (GSHP) measures installed in Con Edison's residential service area.

#### 4.2.1 Residential Contractor Allocations

The Program will allocate a share of the monthly funding available to the Residential ASHP contractors that request an allocation. This process will be refreshed quarterly and is designed to give Participating Contractors more transparency and certainty around incentive availability while helping the Company run the program effectively. By refreshing the allocations on a quarterly basis, Con Edison will seek to allocate a fair percentage of the monthly sectoral allocation among high- and low-volume contractors, reserve funding to allow new contractors to enter the program without delays, and allow room to grow for contractors with a dedicated track record of success.

---


<sup>65</sup> <https://cleanheatconnect.ny.gov/calendar/sizinganddesign>

To create fair allocations, the Program will ask contractors in the ASHP segment to submit forecasts of their monthly activity. ASHP contractors should submit their forecasts for the quantity and value of applications submitted per month based on completed installations. The Program will use each Contractor’s forecast as an input along with other factors including historical performance and program budget availability to create a monthly allocation for each contractor.

Con Edison will not approve applications that exceed a Contractor’s monthly allocation unless the Company has granted prior approval. Contractors who wish to submit applications above their allocation in a given month should reach out to their account manager. At its discretion, Con Edison may increase the allocation for a Participating Contractor in a given month.

Con Edison will attempt to communicate contractor allocations in the first week of the final month of the quarter for the following quarter. For example, monthly allocations for Q4 (October, November and December) will be communicated in early September. To deliver on this timeline, the program team will ask contractors to submit an allocation request to high-volume contractors in the middle of the second month of the quarter. Contractors’ allocation requests will help the Con Edison Program team assign monthly allocations for the subsequent quarter. Additionally, the account management team may follow up with questions regarding allocation requests. The account management team will also follow up regularly during the quarter will follow up weekly to see how Contractors are trending against their monthly allocation.

Figure 2: Quarterly Timeline for Allocation Request Forecasts:



Monthly allocations awarded to Residential Participating Contractors will be fixed each month and unused allocations will not roll over into that contractor’s allocation in subsequent months. In the first quarter of 2023, Con Edison will launch a dashboard on its OIT where contractors will be able to view their allocations and progress against their allocation.

ASHP projects will draw down their sectoral allocation and their contractor allocation on the date Con Edison receives a complete post-installation application. GSHP projects draw down their sectoral allocation on the day Con Edison receives the pre-installation application with a signed customer contract.

#### 4.2.2 Incentive Eligibility

To be eligible for residential Clean Heat incentives, a customer must:

- Be a Con Edison electric customer with an active Con Edison account number<sup>66</sup>
- Be located in a building consisting of 1-4 dwelling units OR be pursuing a project electrifying 1-4 dwelling units in a building with greater than five dwelling units
- Be located in a dwelling unit that has not previously received incentives for full-load electrification from the NYS Clean Heat Program

Customers whose dwelling units previously received partial load Clean Heat incentives, are eligible to apply for full-load Clean Heat incentives.

New construction projects are only eligible for GSHP incentives. Gut renovations and existing buildings are eligible for ASHP, AWHP, and GSHP incentives.

#### 4.2.3 Incentives

The NYS Clean Heat Program in Con Edison's service territory offers residential incentives for space heating for five types of projects:

- Category 2a: ASHP Full-load heating with integrated controls
- Category 2b: ASHP Full-load heating with decommissioning
- Category 2e: AWHP Full-load heating with decommissioning
- Category 3: GSHP full-load heating with decommissioning<sup>67</sup>
- Categories 2a, 2b and 3: Existing ASHP partial load projects converting to full-load heating with decommissioning or integrated controls.

Integrated controls units must be attached to existing heating units and operated such that the heat pump serves as the primary source of heat from the combined heat pump and legacy system. To be eligible for Category 2a incentives, the integrated control system must be listed on the NYS Clean Heat Integrated Controls Qualified Product list located under the ASHP tab on the NYS Clean Heat Resources webpage.<sup>68</sup>

For decommissioning projects, legacy heating systems must be removed, disabled, or disconnected consistent with the appropriate decommissioning checklist must remove or disable the legacy space heating system.<sup>69</sup>

Clean Heat incentives must be identified on an invoice to the customer, with incentive amounts to be paid directly to the Participating Contractor upon program approval.

---

<sup>66</sup> GSHP projects in new construction may not need to provide a customer account number at the time of initial application.

<sup>67</sup> For existing buildings, all existing fossil heating systems must be decommissioned. For new construction, the GSHP system must be the only system for heating for the building.

<sup>68</sup> <https://cleanheat.ny.gov/contractor-resources>

<sup>69</sup> Residential decommissioning projects may include electric resistance heating not to exceed 10% of BHL.

**4.2.3.1 ASHP Incentives**

There are two rates offered for ASHP categories as summarized in Table 24 – installations in single family homes, and another for installations in individual apartments with multiple apartments in a building. ASHP rates are available for ccASHP mini-splits, central systems, PTHPs, SVPHPs, and AWHPs. Each dwelling unit must be separately metered and comply with all applicable laws and regulations regarding dwelling units.

*Table 24: Residential ASHP Incentives*

c Number	Description	Non-DAC		DAC	
		Single Family Home	Apartment	Single Family Home	Apartment
2a	ccASHP: Full load heating with integrated controls	\$2,500	\$1,000	\$4,500	\$2,000
2b	ccASHP: Full load heating with decommissioning	\$8,000	\$4,000	\$10,000	\$5,000
2e	AWHP: Full load heating with decommissioning				

Projects in DAC are eligible to receive incentives that cover up to 70% of project costs, while incentives for projects outside of DACs remain capped at 50% of project costs. The DAC incentive rates apply to both decommissioning and integrated controls projects. Contractors can determine whether a project is in a DAC by searching the address at:

<https://www.nyserda.ny.gov/ny/Disadvantaged-Communities>.

The NYS Clean Heat Program for Con Edison offers incentives for customers who had previously received Category 1 (partial load incentives) to transition to full load heating. Incentives for this offering are shown in Table 25.

*Table 25: ASHP incentive rates for premises that previously received a partial load incentive*

Category Number	Description	Single Family Home	Apartment
2a	ccASHP: Full load heating with integrated controls	\$1,250	\$500
2b	ccASHP: Full load heating with decommissioning	\$4,000	\$1,500
2e	AWHP: Full load heating with decommissioning		

**4.2.3.2 GSHP Incentives**

The Clean Heat Program will offer two different incentive rates for residential GSHP projects: one for customers in Disadvantaged Communities (DAC) and one for customers outside of DAC. The incentive rate for residential GSHP projects located outside of a DAC is \$25,000 per building or 50% of project costs, whichever is lower. The incentive rate for GSHP projects located within a DAC is \$35,000 per building or 70% of project costs, whichever is lower. These rates are shown in Table 26.

Contractors can determine whether a project is in a DAC by searching the address at: [www.nyserda.ny.gov/ny/Disadvantaged-Communities](http://www.nyserda.ny.gov/ny/Disadvantaged-Communities).

All GSHP projects for existing buildings must include decommissioning of the existing space heating system. GSHP projects may include ASHP or AWHP as an ancillary heating system over a minority area of the project, however all GSHP systems must provide heating for 80% of square footage of the house. The inclusion of the ASHP or AWHP does not change the prescribed GSHP incentive rate for the project. Projects that include ASHP or AWHP must make note of the difference by square footage and heating load in the Manual J floor by floor plan.

*Table 26: Residential GSHP Incentives*

	<b>Category 3: GSHP Full Load Heating Incentive</b>	<b>Incentive Cap</b>
Located outside of DAC	\$25,000	50%
Located in DAC	\$35,000	70%

As of September 2023, the NYS Clean Heat Program for Con Edison will offer incentives for customers in Dwelling Units which had previously received Category 1 (partial load incentives) to transition to full load heating. Eligible GSHP projects will receive the full Category 3 incentive rate based on the location of the project.

Ground loops must comply with applicable state and local laws and International Ground-Source Heat Pump Association (“IGSHPA”) standards.

For projects installed at new construction sites, all components installed as part of an approved GSHP system must be new. For projects installed at existing sites, the heat pumps must be new and any system subcomponent or subassembly such as controls or ductwork that is replaced should be replaced by a new subcomponent or subassembly. The installation of used or refurbished equipment and components is not permitted under the program.

**4.2.3.3 Limited-Time 2024 Promotion Incentives**

Con Edison has introduced new incentive rates for decommissioning projects as part of a Limited-Time 2024 Promotion in the Residential sector. ASHP projects installed on or after December 5, 2023, with applications submitted on or before May 31, 2024 are eligible for the 2024 Promotion Rates. ASHP project applications submitted after May 31, 2024 will be eligible for base incentive rates. ASHP incentive rates for the 2024 Promotion can be found in Table 27 below.

Table 27: Residential ASHP Limited-Time 2024 Promotion Incentives

Category Number	Description	Non-DAC		DAC	
		Single Family Home	Apartment	Single Family Home	Apartment
2b	ccASHP: Full load heating with decommissioning	\$10,000	\$6,000	\$12,000	\$7,000
2e	AWHP: Full load heating with decommissioning				

Residential GSHP projects will be eligible for the 2024 Promotion Rates if they are installed on or after December 5, 2023, and submit signed customer commitments between now and May 31, 2024. Signed commitments and incentive applications submitted after May 31, 2024, will be eligible for base incentive rates. GSHP incentive rates for the 2024 Promotion can be found in Table 28 below.

Table 28 Residential GSHP Limited-Time 2024 Promotion Incentives

Category Number	Description	Non-DAC	DAC
		Whole Building	Whole Building
3	GSHP: Full Load Heating	\$35,000	\$45,000

Projects in DAC are eligible to receive incentives that cover up to 70% of project costs, while incentives for projects outside of DACs remain capped at 50% of project costs.

#### 4.2.3.4 Incentive examples by building types

Building and project type determines the value of incentive for which each residential project is eligible. Eligible sites for residential Clean Heat projects include residential buildings owned or controlled by an active Con Edison customer where an eligible heat pump system for space heating is being installed as a retrofit. For GSHPs, the building types can also include newly constructed buildings.

Both attached and detached single family homes are eligible for the single-family incentive rates, and are illustrated in Table 29. Participating Contractors who submit applications for incentives for single family homes must indicate the building type.

Table 29: Residential Single-Family Building Type Examples

Building Type	Illustrative picture	Description
Single family detached		A building with one Dwelling Unit that does not share any walls with other conditioned residential buildings.
Single family attached		A building with one Dwelling Unit that shares at least one wall with another residential building

If a project electrifies individual dwelling units in a building with four or fewer dwelling units, the project will be eligible for incentives equal to the number of dwelling units multiplied by the relevant per apartment rate.

Projects which electrify between one and four dwelling units in a multifamily building with five or more dwelling units, are eligible for the residential per apartment rate.

#### 4.2.4 Residential Application Process

There are four basic stages for a residential application listed here and described below:

1. Contractor Enrollment and Allocation
2. Initial Project Documentation
3. Project Installation and Technical Review
4. Final Review and Payment

Residential incentive applications qualifying for incentives must be submitted within 30 days after the installation is complete.

##### **Stage 1 - Enrollment and Allocations**

This stage describes the activities before a Participating Contractor is ready to submit an incentive for a specific project. Before applying for residential Clean Heat incentives, all contractors must first become a Participating Contractor and provide Con Edison with their monthly allocation requests. Newly added contractors will need to submit an allocation request within the quarter they sign up to participate. Contractors must have an allocation before submitting an incentive application. Please refer to Section 4.1 for more on how to become a Con Edison Residential Participating Contractor, and Section 4.2.1 for the monthly Contractor allocation process.

##### **Stage 2 – Initial Documentation**

This stage includes the activities that are undertaken while a Participating Contractor contracts with a customer and before the project is installed. For GSHP projects, Participating Contractors must submit a pre-installation application and upload a copy of a signed customer contract within 14 days of contract signing subject to available budget within the Contractor's allocation. When a Participating Contractor submits the initial documentation for the GSHP project, this draws down the monthly allocation.

This step is optional for ASHP projects and would not impact a contractor's monthly ASHP allocation.

Con Edison offers a tool for Participating Contractors to verify customer eligibility for Clean Heat incentives. To conduct a look-up, Participating Contractors will need to enter a customer's 14-digit account number, meter number, or premise address. If the premise is eligible for Clean Heat incentives, the system will provide Contractors with an eligibility key. Premises that have already received full-load Clean Heat incentives are not eligible for additional incentives.



Additionally, the Program offers a pre-application option for ASHP contractors. One calendar day after a pre-installation application is received, a system automated pre-approval notification is sent to the Participating Contractor via email that confirms eligibility, and incentive details, including the estimated incentive amount. Documentation required for the pre-installation application is captured in the box at right.

*Box 1: Data Fields for Pre-Installation Application*

When the pre-application process becomes available for ASHP projects in existing buildings the pre-approval confirmation will expire in 30 days for existing buildings.

For GSHP projects, the incentive offer provided in the project pre-approval confirmation email will expire in 180 days for projects in existing buildings and the sooner of September 1, 2025 or 24 months from the date of the confirmation email for new construction. The Participating Contractor may request an extension of time to complete projects by submitting an email to Con Edison explaining the reason for the delay. Extensions may be granted at Con Edison’s discretion.

- Project Name
- Eligibility Key
- Premise Address
- Building Type
- Multifamily Building (Y/N)
- No. of Dwelling Units
- Building Load
  - ASHP full load with integrated controls or decommissioning
  - GSHP with decommissioning)
- Estimated total Project Cost
- Planned Installation Date
- Signed customer agreement (for GSHP projects)

### **Stage 3 – Installation and Technical Review**

This stage includes the activities that occur after the Participating Contractor completes installation of the project and submits the final application for incentives and required supporting documentation. Incentive applications are due no later than 30 days after the heat pump system is installed and operational.

The application processing system will calculate if the new application package will cause the Participating Contractors to exceed their monthly allocation and prevent submission. In this circumstance the Contractor will be invited to save their package and submit in the following month. Contractors approaching their monthly allocation, who still wish to submit projects, should reach out to the Residential Program team for permission to exceed their allocation.

Data fields previously provided in Stage 2 marked with an asterisk (\*) in **Box 2Error! Reference source not found.**, will be pre-populated and are not editable during this step. If any of the pre-populated information has changed, Contractors will be required to “cancel” the current pre-application submission. Once cancelled, Contractors will then be able to “clone” the previous submission and choose to “edit” and amend the relevant data fields and submit. Contractors will then be able to return to this application the following calendar day to submit their application package.

### **Documentation Requirements – ASHP and GSHP projects**

All projects are required to submit the following documents as part of the application:

- **Completed program application** – Relevant fields and documents are listed below.

- **Cutsheets for System Capacity** – Specific model(s) and product ratings being used in the project must be reflected on the cutsheets.
- **Customer Invoice** –A final invoice must be provided to Con Edison clearly showing the costs of the project, separated by labor and materials with a total, and the value of the Clean Heat incentive clearly labeled as a discount from Con Edison. The invoice must also indicate the manufacturer, model number and number of each unit installed.
- **Customer Participation Acknowledgement** – Confirmation that customer agrees to terms and conditions and recognizes the incentive amount provided. Customer signatures may be provided electronically.
- **Floor by Floor Manual J** – Latest heating and cooling load calculations showing that the heat pump system design and appliance selection has been performed in accordance with ACCA Manual J, ANSI/ASHRAE/ACCA Standard 183-2007 (RA2017) or other code-approved equivalent computational procedure depending on building type. Manual J calculations should be submitted in PDF format, unless otherwise requested.
- **Photo Submission** – Contractors must submit the following pictures all of which must have time and date stamps.
 

Taken before beginning work:

  - Wide shot of the boiler
  - Wide shot of the exhaust vents
  - Shot of the burner assembly
  - Shot of the thermostat controlling the appliance

Following completion of the work:

  - Decommissioned system including capped fuel lines
  - Permanently sealed exhaust vent openings
  - Permanently sealed circulation pipes (for boilers) or ducts (furnaces)
  - The space where the control module had been
  - The space where the burner assembly had been
- **Decommissioning Checklist (if applicable)**

*Box 2: Final Application Data Fields*

- **Project Name\***
- **Eligibility Key\***
- Customer Name
- **Premise Address\***
- **Account Number\***
- **Building Type\***
- Installation Date
- Year built
- Building Cooling Load (BCL) at design temp
- Total System Cooling Capacity at design temp
- Building Heating Load (BHL) at design temp
- Total System Heating Capacity at design temp
- Total Project Costs (Labor + Equipment – excluding tax)<sup>1</sup>
- System Cost for Equipment (as a percentage)
- Status of Existing Equipment (decommissioned or removed)
- Was Clean Heat financing used on this project?
- Total building square footage
- Manual J conditioned square footage
- Replaced Heating fuel of system
- Replaced Electric Heating System (if applicable)
- Replaced Fossil Fuel Heating System (if applicable)

The Program will review the application package for all projects to confirm the incentive and savings based on as-built conditions and as-installed costs. All documentation must be complete and accurate

before a project will be approved for payment. When an application is incomplete or inaccurate, Con Edison will contact the Participating Contractor to request the missing and/or correct information. Participating Contractors have 30 days from the date Con Edison or ICF notifies them to complete their application, unless otherwise indicated. If the missing and/or incorrect application is not resolved within the specified timeline, including resolution of inspection flags, the application will be cancelled and will not receive an incentive.

Projects outside the recommended BHL/SF guidelines in Table 30 will be subject to additional technical review, including higher inspection rates.

*Table 30: Recommended BHL/SF Ranges by Building Age*

<b>Year Built</b>	<b>Minimum BHL/SF</b>	<b>Maximum BHL/SF</b>
Pre-1945; uninsulated Brick	30	45
Pre-1945 Insulated	25	45
Pre-1979	20	35
1979-2006	15	30
2007 or later	15	25

**Stage 4 – Final Review and Payment**

Con Edison has set a target of 10% of projects by contractor for a Post-Installation Programmatic Inspection to confirm that the work was conducted in accordance with the incentive application. Con Edison will withhold incentive payments for projects selected for Programmatic Inspection until after the inspection is complete and any issues found on site which call for remediation are addressed. Projects not selected for a Programmatic Inspection will be reviewed and processed for payment. All projects may be subject to a QAQC Inspection discussed below. Contractors should inform customers of the possibility of up to two inspections at the time of installation.

Rejection or modification of an incentive application is at Con Edison’s sole discretion.

For ASHP projects, contractors are required to deduct the Clean Heat incentive, clearly labeled as a discount from Con Edison, from the final invoice to the customer. The Program will pay residential ASHP or GSHP incentives to Participating Contractors upon incentive approval. Each Participating Contractor will be reimbursed for an amount not to exceed the instant discount amount provided to Customer at the time of install, and as documented in the site owner invoice or contract. High volume contractors may apply to receive incentive payments via ACH, so that eligible Participating Contractors can receive incentive payments directly into their bank accounts without the need for paper checks. The minimum threshold to be eligible for ACH are deposits totaling \$100,000 annually.

Through participation in the Residential program, Participating Contractors will be required to comply with a Quality Assurance/Quality Control (QA/QC) process for the purpose of ensuring quality installations and improving program processes.

## 4.2.5 Residential Savings Calculations

### **4.2.5.1 Savings Methodology for Residential projects**

For residential projects, Con Edison will calculate savings using a deemed savings approach based on the conditioned square footage and age of the building. Con Edison will work with other stakeholders across the state to add the deemed savings methodology for relevant technologies to *The New York Standard Approach for Estimating Energy Savings from Energy Efficiency Programs - Residential, Multi-Family, and Commercial/Industrial*, known as the Technical Resource Manual (“TRM”).

### **4.2.5.2 Savings Methodology for GSHP**

Con Edison uses the methodology outlined in the TRM and best practices to estimate energy savings for GSHP heat pump installations.<sup>70</sup>

### **4.2.5.3 Savings Methodology for GSHP VRF**

GSHP VRF systems in residential buildings are eligible for GSHP incentives but the savings for the measure are not defined in the TRM. Therefore, projects with GSHP VRF systems must use an alternative calculation method, such as the statewide Custom Clean Heat Program Savings Calculator.

The Statewide Custom Clean Heat Program Savings Calculator is an Excel-based tool that has been developed to assist Participating Contractors applying to the NYS Clean Heat Program with calculating energy savings and incentives for several different types of heat pump technologies. Refer to the Statewide Custom Clean Heat Program Savings Calculator user guide<sup>71</sup> for an updated list of relevant technologies whose savings and incentives can be calculated using the Clean Heat Calculator.

The Clean Heat Calculator should be used as the default method to calculate energy savings for GSHP VRF systems. Under certain circumstances, applicants may bypass using this calculator, opting instead to calculate savings using their own custom bin analysis or energy modeling approach, as approved by Con Edison.


---

<sup>70</sup> The New York Standard Approach for Estimating Energy Savings from Energy Efficiency Programs - Residential, Multi-Family, and Commercial/Industrial, known as the Technical Resource Manual (TRM), <https://www3.dps.ny.gov/W/PSCWeb.nsf/All/72C23DECFF52920A85257F1100671BDD>

<sup>71</sup> <https://cleanheat.ny.gov/assets/pdf/Calculator-User-Guide.pdf>

### 4.3 Non-Residential Program Requirements and Application Process

Non-residential projects submitted to the Program will follow the general process outlined below. Steps are dependent on whether project measures fall under prescriptive incentive categories or custom incentive categories.



#### 1. Check Project and Equipment Eligibility

Confirm that the customer, site, proposed measures, and contractors qualify for the program as specified in the Eligibility Requirements in this Manual.

#### 2. Submit Application Package

Depending on the customer segment (see below for more information), contractors should submit applications via the following channels:

- *C&I*: Customers & Participating Contractors should submit applications via email to [cleanheatcommercial@coned.com](mailto:cleanheatcommercial@coned.com) with a subject line of **New C&I Clean Heat Application – [Applicant Name]**.

- **SMB and MF:** Customers & Participating Contractors should upload applications to SMART (Willdan’s project management web portal, available at <https://sbdi.smart-willdan.com/> for SMB and <https://mf.smart-willdan.com> for Multifamily). Incomplete submissions will be rejected.

An application package may include the documentation below. In custom category cases where the scope consists of heat pumps being installed across multiple buildings owned by the same entity, a single custom application shall be submitted. Descriptions of the required documentation can be found in Section 4.3.1.

Documentation for SMB projects is defined in Section 4.3.3.5 Program Pathway (Prescriptive vs Custom).  
4.3.3.5 Program Pathway (Prescriptive vs Custom).

When submitting an application package, Participating Contractors must label these documents with the appropriate file names shown below:

- **Completed program application for the current year:** (*Filename: Address\_Application*)
- **W-9 of the incentive recipient:** (*Filename: Address\_W9 Form*)
- **Scope of Work:** (*Filename: Address\_Statement of Work*). Must include the following:
  1. **Cutsheets for Proposed Equipment:** (*Filename: Address\_Cutsheet – [Make - Model #]*)
  2. **Cost Estimate for Proposed Work:** (*Filename: Address\_Cost Estimate*)
  3. **Project Timeline:** (*Filename: Address\_Project Timeline*)
  4. **Design Drawings:** (*Filename: Address\_Design Drawings*)
  5. **Load Calculations:** (*Filename: Address\_Load Calc*)
  6. **Energy Savings Analysis:** (*Filename: Address\_Calculations*)
  7. **Building Information:** (*Filename: Address\_Building Info*)
  8. **Other measure specific documentation:** (*Filename: [Specify Document Type based on measure-specific requirements]*)

### **3. Pre-Inspection & Initial Engineering Review**

#### **a. Initial Engineering Review**

Con Edison will review the application’s technical documentation for completeness to verify equipment technical eligibility, project incentive category, baseline and assumptions used in the energy analysis to determine preliminary savings and incentives for the project.

During the review process, the reviewing engineers might request further information and documents to complete their review of a project.

#### **b. Pre-Installation Inspection**

All projects are subject to an onsite pre-installation inspection of existing heating and cooling systems after the initial technical review. Scheduling of inspections is coordinated with the customer and Participating Contractor based on the customer’s availability. The inspection verifies the existing site conditions, including HVAC and other building systems, as consistent with the scope of work and Program requirements.

In the case of new construction projects, a document review will be conducted to produce the Preliminary Incentive Offer Letter and Notice to Proceed.

For multifamily projects, inspections will require access to a minimum of 10% of the total building dwelling units.

For SMB projects, some projects may receive virtual inspections, in which case Participating Contractors must follow the detailed guidelines provided by the program.

**c. Measurement & Verification**

Measurement and Verification (M&V) may be required for projects in which the technology or project has a high degree of savings uncertainty, is an unknown or unique application, is comprised of a complex group of measures, or is part of a Non-Wires or Non-Pipeline Solutions area. The overall intent of M&V is to mitigate risk to the program by reporting more accurate savings through metering and data collection. It involves a more robust approach to measuring the energy conservation measure and its application. The M&V approach will utilize various methods to obtain insights into energy conservation measures (ECMs), assess their application as well as their impact on savings and incentives.

**4. Sign Preliminary Incentive Offer Letter**

Once the customer receives the PIOL, they must sign and return it within 30 days. The estimated dates for installation start and completion must also be provided on the signed PIOL. *For SMB and Multifamily only*, once the PIOL is returned, the Participating Contractor can begin the installation. *For C&I*, the Participating Contractor must wait until the pre-inspection is complete and they have received a Notice to Proceed.

Projects will draw down their sectoral allocation on the date Con Edison issues a PIOL.

Table 31 gives the timelines on which projects must be completed from the date of the PIOL.

*Table 31: Installation Timelines*

Category	Existing Buildings
Prescriptive	12 Months
Custom	24 months

In the event of unusual delays, the Participating Contractor may request timeline extension to complete the project. Extension requests are subject to the sole discretion of Con Edison.

**5. Notice to Proceed**

*For C&I projects only*, following the signed PIOL, Con Edison will issue a Notice to Proceed at which point project work may begin.

**6. Install Equipment or Perform Project Work**

The Participating Contractor must submit project completion documents as soon as the project is completed. A project is considered complete when the eligible scope is installed and operational, and the project is ready for post-inspection. The completion documents include:

1. **Customer Acknowledgement Form:** (*Filename: Customer Acknowledgement Form*)
2. **Final Invoice:** (*Filename: Invoice*)
3. **Decommissioning Checklist (if applicable):** (*Filename: Decommissioning Checklist*)
4. **Electric Service Ruling:** (*Filename: Electric Service Ruling*)
5. **Updated Scope of Work (if applicable):** (*Final to the file name*)
6. **Warranty:** (*Filename: Warranty*)
7. **DOB Permit (upon request):** (*Filename: DOB Permit*)

## **7. Post-Installation Inspections & Final Engineering Review**

### **a. Post-Installation Inspections**

Con Edison will conduct an on-site post-installation inspection to confirm that all work was installed in accordance with the SOW provided with the initial application. Post-installation Inspections will be conducted after all approved heat pump measures have been installed and the completion paperwork has been submitted. The inspections team will assess the quality of workmanship of the heat pump installation, including verifying proper installation and functioning of the equipment and that work has been performed in accordance with the approved scope of work in compliance with Program rules.

Similar to pre-installation inspection, the inspectors will need access to at least 10% of dwelling units in the multifamily sector, as well as 100% of all condensers.

### **b. Final Engineering Review**

Con Edison will review the completion paperwork and findings from the post-installation inspection, revising the energy savings calculations, as necessary, to reflect as-built conditions and as-installed costs, and determine the final project savings and incentive. If the oversight, including on-site inspections finds any conformances, the Program may require that those be fixed before issuing payment.

If the final project differs from the SOW and the PIOL, the incentive will be adjusted to match the final installation. For projects with a requirement to submit DOB drawings, if the final project differs from the DOB-approved design drawings, a DOB-approved PW4 must also be submitted.

In the event that the energy savings were to increase, a higher incentive than what was listed on the PIOL cannot be guaranteed.

### **c. Quality Assurance/Quality Control**

Some projects will be selected for QAQC activities, such as a secondary inspection or an additional engineering review. The goal of QAQC is to protect the Program from fraud and provide actionable insights for program improvement and efficiency. QAQC is performed by a third-party contractor on behalf of Con Edison. Projects may be selected at random or based on other criteria including size, savings or incentives. QAQC activities are not optional, and the participant is expected to cooperate fully with any effort by Con Edison or its contractors and subcontractors to make follow-up visits to customer facilities, provide supporting documentation, and other requests in support of this effort. Additionally, Participating Contractors may be subject to utility-specific reviews and/or assessments to verify program measure implementation and acquisition. Contractors with concerns about the QAQC process should reach out to their account manager.



## 8. Receive Incentive Payment

After the Con Edison Program team finalizes the Project's energy savings and incentives, Con Edison will issue an incentive check to the incentive recipient designated on project documents.

### 4.3.1 Supporting Documentation Description

#### *Application & W-9*

- Applications must include a copy of a signed legal contract between the participating contractor and the customer, with terms and conditions. Incomplete applications, or applications with inaccurate and/or incomplete customer/customer's representative details are not accepted. Account name must match the name of the Con Edison account holder
- The W9 must match the name of the payee as indicated on the program application and must be latest version available on IRS website at the time of application to the program.

#### *Scope of Work*

A detailed scope of work that specifies all equipment related to the proposed measure, includes a description of the existing system operation, and provides the following additional details:

- Describes the extent of work and indicates whether the scope involves gut rehab.
- Provides a description of existing heating and cooling systems and building envelope, or in the case of gut rehab, a counterfactual case that describes the equipment and building envelope that would have been installed but for the Clean Heat Project.
- Specifies the type of heat pump technology being proposed for installation, quantity of new units, and proposed system application (e.g., domestic hot water heating, space heating and cooling). Specifies whether equipment is ducted or ductless.
- Provides design capacity, efficiencies, and proposed sequence of operations for new heat pump installation
- Specifies what percentage of the design heating/cooling load the new heat pumps are proposed to accommodate. See Required Equipment Sizing for details regarding equipment sizing.
- Specifies whether supplemental heating, via either an existing heating system or new heating system, is required to accommodate the design heating load. If a supplemental heating system is required, provide an explanation as to the following:
  - In the case of a partial load project, describes why additional electrification above and beyond the proposed design is not feasible.
  - In the case of a decommissioning project, describes the existing heating system's decommissioning plan.
  - Identifies the on-site personnel that will learn & operate the control module(s).

**For Gut Renovations:** Specify which energy code compliance pathway (*i.e.*, Tabular Analysis, COMcheck, or Performance Path) design follows to demonstrate compliance with the applicable 2020 energy code and whether design trade-offs have been taken.

A completed Scope of Work must also include the supporting documentation listed below:

#### **1. Cutsheets & AHRI/NEEP certificates**

Specific model(s) and product ratings being used in the project must be submitted with the project

application to properly determine equipment eligibility. Model numbers must be highlighted on the cutsheets before submission to the program. AHRI and NEEP certificates of the proposed equipment are required as well.

## **2. Cost Estimate for Proposed Work**

Applicants shall submit a cost estimate for the proposed work with its initial application. Installation costs as provided to the customer, including labor and materials, date of the proposal generated, and the customer's representative's details to whom it was submitted must be submitted with the project application for the proposed heat pump scope. Labor and material costs shall be presented separately as an itemized list, and costs shall be limited to the equipment cost and labor cost. Other costs such as taxes, internal labor costs, shipping, administrative costs, project management, construction management, permitting, or similar costs will not be included with total project cost when calculating incentive caps.

## **3. Project Timeline**

Applicants must include anticipated timeline of installation beginning and completion.

## **4. Design Drawings**

Applicants must submit project design drawings at the request of Con Edison.

## **5. Load Calculation**

- For commercial spaces & buildings, BHL & BCL shall be calculated following ANSI/ASHRAE/ACCA Standard 183-2007(RA2020)<sup>72</sup>, ACCA Manual N 5th ed.<sup>73</sup>, or other code-approved equivalent computational procedure, and the Participating Contractor must submit a load calculation report.
- Calculation of the building's design heating load shall be at the 99% dry bulb heating design temperature for the most relevant ASHRAE 2017 location.
- Calculation of the building's design cooling load shall be at the 1% dry bulb cooling design temperature for the most relevant ASHRAE 2017 location.
- Software files detailing the project's load calculation analysis may be requested by the program team at their discretion.
- Every load calculation report copy must have a completed and signed copy of the ASHRAE 183 Compliance form, for reference, see **Figure 3 ASHRAE 183 Compliance Form**.
- The heat pump designer responsible for sizing the system must be the one performing and approving the load calculation. If a project has a building permit filed for the onsite work, it must share the responsible registered P.E./R.A. with the load calculation report.
- **Technical requirements:**
  - a) **Load calculation method:** a procedure used to calculate the cooling or heating load of a zone or building. Load calculation methods that comply with ANSI/ASHRAE/ACCA Standard 183-2007 include, but are not limited to:
    1. the cooling load temperature difference/cooling load factor (CLTD/CLF) family of methods,
    2. total equivalent temperature difference/time averaging (TETD/TA) methods,
    3. transfer function methods (TFMs),
    4. radiant time series (RTS) methods, and
    5. heat balance (HB) methods.

---

<sup>72</sup> [https://www.techstreet.com/ashrae/standards/ashrae-183-2007-ra-2020?product\\_id=2202075](https://www.techstreet.com/ashrae/standards/ashrae-183-2007-ra-2020?product_id=2202075)

<sup>73</sup> <https://www.acca.org/store#/productDetail/5A744C03-BC20-E511-80FA-C4346BACEBF4/>

- b) Load calculation analysis must be zone-by-zone or room-by-room type; block load calculations will not be accepted.

(This appendix is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal to ASHRAE or ANSI.)

**INFORMATIVE APPENDIX B**  
**RECOMMENDED ASHRAE/ACCA COMPLIANCE FORM FOR STANDARD 183**

**Building or Zone Name:**  
 <BUILDING NAME>

**Location or Address:**  
 <FULL SITE ADDRESS>

**Design Conditions:** MUST BE COMPLETE

	Cooling	Heating
Weather Data Used		
Indoor Dry Bulb Design Temperature		
Indoor Design Relative Humidity		

**Load Calculation Method:**  
 (Indicate which of the following methods is used.)

**CLTD/CLF**—Cooling Load Temperature Difference/Cooling Load Factor methods

**HB**—Heat Balance methods

**TET/ITA**—Total Equivalent Temperature Difference/Time Averaging methods

**TFM**—Transfer Function Methods

**RTS**—Radiant Time Series methods

**OTHER** (please specify) <SPECIFY IF SELECTED, ELSE USE ONE FROM ABOVE>

The undersigned attests that the above information is correct and that the procedures used to perform the load calculations comply with ANSI/ASHRAE/ACCA Standard 183.

**Signed:** <SIGN AND STAMP BY P.E.> **Date:** <FILL>

**Submitted by:** <FULL NAME AND PROFESSIONAL CREDENTIALS> **Date:** <FILL>

ANSI/ASHRAE/ACCA Standard 183-2007 (RA 2020)

Figure 3 ASHRAE 183 Compliance Form

## 6. Savings Calculations

The Statewide Custom Clean Heat Program Savings Calculator (Clean Heat Calculator) is an Excel-based tool that has been developed to assist Participating Contractors applying to the NYS Clean Heat Program with calculating energy savings and incentives for various types of heat pump technologies. The Statewide Custom Clean Heat Program Savings Calculator user guide<sup>74</sup> contains an updated list of technologies for which the Clean Heat Calculator calculates savings and incentives.

The Clean Heat Calculator should be used as the default method to calculate energy savings for the custom categories (4, 4a, and 10).

Applicants may bypass using this calculator, opting instead to calculate savings using their own custom bin analysis or energy modeling approach. All calculations must be clear and transparent, utilizing

<sup>74</sup> <https://cleanheat.ny.gov/assets/pdf/Calculator-User-Guide.pdf>

standard engineering methodologies, including a listing of source values.

### **7. Building Information**

Description should specify building type and the floors or building areas impacted by the project. Include whether any other measures are being installed to contribute to additional heating or cooling relief, such as building envelope upgrades (e.g., weatherization, sealing, insulation, etc.).

### **8. Other measure specific documentation**

Projects may be required to include other documentation specified in this Program Manual specific to the technology or category. For example, SMB projects applying for prescriptive incentives based on square footage must submit floor plans.

#### *Project Completion Documents*

#### **1. Customer Acknowledgement Form**

Customer and Participating Contractor signed Customer Acknowledgement Form. Only material and labor costs directly related to incentivized measures should be included on the completion form.

#### **2. Final Invoice**

Applicants shall submit a final invoice, documenting actual material and labor costs for the installation, with all completion documents. The final invoice must include all the information listed below to meet the documentation requirements. The document must be labeled as an invoice and cannot be labeled as a proposal and include the following elements as in **Figure 4: Sample Invoice**.

#### **Project Costs and Invoicing Requirements**

Material and labor costs submitted to the program are subject to Con Edison review and may be capped for incentive calculations at the company's sole discretion. Internal labor costs will not be included with total project cost when calculating incentive caps. When submitting invoices with the Customer Acknowledgement Form, customers must provide Con Edison with detailed invoices identifying the following:

- Contractor name and address
- Contractor contact information
- Customer representative's details, project's address, related to the items listed in the scope of work that was approved by the program. Changes to approved scope of work must be submitted to the program team for approval
- Itemized description of equipment installed – Make and model number(s) are required in both cost proposal and the final invoice. Serial number(s) are not required in the cost proposal but are required in the final invoice.
- Quantity, purchase date and delivery date of equipment installed: This is required to verify the quantity of equipment installed aligns with the Con Edison Program application.
- Invoice Number
- Installation date and invoice issue date
- Itemized labor and material costs for all installed equipment
- Material costs associated with decommissioning existing fossil heating systems as applicable
- The final invoice provided to Con Edison must be the same invoice the customer is receiving and match the Customer Acknowledgement Form.

- Unless otherwise specified, project cost is limited to the equipment cost and labor cost. Other costs such as taxes, internal labor costs, shipping, training, admin costs, or similar costs will not be included with total project cost when calculating incentive caps.
- Each line item must include a brief description. For example, include the equipment tag for an air handler as “AHU 13B”, as well as make, model and serial number.
- Unless specified in the incentive application, the Participating Contractor would be the default recipient of the approved incentive amount.
- If a Participating Contractor is receiving incentives on behalf of a customer, a line item stating “Con Edison Incentive Credit” with an invoice credit must be documented on the invoice. The invoice credit must reflect the same incentive amount the customer would receive had they completed the submission themselves for the same project. In the event a custom project submitted for incentives is a portion of a larger scope, the customer will provide invoice(s) that clearly outline the specific project description and costs that is being applied to the project in the program.

Figure 4: Sample Invoice

### INVOICE

**1 Vendor Name**  
123 Main Street  
New York, NY 10001

**2** 1(800) 888-1234  
[info@vendor.com](mailto:info@vendor.com)

**5 Bill To:**  
John Doe  
123 Street  
New York, NY 10001

**4**

INVOICE #	INVOICE DATE	INVOICE DUE
#0001	1/1/2022	1/1/2022

**6 Service Location:**  
Building A  
456 Street  
New York, NY 10001

Description	QTY	Material	Total
<b>7</b> Heat Pump Manufacturer: ABC Heat Pump Model #: AABBC-HP1122	<b>8</b> 3	<b>9</b> \$8,000	\$24,000
Heat Pump Manufacturer: DEF Heat Pump Model #: DDEEFF-HP3344	5	\$10,000	\$50,000
Labor			\$ 10,000.00
<b>10</b>			
Subtotal			\$84,000
Tax			\$6,567.50
TOTAL			\$90,567.50

**1. Contractor name and address**

**2. Contractor contact info**

**3. Invoice #**

**4. Install date/ Invoice date**

**5. Customer name and address**

**6. Installation site**

**7. Make and model # installed**

**8. # Units installed**

**9. Unit cost**

**10. Total cost including labor**

### 3. Decommissioning Checklist

Completed decommissioning checklist (as applicable)

#### **4. Electric Service Ruling**

All projects must be reviewed by and receive a ‘service adequate’ electric service ruling from Con Edison Energy Services. A Master Case ID (“MCID”) will be issued by Con Edison Energy Services when the project is submitted for review. The MCID shall be provided to the Program as early as possible, but no later than notification of construction completion, to serve as record that consultation with Con Edison Energy Services has occurred. Final incentive payments will be contingent on receipt of the MCID and a ‘service adequate’ electric service ruling from Con Edison Energy Services. For more information, refer to the Con Edison Blue Book<sup>75</sup> that is located on the Con Edison’s Energy Services Resource Web Site.<sup>76</sup>

#### **5. Updated Scope of Work**

If any aspect of the scope of work changed during installation, the relevant documents must be updated and resubmitted.

#### **6. Warranty**

Each qualified residential and small commercial ASHP receiving an incentive under the Program must include a minimum five (5) year manufacturer’s warranty for parts including compressor. Warranty terms must be included in at least one document supplied to the customer – it could be included in the final invoice, and/or in the contract between the customer and the Participating Contractor. This requirement does not apply to large commercial and industrial customers.

#### **7. DOB Permit (upon request)**

At its sole discretion, Con Edison may request and contractors must provide an approved Department of Buildings permit submission including EN-drawings and energy analysis (COMcheck, tabular analysis).

### 4.3.2 Multifamily Program Eligibility and Requirements

This Section of this Program Manual is designed to provide Participating Contractors with the information they will need to participate in the multifamily sector of the Clean Heat Program and supplements the application process outlined above in section 4.3. The multifamily program supports air-source heat pump (ASHP), ground-source heat pump (GSHP), and heat pump water heater (HPWH) measures installed in Con Edison’s electric service area.

#### **4.3.2.1 Incentive Eligibility**

Buildings with five or more Dwelling Units are eligible for the Clean Heat multifamily incentives. Existing buildings are eligible for incentives for ASHP, AWHP, HPWH and GSHP. New construction projects are only eligible for GSHP incentives. New construction projects are not eligible for ASHP incentives, including when used to supplement GSHP projects. New construction projects can participate in midstream HPWH program or receive custom incentives when paired with GSHP for space heating. New construction projects pursuing standalone custom hot water with ASHP or AWHP for space heating are not eligible for incentives.

Mixed-used buildings with both multifamily and commercial spaces should apply to the program with the dominant use type, determined on a case-by-case basis. In most cases, where more of a building’s

---

<sup>75</sup> <https://cdne-dcxprod-sitecore.azureedge.net/-/media/files/coned/documents/small-medium-large-businesses/electricbluebook.pdf?rev=2265eee294b94ba6ba26feb2190b90ff&hash=2ECE100C08B211EFAC7B6339B0B7ECB3>

<sup>76</sup> <https://www.coned.com/en/small-medium-size-businesses/building-project-center>

square footage is dedicated to multifamily uses, this will lead mixed-use buildings to apply in the multifamily program.

All existing buildings are subject to decommissioning of the existing heating system for the building’s space-heating scope of work. For example, if the project applies for incentives for the whole building, it must decommission the existing heating system used for space heating throughout the whole building. Alternatively, if a project applies for incentives for a wing of the building, it must decommission the existing heating elements in that wing. The existing heating system is permitted to heat other areas of the building which were not in the scope of the Clean Heat project.

To be eligible for multifamily Clean Heat incentives, a customer must meet the following criteria:

- Have an active Con Edison electric account
- The building must be occupied year-round
- Projects submitted after January 17, 2023 should not have begun installation<sup>77</sup>

Projects in the following categories are not eligible for Clean Heat incentives:

- Sites that received incentives from a previous Clean Heat Program covering the same scope of work
- Common-area-only-scope of work

In cases where a project covers 1-4 Dwelling Units in a multifamily building, it is eligible for residential incentives in category 2a2b or 2e, but not multifamily incentives in category 2c or 4.

#### 4.3.2.2 Incentives

Incentives are available on a first-come, first-served basis. All incentives are limited to 50% of project costs or \$1 million, whichever is lower. Project costs include those related to equipment, labor, decommissioning, and project design.

The NYS Clean Heat Program in Con Edison’s service territory offers incentives for the following types of multifamily projects:

- Category 2c — ASHP Full-load heating with decommissioning in buildings with 100 or fewer Dwelling Units
- Category 4 — Custom space heating applications with decommissioning
- Category 4a — Custom heat pump projects with envelope upgrades and decommissioning
- Category 6 — Custom Hot Water Heating Applications
- Category 6a – Prescriptive Hot Water Heating Applications
- Category 10 – Custom Partial Load Space Heating Applications

Table 32: Multifamily incentive Rates

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
2c	Multifamily Full Load Heating with	N/A	\$5,000/dwelling unit	\$5,000/dwelling unit

<sup>77</sup> Installation is defined as having installed any indoor or outdoor mechanical equipment.

	Decommissioning			
<b>4</b>	Custom Space Heating Applications	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope – Tier 1	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu
	Custom Space Heating Applications + Envelope – Tier 2	\$150/MMBtu	\$225/MMBtu	\$225/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu
<b>6a</b>	Prescriptive Domestic Hot Water (“DHW”)	N/A	N/A	\$1,000/dwelling unit
<b>10</b>	Custom Partial Load Space Heating Applications	N/A	\$100/MMBtu	\$70/MMBtu

**4.3.2.3 Multifamily Limited-Time 2024 Promotion**

Con Edison has introduced new incentive rates as part of a Limited-Time 2024 Promotion for Multifamily projects. To be eligible for the 2024 Promotion Rates, multifamily projects must submit completed applications by May 31, 2024 and be installed by the following deadlines by category:

- Categories 2c and 6: October 1, 2024;
- Categories 4, 4a, and 10: September 1, 2025.

GSHP projects in Categories 4 and 4a must be fully installed and pass post-inspection no later than November 1, 2025.

Projects for which completed applications are not submitted by, or which are not installed by the specified dates, will be eligible for base incentive rates. Incentive rates for the 2024 Promotion can be found in Table 33 below.

*Table 33: Multifamily Limited-Time 2024 Promotion Incentives*

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
<b>2c</b>	Multifamily Full Load ASHP Heating with Decommissioning	N/A	N/A	\$7,000/dwelling unit
<b>4</b>	Custom Space Heating Applications	\$150/MMBtu	\$300/MMBtu	\$225/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope – Tier 1	\$150/MMBtu	\$300/MMBtu	\$225/MMBtu
	Custom Space Heating Applications + Envelope – Tier 2	\$175/MMBtu	\$325/MMBtu	\$250/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$150/MMBtu	\$300/MMBtu	\$225/MMBtu
<b>10</b>	Custom Partial Load Space Heating Applications	N/A	N/A	\$95/MMBtu



#### **4.3.2.4 Program Pathway (Prescriptive vs Custom)**

All projects will require a floor-by-floor Manual J Load Calculation report.

#### **Prescriptive Projects**

A building is eligible to proceed under the prescriptive pathway, under category 2c, if it contains 100 Dwelling Units or fewer. Projects receiving the prescriptive rate must electrify and decommission either the whole building or an identifiable portion of the building. In cases where a project electrifies 1-4 Dwelling Units in a multifamily building, that project is eligible for residential incentives at the per apartment rate, not the multifamily rate.

A project is eligible to apply for incentives under the prescriptive category 6a for domestic hot water in properties where hot water serves in-unit use only. Only full load air-to-water heat pump installations are eligible for category 6a incentives.

Prescriptive projects may not combine their project with a custom project at the same time and location. For example, a prescriptive project which relied on a central ASHP system could not also seek custom incentives for installation of a complementary ERV/HRV.

#### **Custom Projects and Approved Calculation Approaches**

A project is eligible to apply for incentives under the custom incentive rates, in categories 4, 4a and 6 if it contains more than 100 Dwelling Units or is installing a custom technology. A project may choose to apply for incentives in custom categories 4 and 4a for buildings under 100 dwelling units. In these cases, contractors must follow the application process requirements outlined above in section 4.3. A project is eligible to apply for incentives under the custom incentive rates in category 6 for properties with major water-consuming amenities (gyms, pools) or is installing a custom technology.

To be eligible for Category 10 incentives, projects must displace at least 50% of on-site fossil fuel consumption or result in at least 4,000 MMBTU of annual energy savings. Partial-load custom space heating are available to existing buildings and gut renovations only. All projects applying for incentives under the custom categories must submit savings calculations using either the latest version of the Statewide Custom Clean Heat Program Savings Calculator or a custom Excel model.

Equipment eligibility is specified in Section 3.2. In summary, central ccASHPs and ductless or partially ducted mini-split heat pumps (“MSHP”) must be on the NEEP Product List to be eligible for incentives, while other technologies follow the guidance in sections 3.2.4 through 3.2.11.

#### **4.3.2.5 Multifamily Savings Calculations**

For projects in category 2c, electrifying 100 apartments or fewer, Con Edison will calculate savings using a deemed savings approach to be added to the TRM in 2024.

For custom projects in categories 4, 4a, 6, and 10, applicants and Con Edison follow methodologies outlined in Section 3.

#### 4.3.3 Small and Medium Business Program Eligibility and Requirements

This Section of this Program Manual is designed to provide Participating Contractors with the information needed to participate in the small and medium business (SMB) sector of the Program. The SMB program supports cold climate air-source heat pump (ASHP), ground-source heat pump (GSHP), and heat pump water heater (HPWH) measures installed in Con Edison's electric service area.

##### **4.3.3.1 Incentive Eligibility**

Existing buildings are eligible for incentives for ASHP, AWHP, HPWH, and GSHP. New construction projects are only eligible for incentives for GSHP and HPWH when installed in conjunction with GSHP. New construction projects are not eligible for ASHP or AWHP incentives, including when used to supplement GSHP projects. New construction projects can participate in midstream HPWH program or receive custom incentives when paired with GSHP for space heating. New construction projects pursuing standalone custom hot water or custom hot water with ASHP or AWHP for space heating will not be eligible for incentives.

Mixed-used buildings with both multifamily and commercial spaces should apply to the program with the dominant use type, determined on a case-by-case basis. In most cases, where more of a building's square footage is dedicated to multifamily uses, this will lead mixed-use buildings to apply in the multifamily program.

All existing buildings are subject to decommissioning of the existing heating system for the building's space-heating scope of work.

To be eligible to participate in the SMB sector of the Program, all the following statements must be true:

- The customer must have an active direct metered Con Edison electric account and, when installed, the heat pumps' usage must be billed to this account.
- The customer must have an average peak demand of less than 300 kW on a rolling 12-month basis.
- The customer has not previously received Clean Heat incentives.
- The site must be occupied year-round.
- Equipment must be installed *after* the customer signs and submits a signed Preliminary Incentive Offer Letter ("PIOL") from Con Edison and allows for pre-installation inspection.
- Installed HPs must be used for heating to displace existing fossil fuel or electric space heating and/or DHW usage and cannot be used *only* for cooling.

#### 4.3.3.2 System Eligibility

The Program expects that projects applying for the prescriptive incentives should fall within the minimum and maximum BH/square foot guidelines in Table 34 for each business sector. BH/square foot is defined as the actual equipment heating output at 17F. The Program may accept projects outside of these ranges on a case-by-case basis with a reasonable, documented justification.

Table 34: Recommended Range BH/SF for SMB Projects

Building Sector	Min BH/SF	Max BH/SF
Restaurant /Fast Food	20	30
Big Box Retail	15	35
Small Retail	20	40
Schools	18	35
Office	15	30
Religious Institutions	20	35
Grocery Stores	20	35
Auto Repair	25	45
Hospital and Healthcare	20	40
Assembly	20	30
Fitness Centers	20	35
Warehouses	8	20
Light Industrial	25	50
Hotels	15	30

#### 4.3.3.3 Incentives

Incentives are available on a first-come, first-served basis. All incentives are limited to 50% of project costs or \$200,000, whichever is lower. Project costs include those related to equipment, labor, decommissioning, and project design.

The Con Edison Clean Heat offers incentives for the following types of projects in the SMB program:

- Category 2d: Full-load heating with decommissioning (required for all projects with a floor area of 2,500 square feet or less)
- Category 4: Custom heat pump space heating applications with decommissioning
- Category 4a: Custom heat pump projects with envelope upgrades and decommissioning
- Category 6: Custom Hot Water Heating Applications

Information on incentives and program details can also be found at [conEd.com/CleanHeatSmallBusiness](http://conEd.com/CleanHeatSmallBusiness).

Table 35 offers a summary of the SMB incentive offerings.

Table 35: SMB Incentive Rates

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
2d	SMB Full Load Heating with Decommissioning (<1,000 square feet)	N/A	N/A	\$5,000/project
	SMB Full Load Heating with Decommissioning (1,001-1,500 square feet)	N/A	N/A	\$7,500/project
	SMB Full Load Heating with Decommissioning (1,501-2,000 square feet)	N/A	N/A	\$10,000/project
	SMB Full Load Heating with Decommissioning (2,001-2,500 square feet)	N/A	N/A	\$12,500/project
4	Custom Space Heating Applications	\$125/MMBtu	\$200/MMBtu	\$150/MMBtu
4a	Custom Space Heating Applications + Envelope	\$125/MMBtu	\$200/MMBtu	\$150/MMBtu
6	Custom Domestic Hot Water (“DHW”)	\$125/MMBtu	\$200/MMBtu	\$200/MMBtu

**4.3.3.4 SMB Limited-Time 2024 Promotion**

Con Edison has introduced new incentive rates as part of a Limited-Time 2024 Promotion for SMB projects. To be eligible for the 2024 Promotion Rates, SMB projects must submit completed applications between December 5, 2023 and May 31, 2024 and be installed on or before October 1, 2024. Projects for which completed applications are not submitted by, or are not installed by, the above dates will be eligible for base incentive rates. GSHP projects in Categories 4 and 4a must be fully installed and pass post-inspection no later than November 1, 2025.

Prescriptive projects in Category 2d located within a DAC will be eligible for the 2024 Promotion DAC Rates and the incentives will be capped at 60% of project costs. 2024 Promotion incentives for custom projects in Category 4 and 4a will be capped at \$400,000. Incentive rates for the 2024 Promotion can be found in Table 36 below.

Table 36: SMB Limited-Time 2024 Promotion Incentives

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
2d	SMB Full Load Heating with Decommissioning (<1,000 square feet)	N/A	N/A	\$6,000/project
	SMB Full Load Heating with	N/A	N/A	\$8,500/project

	Decommissioning (1,001-1,500 square feet)			
	SMB Full Load Heating with Decommissioning (1,501-2,000 square feet)	N/A	N/A	\$11,000/project
	SMB Full Load Heating with Decommissioning (2,001-2,500 square feet)	N/A	N/A	\$13,500/project
<b>4</b>	Custom Space Heating Applications	\$150/MMBtu	\$300/MMBtu	\$175/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope	\$175/MMBtu	\$325/MMBtu	\$200/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$175/MMBtu	\$300/MMBtu	N/A

**4.3.3.5 Program Pathway (Prescriptive vs Custom)**

**Prescriptive Pathway**

A project is eligible to proceed under the prescriptive pathway, under category 2d, if its floor area is 2,500 square feet or fewer. Projects receiving the prescriptive rate must electrify heating and decommission the existing heating system for the entire project area, as required for all SMB projects.

For projects in category 2d, Con Edison will use the savings calculations prescribed in the TRM.

Equipment eligibility is specified in Section 3.2. In summary, central ccASHPs and ductless or partially ducted mini-split heat pumps (“MSHP”) must be on the NEEP Product List to be eligible for incentives, while other technologies follow the guidance in sections 3.2.4 through 3.2.11.

**Custom Pathway**

Projects are eligible to apply for the custom incentive rates for Categories 4, 4a, and 6 provided the project has a floor area greater than 2,500 square feet.

All projects applying for incentives under the custom categories must submit savings calculations using the latest version of the NYS Clean Heat Program Savings Calculator or a custom model.

**Required Documents**

In addition to all documents specified at the beginning of Section 4.3 above, applicants for SMB incentives must also submit the following documents with their initial application. These documents can all be submitted as one individual PDF document or as separate PDF documents:

- **Floor Plan Document:** (*Filename: Address\_Floor Plan*). A floor plan for all the spaces within the scope of the project which includes:
  - All walls, which must have:

- End-to-end lengths for each wall.
- Indicate exterior or interior wall.
- Door and window openings.
- Total floor area or room-by-room floor area in square feet (sq. ft.)
- Location of HVAC Indoor Units / Evaporator Units.
- Document must be submitted as a PDF file which is readable

**Suggestions<sup>78</sup>:** Typical load calculation software programs such as “Wrightsoft Right-N®”, can export floor plans as PDF files, either as separate files from the load calculation report, or combined with the load calculation report. Floor plans can also be created easily in freely and commercially available programs such as "Sketchup Free", "Microsoft Visio", "Sweet Home 3D", etc. You can use "Google Earth" for site orientation.




Figure 5 Inadequate floor-plan example




Figure 6 Compliant Floor-plan example

- **Photo Documentation:** (Filename: Address\_Existing Photo #, before installation, or Address\_Installed Photo # after installation). Timestamped and geotagged pictures of the existing space, along with pictures of the existing heating and cooling equipment. Submission template and instructions will be provided by Willdan Energy Solutions.
- **Mechanical Schedule Document:** (Filename: Address\_Mechanical\_Schedule). The document must have a Unit-Schedule. A Unit-Schedule is a table that lists all indoor and outdoor units and

<sup>78</sup> Any suggestions for products or software made in this document are purely for instructional purposes. They are not intended as a recommendation or cannot be construed as an advocacy of any company, product, or pathway.

their details. The following details must be included in the unit-schedule as columns, at the minimum:

- a. Unit Name/Tag (e.g. VRF-1, VRF-2, etc.)
- b. Manufacturer
- c. Unit Duct type (e.g. ducted, non-ducted, mixed, etc.)
- d. Model Number
- e. AHRI Number

The following fields are optional, but recommended to be included for easier project processing:

- f. Heating Capacity at 17 F
- g. Cooling Capacity at 95 F
- h. Heating COP
- i. Cooling EER
- o. Manufacturer technical specification sheets with performance data must be included in the same file.
- o. Document must be submitted as a PDF file which is readable

Table 37: Required Documentation for SMB Projects

SMB Documentation Table					
		Pre-Install Documentation		Post-Install Documentation	
		Prescriptive	Custom	Prescriptive	Custom
		≤2500 sq. ft.	>2500 sq. ft.	≤2500 sq. ft.	>2500 sq. ft.
Administrative	1. Program Application	Required	Required		
	2. W-9	Required	Required		
	3. Scope of Work	Required	Required	Required**	Required**
	4. Projected Installation Date	Optional	Required		
	5. Photo Submission	Required	Required	Required	Required
Technical	7. Cutsheets	Required	Required	Required**	Required**
	8. AHRI/NEEP Certificates	Required	Required	Required**	Required**
	9. Floor Plans	Required	Required		
	10. Mechanical Drawings	Optional	Required	Required**	Required**
	11. Load Calculation Report	Required	Required*		Required**
	12. Energy Savings Analysis Tool	Required	Required		
	13. Permits	Upon request	Upon request	Upon request	Upon request
	14. Electric Service Ruling			Required	Required

<b>Financial</b>	<b>15. Cost Estimate</b>	<b>Required</b>	<b>Required</b>		
<p>*Submitted by a Registered Design Professional - completed, stamped, signed.</p> <p>**Documentation required if scope of work changes from pre-install stage to post-install stage.</p> <p>* Only required for projects with heat pump system-size equal to or greater than 480,000 Btu/hr at 17 °F</p>					

#### 4.3.4 Commercial & Industrial Program Eligibility and Requirements

This Section focuses on the incentives available to Commercial and Industrial (“C&I”) customers and Participating Contractors who serve those customers. Eligible technologies include air-source heat pumps, heat pump water heaters and ground source heat pumps. In addition, the program offers incentives for envelope improvements, heat recovery chillers and heat pump chillers, and energy recovery ventilators/heat recovery ventilators (ERV/HRV) when paired with an eligible heat pump system. To get started, Participating Contractors or customers can determine a project’s eligibility, submit an application package, or speak with an Energy Advisor by sending an email to: [cleanheatcommercial@coned.com](mailto:cleanheatcommercial@coned.com).

##### **4.3.4.1 Incentive Eligibility**

Con Edison Commercial customers with an average peak demand that exceeds 100 kW on a rolling 12-month basis are eligible for C&I Clean Heat incentives, excluding Multifamily buildings. Commercial customers with an average peak demand that is between 100-300 kW on a rolling 12-month basis may instead choose to participate with Con Edison through the Small to Medium Business (SMB) sector of the Program.

The customer must not have applied for or received an incentive from another Con Edison program or from another utility for the same project. Customers who have applied for or received an incentive from the New York State Energy Research and Development Authority (NYSERDA) may be eligible to stack incentives consistent with NYSERDA program rules and the requirements in Section 2.8 Coordination with NYSERDA Programs.

To be eligible to participate in the C&I sector of the Program, all the following statements must be true:

- The customer must have an active direct metered Con Edison electric account and, when installed, the heat pumps’ usage must be billed to this account.
- The Con Edison customer of record listed on the application is a directly metered commercial or industrial customer.
- The customer must have an average peak demand greater than 100 kW on a rolling 12-month basis.
- The site must be occupied year-round.

Equipment must be installed *after* the customer signs and returns a signed copy of the Preliminary Incentive Offer Letter (“PIOL”) from Con Edison, allows for pre-installation inspection, and receives a Notice to Proceed (“NTP”) from Con Edison.

- Installed HPs must be used for heating to displace existing fossil fuel or electric space heating and/or DHW usage and cannot be used *only* for cooling.



As part of the application process for C&I projects, there will be a PIOL, an on-site pre-installation inspection and an NTP. Con Edison will issue the PIOL after reviewing the application. The PIOL must be signed by the customer or responsible party and returned to Con Edison. Upon receipt of the signed PIOL, Con Edison will conduct a pre-installation inspection to verify existing conditions at the facility. After completion of the pre-installation inspection, Con Edison will issue a NTP. Only after Con Edison issues a NTP may the Participating Contractor install equipment on site.

**4.3.4.2 Incentives**

Incentives are available on a first-come, first-served basis. Incentives cannot exceed 50% of the project cost for eligible measure(s) or 100% of each measure cost. Total incentives are capped at \$1,000,000 for all projects, per account per year. Material and Labor costs submitted are subject to Con Edison review and may be capped for incentive calculations at its sole discretion.

*Table 38: C&I Incentives Summary*

Category Number	Description	GSHP		All Other Clean Heat Technology
		New Construction (\$/MMBtu)	Existing Buildings incl. Gut Rehab (\$/MMBtu)	Existing Buildings incl. Gut Rehab (\$/MMBtu)
<b>4</b>	Custom Space Heating Applications	\$125	\$200	\$120
<b>4a</b>	Custom Space Heating Applications + Envelope - Tier 1	\$125	\$200	\$120
	Custom Space Heating Applications + Envelope - Tier 2	\$150	\$225	\$150
<b>6</b>	Custom Hot Water Heating Applications	\$125	\$200	\$200
<b>10</b>	Custom Partial Load Space Heating Applications	N/A	\$100	\$70

**4.3.4.3 C&I Limited-Time 2024 Promotion**

Con Edison has introduced new incentive rates as part of a Limited-Time 2024 Promotion for C&I projects. To be eligible for the 2024 Promotion Rates, C&I projects must submit completed applications by May 31, 2024 and be installed by October 1, 2024. Additionally, C&I projects must be fully installed and pass post-inspection no later than November 1, 2024.

Projects for which completed applications are not submitted by, or which are not installed by the specified dates, will be eligible for base incentive rates. Incentive rates for the 2024 Promotion can be found in Table 39 below.

Table 39: C&I Limited-Time 2024 Promotion Incentives

Category	Description	GSHP		ASHP
		New Construction	Existing Buildings	Existing Buildings
<b>4</b>	Custom Space Heating Applications	\$150/MMBtu	\$300/MMBtu	\$195/MMBtu
<b>4a</b>	Custom Space Heating Applications + Envelope – Tier 1	\$150/MMBtu	\$300/MMBtu	\$195/MMBtu
	Custom Space Heating Applications + Envelope – Tier 2	\$175/MMBtu	\$325/MMBtu	\$225/MMBtu
<b>6</b>	Custom Domestic Hot Water (“DHW”)	\$150/MMBtu	\$300/MMBtu	\$275/MMBtu
<b>10</b>	Custom Partial Load Space Heating Applications	N/A	N/A	\$145/MMBtu

Equipment eligibility is specified in Section 3.2. In summary, central ccASHPs and ductless or partially ducted mini-split heat pumps (“MSHP”) must be on the NEEP Product List to be eligible for incentives, while other technologies follow the guidance in sections 3.2.4 through 3.2.11.

**4.3.4.4 Category 10 – Partial-load custom space heating**

Incentives under Category 10 – Partial-load custom space heating are available to existing buildings and gut renovations only. A partial load heating system is a prioritized, first stage, heat pump system installed alongside a supplemental, second stage, heating system for the purpose of providing heating. The supplemental heating system may be either the existing system or a new system. New fossil and electric resistance heating systems are not eligible for Clean Heat incentives. A partial-load system can either be a system with a heating capacity under 90% of the BHL at design conditions or a system that provides >90% of the BHL at design conditions but does not decommission the existing heating system.

Additional requirements for eligibility for partial-load incentives:

- Energy consumption from the existing heating source (e.g., heating oil, natural gas, steam, etc.) must be reduced by the new electric technology or application.
- Technology must use staged, multi-speed or variable-speed heat pumps
- Project must displace at least 50% of annual baseline heating consumption or provide minimum heating savings of at least 4,000 MMBTU annually according to Con Edison Engineering Review<sup>79</sup>
- Fuel savings cannot include fossil fuel system efficiency savings in savings calculations; the fossil fuel baseline efficiency (including distribution) must equal the existing or upgraded (boiler) system efficiency.

Con Edison reserves the right to not offer partial-load heating incentives to projects which do not meet the articulated requirements or spirit of the Program.

<sup>79</sup> Heat pump chillers and heat recovery chillers are exempt from this requirement.

**4.3.4.5 Exemption from Decommissioning**

To qualify for full load heating incentives in the C&I sector, the NYS Clean Heat Program for Con Edison requires the decommissioning of existing heating system unless the building qualifies a critical facility as defined in Table 40. Critical facilities may qualify for full load C&I incentives subject to the approval of Con Edison without decommissioning or cutting/capping their existing systems, if their heat pump system meets at least 90% of the BHL at design conditions and the incentives application successfully shows that the heat pump systems are prioritized over the existing heating system.

*Table 40: Critical Facilities Exempt from Decommissioning*

<b>Critical Facilities</b>		
Airports	Emergency Shelter	Nursing Home
Cable Television Facility	Fire Facility	Paramedic and Rescue Facility
College or University	Flood Control Structures	Police Facility
Cellular Telephone Facility	Fuel Transfer/Loading Facility	Prison/Correctional Facility
Dialysis Facility	Hospital	Radio Broadcasting Facility
Electric Utility Facilities	Landline Telephone Facility	Schools
Emergency Cooling Center	Mass Transit (e.g. tunnels, bridges, ferry terminals, major rail facility)	Television Broadcasting Facility
Emergency Management Office	Military Bases	Wastewater Delivery/Treatment Facility
Emergency Medical Facility (Urgent Care)	Natural Gas Utility or Pipeline Facility	Water Supply System

## 4.4 Midstream Heat Pump Water Heater (HPWH)

The Con Edison Midstream HPWH Program offers incentives to increase the adoption of high-efficiency HPWH's in Con Edison's electric service territory. Con Edison offers two channels for participation: the Wholesale Channel and the Retail Channel.

Projects will draw down their sectoral allocation on the date Con Edison receives an application for a HPWH incentive.

### 4.4.1 Wholesale Channel

Con Edison offers incentives to distributors for each qualifying HPWH sale to an eligible customer. Distributors are responsible for both passing on the incentive to the installing contractor and/or Con Edison customer as well as submitting projects to the program's Implementation Contractor, Energy Solutions, through the online incentive system at <https://nyrebates.com/>.

#### 4.4.1.1 Eligibility

**Customer eligibility:** Any non-NYPA active Con Edison electric customer is eligible to participate.

**Distributor eligibility:** Distributors are entities who purchase eligible equipment directly from the manufacturer for resale. To participate, distributors must complete the enrollment documents including but not limited to the distributor participation agreement form, and a W-9 form.

**Installer eligibility:** Installers are not required to enroll in the program and may purchase qualifying equipment from participating distributors for sale at qualifying customer sites.

**Equipment Eligibility:** A residential duty (UEF rated) air-source HPWH with a tank up to and including 120 gallons, and a current rating  $\leq 24$  amps and voltage  $\leq 250$  volts. Units must meet or exceed ENERGY STAR<sup>®</sup> Residential Water Heater requirements.<sup>80</sup>

**Quantity Eligibility:** Any sales of two (2) or more HPWH units to the same installation address must be pre-approved by Con Edison.

#### 4.4.1.2 Process to Participate

##### Step 1. Become a participating distributor

Interested distributors shall return the enrollment materials including the distributor participation agreement form, which outlines the terms and conditions of the program, and a completed W9 form. Interested distributors can contact Con Edison's program implementer Energy Solutions at [heat-ne@energy-solution.com](mailto:heat-ne@energy-solution.com) or 1-332-266-4467 to request the enrollment materials and an introductory meeting about the program requirements.

##### Step 2. Confirm project eligibility

The distributor confirms project eligibility by contacting the program implementer, Energy Solutions, at [heat-ne@energy-solution.com](mailto:heat-ne@energy-solution.com) or 1-332-266-4467. Other tools to assist with determining eligibility may be provide at time of enrollment.

---

<sup>80</sup> [https://www.energystar.gov/products/water\\_heaters/residential\\_water\\_heaters\\_key\\_product\\_criteria](https://www.energystar.gov/products/water_heaters/residential_water_heaters_key_product_criteria)

### **Step 3. Provide the incentive**

The distributor must provide both the customer and contractor incentive as either a point-of-sale discount or as a credit to the installing contractor. The installing contractor is responsible for installing the equipment and passing on the customer portion of the incentive.

### **Step 4. Submit the application**

The participating distributor submits the relevant data from the sale through the Energy Solutions online incentive system, <https://nyrebates.com/>. This includes but is not limited to the following fields:

- Customer name
- Installation address
- Installation building type
- Sale invoice number
- Previous water heater fuel type (only for existing buildings)
- Equipment manufacturer
- Equipment model number
- Equipment serial number
- Equipment quantity
- Equipment cost per unit
- Contractor name
- Contractor contact information

### **Step 6. Application review**

Con Edison's Implementation Contractor reviews and processes all applications to determine the eligible incentive amounts and if any questions arise during review, will reach out to the relevant distributor application processing contact.

### **Step 7. Receive incentive reimbursement**

The program's Implementation Contractor will pay incentives to distributors for approved incentive applications.

### **Step 8. Installation verification**

Con Edison may select a random selection of customers for an inspection to confirm the installation information reported in the application.

#### **4.4.1.3 Incentives**

The wholesale HPWH channel is a pass-through incentive program. For all approved sales:

1. The distributor will receive an incentive for \$1,100, retain \$50, and pass the remaining \$1,050 to the contractor.
2. The contractor will receive an incentive for \$1,050, retain \$50 and pass the remaining \$1,000 to the customer.

Distributors *must* provide the \$1,050 incentive as either a point-of-sale discount or as a credit to the installing contractor's account once payment is received by the Implementation Contractor.

Description	Incentive Unit	Customer Incentive Amount	Distributor Incentive Amount	Installer Incentive Amount
ENERGY STAR® HPWH: Retail	\$/unit	\$1,000	\$50	\$50

#### **4.4.1.4 QA/QC**

##### **Customer eligibility verification:**

Using the site address and contact information that are submitted by the distributor, a random sample of locations will be visited to confirm equipment was installed at the site address.

#### 4.4.2 Retail Channel

Through the midstream HPWH Retail Channel, Con Edison offers an incentive to directly to customers for each eligible HPWH that they purchase at select retailers.

##### **4.4.2.1 Eligibility**

**Customer eligibility:** Any non-NYPA active Con Edison electric customer is eligible to participate.

##### **Equipment Eligibility:**

A residential duty (UEF rated) air-source HPWH with a tank up to and including 120 gallons, and a current rating ≤24 amps and voltage ≤250 volts. Units must meet or exceed ENERGY STAR® Residential Water Heater requirements.<sup>81</sup>

**Retailer Eligibility:** Purchase must be made at a participating retailer.<sup>82</sup>

**Quantity Eligibility:** Limited to one heat pump water heater rebate per account per calendar year. Any customer purchase of two (2) or more HPWH units to the same installation address must be pre-approved by Con Edison.

##### **4.4.2.2 Process to Participate**

###### **Step 1. Confirm Eligibility**

Interested customers shall complete the eligibility form by visiting [VerifyConEdRebates.com](http://VerifyConEdRebates.com), which outlines the terms and conditions of the program and confirms customer eligibility. Interested customers can contact Con Edison’s Implementation Contractor, Energy Solutions, at [heat-ne@energy-solution.com](mailto:heat-ne@energy-solution.com) or 1-332-266-4467 to request additional assistance in the process or request additional information about the program requirements.

###### **Step 2. Receive a Coupon**

Customers will receive a coupon via email or text message after completing the eligibility form. The coupon is only valid for the retailer where it was created.

<sup>81</sup> [https://www.energystar.gov/products/water\\_heaters/residential\\_water\\_heaters\\_key\\_product\\_criteria](https://www.energystar.gov/products/water_heaters/residential_water_heaters_key_product_criteria)

<sup>82</sup> A list of participating retailers can be found at: <https://www.coned.com/en/save-money/rebates-incentives-tax-credits/rebates-incentives-tax-credits-for-residential-customers/electric-heating-and-cooling-technology-for-renters-homeowners/swap-your-water-heater-and-save>

**Step 3. Make a purchase in-store**

The coupon provided to the customer must be scanned in-store at a participating retailer to receive an instant rebate on a qualified HPWH. The coupon can be used at any participating store as long as it is for the same retailer that was selected in the eligibility form. Customer receives instant rebate at the point of purchase.

**Step 4. Application Review**

The Implementation Contractor reviews and processes all applications to confirm eligibility and works with the participating retailers if any questions arise during review.

**Step 5. Installation Verification**

Con Edison may select a random selection of customers for an inspection to confirm the installation information reported in the application.

**4.4.2.3 Incentives**

Description	Incentive Unit	Customer Incentive Amount
ENERGY STAR® Certified HPWH	\$/unit	\$1,000

**4.4.2.4 QA/QC**

**Customer eligibility verification:**

Using the site address and contact information that are submitted by the distributor, a random sample of locations will be visited to confirm equipment was installed at the site address.

## 5. Field Inspections and Oversight

Con Edison will maintain the integrity of the Program through a standardized field inspection and oversight process. This process is aimed to provide assurance that Participating Contractors have demonstrated compliance with program rules and requirements. There will be two types of on-site inspections: Programmatic Inspections and Quality Assurance/Quality Control (“QAQC”) inspections.

Programmatic Inspections will focus on driving quality installations and contractor performance and will be conducted by Con Edison or its implementation contractors using standardized checklists to assess projects submitted by Participating Contractors. The standards and quality assurance checklists provide the criteria that will be used to evaluate the accuracy of heat pump system design, documentation, and functionality of installations. Con Edison inspection checklists can be found online at the Contractor Resources Page.<sup>83</sup>

In addition to the Programmatic Inspections, Con Edison will perform routine QAQC activities to monitor program processes and performance. These QAQC activities will be performed by an independent third party for additional oversight, including secondary reviews of projects which have received a Programmatic Inspection, and to inform improvement of program processes.

Con Edison Programmatic Inspections and QAQC activities for the program will be managed independently of the Statewide Clean Heat Quality Service Provider (QSP) Field Assessment process. Statewide contractor status would not be impacted by Con Edison programmatic inspections or QAQC results, but findings from Con Edison QAQC inspections will be shared with fellow Joint Efficiency Providers to promote statewide coordination. In particular, Con Edison will share results from QAQC inspection checklist items that are consistent with the statewide checklist items.

A Participating Contractor’s status in the NYS Clean Heat Program for Con Edison will be contingent upon quality installations recognized by successful Programmatic Inspections. Contractors will be expected to remediate any nonconformances found in either Programmatic or QAQC Inspections within 30 days of such a finding. Con Edison will take progressive disciplinary action to drive contractor performance and may take actions when a contractor does not remediate any issue within 30 days of being notified of such a finding.

Con Edison will coordinate as closely as practicable with other Joint Efficiency Providers regarding contractor performance. For example, if Con Edison takes disciplinary action against a contractor, Con Edison will notify the other Joint Efficiency Providers. Similarly, Con Edison will be aware of any disciplinary actions taken by other Joint Efficiency Providers, which may instigate disciplinary actions from Con Edison as appropriate. For example, a contractor removed from the NYS Clean Heat Program for Con Edison, would no longer be listed as eligible in the Con Edison territory on the statewide maintained database. Con Edison contractors will qualify through the statewide application process with additional requirements.

Across all customer segments, Participating Contractors should make customers aware that participating in Clean Heat includes inspection processes. Participating Contractors should make every effort to

---

<sup>83</sup> <https://cleanheat.ny.gov/contractor-resources/>



facilitate scheduling and conducting inspections and failure to allow sufficient inspections may be cause for disciplinary action.

## 5.1 Field Inspection Categories

Program staff conduct field inspections to verify site conditions associated with Clean Heat projects. Field inspections are categorized as follows:

- **Pre-Installation Programmatic Inspections (applicable to SMB, MF, and C&I segments):** Pre-installation inspections are completed before the start of any work associated with a Clean Heat project in the non-residential segment. Typically, such inspections verify existing site conditions prior to the installation of heat pump systems.
- **Post-Installation Programmatic Inspections:** Post-installation inspections are completed after successful installation of the heat pump system. Such inspections verify that the project is installed and operational, and meets the Scope of Work and complies with all program requirements.
- **Quality Assurance & Quality Control (QAQC) Inspections:** QAQC inspections are completed on a sample of projects across all customer segments. Such inspections are intended to identify areas for improving overall program process. QAQC Inspections may be performed on projects which received Post-Installation Programmatic Inspections, or those that did not.

The Program performs field inspections according to the need of each customer segment. All non-residential projects may receive a Pre- and Post-Installation Programmatic Inspection. A random sample of residential projects will receive a Post-Installation Programmatic Inspection. All projects are subject to QAQC inspections at sampling rates determined by sector. Con Edison will conduct Post-Installation Programmatic and QAQC over a sample of midstream HPWH projects.

## 5.2 Residential Inspections

Inspections in the Residential customer segment include Post-Installation Programmatic Inspections and QAQC inspections. Projects will be selected for inspection at the discretion of Con Edison. When a project is selected for a Programmatic Inspection, Con Edison will hold incentive payment until the inspection and any necessary follow-up actions are taken. Non-conformances found during any inspection will need to be fixed in accordance with program guidelines. Failure to address non-conformances will result in disciplinary action.

### 5.2.1 Post-Installation Inspections: ASHP, AWHP and GSHP Projects

Post-installation inspections for projects installing ASHP, AWHP or GSHP measures will be subject to Con Edison's ASHP, AWHP or GSHP Checklist depending on the installed measures. Inspections will verify

- Compliance with all aspects of the relevant standards and quality assurance checklist
- Project compliance with all program requirements

Any non-conformances found during a Post-Installation Inspection must be resolved by the Participating Contractor before the selected project will receive incentive payments from the program. If projects are found to be in violation of the criteria outlined in the checklist, the responsible contractor will be subject to disciplinary actions. Findings from these inspections will also affect the Participating Contractor's

standing in the program. See section 5.4 for details on the disciplinary process.

### 5.2.2 QAQC Inspections

In addition to Con Edison's Programmatic Post-Installation Inspections, some projects will be selected for QAQC inspection. These QAQC inspections may occur before or after projects have been approved for payment. The same rules apply for non-conformances found during QAQC inspections as indicated above.

### 5.2.3 Inspection Sampling Rates

Residential projects will be sampled for inspection. Across both ASHP and GSHP installations, Con Edison has sets targets of 10% of projects by Participating Contractor for Programmatic Post-Installation Inspections and 5% of projects for QAQC inspections. Con Edison may choose higher sampling rates based on contractors' status and standing or as a disciplinary measure.

## 5.3 Non-Residential Inspections

Inspections in the non-residential segments - Multifamily, SMB and C&I – will receive Pre-Installation Inspection, Post-Installation Programmatic Inspections and QAQC inspections. All non-residential projects in existing buildings will receive a Pre-Installation Inspection. New Construction and gut renovations may be required to provide other proof of on-site conditions, for example, with photographs, as prescribed by Con Edison. All non-residential projects will receive a Post-Installation Programmatic inspection. Con Edison will inspect a share for all non-residential projects for QAQC inspections, with rates to rise or fall depending on program performance at the discretion of Con Edison.

## 5.4 Disciplinary Process

It is important to the success of the Program that Participating Contractors meet all program requirements and the expectations of Con Edison's customers. Con Edison will document contractor performance through a combination of desk reviews, field inspections, and quality assurance and quality control activities. Con Edison will also closely monitor and track customer feedback, including any notices of violation, with respect to contractor performance and perform investigations as needed to assess potential for disciplinary actions. Con Edison reserves the right to take disciplinary action if there appears to be noncompliance with local regs, permitting requirements. Participating Contractors who have complied with all Program rules will be considered Approved. Con Edison will inform Participating Contractors of deficiencies on a project and may specify corrective actions. Con Edison may take disciplinary action against any approved Participating Contractor who delivers inconsistent results, up to suspension or expulsion. The Program has established a disciplinary policy of increasing severity.

For example, when an Approved contractor fails multiple programmatic inspections within a rolling 6-month timeline, the disciplinary sequence may be:

Disciplinary level 1: Required coaching/reinforcement training

Disciplinary level 2: Warning letter issued to contractor which increases the programmatic inspection rate (up to 100%) and specifies potential consequences should it be escalated to disciplinary level 3

Disciplinary level 3: Disciplinary escalation to be determined based on severity and frequency of identified issues

Potential disciplinary level 3 actions may include reduced prospective participating contractor allocations in the residential segment, suspension from submitting applications, or other actions up to and including program suspension or termination.

### Disciplinary Escalation

Con Edison may establish a probationary or suspension period for an approved Participating Contractor as part of the increasing discipline outlined above. Con Edison will notify the Participating Contractor in writing of such action. Contractors under probation will still be allowed to submit new applications for Clean Heat incentives, but potentially subject to increased oversight or restrictions in the number of new projects they can submit where any future violations would lead to suspension or expulsion. Contractors who are suspended are temporarily removed from the Program and will no longer be allowed to submit new applications for incentives. Both Probation and Suspension will impact future residential Contractor Allocations.

Any notification will outline the deficiencies that have been found, the duration of Probation or Suspension, and any corrective actions that the participating contractor must take end the Probationary or Suspended status. In addition to requiring corrective actions for specific items, Con Edison reserves the right to increase inspections, and, for contractors participating in the residential segment, limit or curtail monthly contractor allocations.

If a participating contractor does not meet the corrective actions outlined in their notification of probation or suspension, they will be subject to program expulsion. If a participating contractor receives

a second Probationary period in any twelve-month period, or if they are found to engage in misconduct, they will be subject to immediate expulsion. The Participating Contractor will be notified, in writing, of their expulsion. The notification shall state the deficiencies found in their performance, the reason for expulsion, and potential steps (if any) the participating contractor could take in order to be reinstated. Reinstatement is not guaranteed and is subject to the discretion of the Program.

If the participating contractor is placed under a disciplinary status within another Con Edison program, they may automatically be placed on probation/suspension in the Program, until the issue in the other program is resolved. The Program will make the determination based on the reason for probation.

Participating contractors that are found to be suspended or expelled from the NYS Clean Heat Programs run by other Joint Efficiency Providers will, at a minimum, receive a warning letter indicating Con Edison's awareness and that any new non-conformances with program rules can result in suspension or expulsion from Con Edison's program.

Con Edison will track, share, and review participating contractor performance across customer segments (C&I, SMB, MF, and residential). Warning letters, suspensions, and expulsions will apply across all customer segments.

Program expulsion is defined as the permanent removal of the Participating Contractor from the Program. All the privileges of Program participation will be revoked including but not limited to the use of all marketing materials associated with the Program and the ability to apply for incentives.

## **5.5 Disciplinary Exceptions**

Con Edison reserves the right to move to immediately suspend or terminate Participating Contractors for any of the following:

- Any aspect of fraud or the intent to commit fraud in any aspect of the program
- Misrepresenting the program rules and requirements to customers
- Failure to resolve non-conformances within the 30-day window described above
- Repeated failure to engage Con Edison, Con Edison's contractors including Implementation Contractors, or customers in a timely manner
- Abusing or threatening abuse towards Con Edison or any of its employees or contractors
- Repeated failures to submit accurate program documentation
- Failing to schedule Programmatic or QAQC inspections in a timely manner
- For the residential segment, submitting a bad faith allocation request that significantly diverges from a contractor's capabilities or performance in the program

## 6. Contact Information

Residential: [info@conedisonresidential.com](mailto:info@conedisonresidential.com)

SMB: [ConEd-SMBProgram@willdan.com](mailto:ConEd-SMBProgram@willdan.com)

Multifamily: [cleanheatmultifamily@coned.com](mailto:cleanheatmultifamily@coned.com)

C&I: [cleanheatcommercial@coned.com](mailto:cleanheatcommercial@coned.com)

HPWH: Jacob Lent; [heat-ne@energy-solution.com](mailto:heat-ne@energy-solution.com); 1-617-440-5468

Clean Heat Financing: [ConEd@CleanHeatFinancing.com](mailto:ConEd@CleanHeatFinancing.com)

## 7. Glossary

*This glossary provides definitions of key terms used in the NYS Clean Heat Program for Con Edison Program Manual (the Program Manual) and the NYS Clean Heat Implementation Plan. Capitalized terms used as defined terms and not defined in this glossary shall be as defined in the main body of the Program Manual or shall be as in common use between the parties.*

**Air-Conditioning, Heating, and Refrigeration Institute (AHRI):** A trade association representing manufacturers of heating, ventilation, air-conditioning, refrigeration, and water heating equipment. AHRI provides the database of equipment performance specifications, which is used in the Program to determine the incentive amount.

**Air Source Heat Pump (ASHP):** An HVAC system that provides space heating using electricity through vapor-compression refrigeration cycle. An ASHP extracts heat from outdoor air and transfers the extracted heat into the conditioned spaces via various means. ASHPs are also used to provide space cooling by reversing the cycle to extract heat from a building and transfer the heat to the outside air.

**Air to Water Heat Pump (AWHP):** A type of air source heat pump that transfers extracted heat from outdoors into water which is used as the distribution medium for space heating, and in some cases space cooling (using a reverse cycle process) and domestic hot water.

**Btu/h:** Unit of thermal power capacity that represents one British Thermal Unit (Btu) of energy transferred per hour.

**Building Cooling Load (BCL):** Building total sensible and latent heat gain in British Thermal Units per hour (Btu/h). For residential buildings, BCL shall be calculated using ACCA Manual J or another code-approved methodology. For commercial buildings, BHL shall be calculated following ANSI/ASHRAE/ACCA Standard 183-2007 (RA2017), or other code-approved equivalent computational procedure. Calculation of the building's design cooling load shall be at the 1% dry bulb cooling design temperature for the most relevant ASHRAE 2017 location.

**Building Equivalent Full Load Hours (BEFLH):** is used for the estimation of heating and cooling savings from heat pump systems, based on building type and location. It represents the equivalent full load operating hours for HVAC equipment based on 1% design temperature, TMY3 weather data, and the design heating load. The New York Technical Resource Manual employs the following vintage categories for determining BEFLH in residential buildings:<sup>84</sup>

- Built prior to 1940, uninsulated masonry buildings, referred to as “Pre-War uninsulated brick.” This category is used only for full load heating hours for multifamily low-rise and high-rise buildings.
- Built prior to 1979, before the Energy Conservation Construction Code of New York State (ECCCNYS) went into effect. This vintage is referred to as “Old” in the Appendix G EFLH tables for single family detached buildings, and “Prior to 1979” in the EFLH tables for low-rise and high-rise multifamily buildings.

---

<sup>84</sup> New York State Standard Approach for Estimating Energy Savings from Energy Efficiency Programs, Appendix G, See NYS TRM V9.pdf

(<https://www3.dps.ny.gov/W/PSCWeb.nsf/All/72C23DECF52920A85257F1100671BDD>)

- Built from 1979 through 2006, with insulation conforming to the 1980s era building codes (1979 ECCCNY). This vintage is referred to as “Average” in the Appendix G EFLH tables for single family detached buildings, and “From 1979 through 2006” in the EFLH tables for low-rise and high-rise multifamily buildings.
- Built from 2007 through the present, new construction conforming to the 2007 ECCCNY for residential buildings and the New York City Energy Conservation Code (if applicable). This vintage is referred to as “New” in the Appendix G EFLH tables for single family detached building, and “From 2007 through the present” in the EFLH tables for low-rise and high-rise multifamily buildings. Appendix G also provides EFLH tables for selected small and large commercial buildings; however, for these building types, EFLH values are the same across all building vintages.

**Building Heating Load (BHL):** Building heat loss in British Thermal Units per hour (Btu/h). For residential buildings, BHL shall be calculated using ACCA Manual J or another code-approved methodology. For commercial buildings, BHL shall be calculated following ANSI/ASHRAE/ACCA Standard 183-2007(RA2017), or other code-approved equivalent computational procedure. Calculation of the building’s design heating load shall be at the 99% dry bulb heating design temperature for the most relevant ASHRAE 2017 location.

**Central ASHP:** An ASHP system that is typically sized to provide heating and cooling to the whole building through an air duct distribution system.

**Coefficient of performance (COP):** COP is the ratio of work or useful energy output of a system versus the work or energy input, measured in the same units. It is a measure of performance often used for electrically-powered heating and cooling equipment, with the higher the system COP corresponding to the more efficient operation.

**Clean Heat Project (“Project”):** The planning and quality installation of a heat pump system at a customer owned parcel of real property using common heat pump system components over a given scope at a given time. A single project may serve multiple electric accounts. A single parcel may have multiple projects subject to the discretion of the relevant Electric Utility.

**Cold Climate ASHP defined as ccASHP:** A heat pump product listed on the Northeast Energy Efficiency Partnership (NEEP) Cold Climate Air Source Heat Pump (ccASHP) Specification and Product List (NEEP Product List), which is designed to identify air-source heat pumps that are best suited to heat efficiently in cold climates (IECC climate zone 4 and higher). The current specification and listed eligible units are available at (<https://neep.org/ASHP-Specification>).

**Commissioning Report:** A report that shows the results of project start-up tests conducted to ensure the system is operating effectively.

**Corrective Action:** In the field assessment inspection process, action(s) that must be undertaken by a participant at the direction of NYSERDA or the Designated Utility to correct identified nonconformances (i.e., specific deviations or work that fails to meet the established quality standard).

**Commercial Unitary (i.e., Large Commercial) ASHP:** Large commercial heat pump systems that include individual heat pump appliances that are powered by three-phase electricity or have rated cooling capacities  $\geq 65,000$  Btu/h for the individual appliance.

**Custom Incentive Categories:** Incentive Categories 4, 4a and 6.

**Decommissioning:** Existing fossil fuel space heating or domestic hot water (DHW) heating appliance that is retired, disconnected, or removed in a manner that complies with all applicable federal, state, and municipality laws, regulations, and codes and is installed in conjunction with an eligible heat pump system. Residential decommissioning projects may include electric resistance heating not to exceed 10% of BHL. Decommissioning Guidance Checklist available at <https://cleanheat.ny.gov/contractor-resources/>.

**Designer:** Individual or company that designs heat pump system. Requirements to be an eligible designer in the Program are described in Program Manual.

**Desuperheater:** An optional feature of a GSHP system that takes advantage of waste heat generated by the compressor and transfers the waste heat to a domestic hot water system.

**Direct Exchange (DX) GSHP:** Direct exchange GSHP systems circulate a refrigerant through a buried, closed-loop copper pipe.

**Driller:** Individual or entity that drills GSHP systems. Requirements to be an eligible driller in the NYS Clean Heat Program are described in this Program Manual.

**Dwelling Unit:** A single unit providing complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking and sanitation. Source: 2020 Energy Conservation Code of NYS Section R202 [https://up.codes/viewer/new\\_york/ny-energy-conservation-code-2020/Section/RE\\_2/re-definitions#R202](https://up.codes/viewer/new_york/ny-energy-conservation-code-2020/Section/RE_2/re-definitions#R202)

**Energy Efficiency Ratio (EER):** A measure of how efficiently a cooling system will operate when the outdoor temperature is 95 degrees Fahrenheit. It is calculated by dividing the rated cooling output at 95 degrees Fahrenheit by the watts used by the AC/HP system. A higher EER means the system is more efficient. It is an instantaneous measure of electrical efficiency, unlike SEER (Seasonal Energy Efficiency Rating), which is an averaged value of efficiency. This is a term applied to air conditioning equipment.

**Energy Recovery Ventilator (ERV):** ERVs reduce heating and cooling loads while maintaining required ventilation rates by facilitating sensible heat transfer between outgoing conditioned air and incoming outdoor air. ERVs employ air-to-air heat exchangers to recover energy from exhaust air for the purpose of pre-conditioning outdoor air prior to supplying the conditioned air to the space, either directly or as part of an air-conditioning system. Unlike HRVs, ERVs do not transfer latent heat (moisture content) between supply and exhaust air streams.

**Full Load Heating System:** A system installed that satisfies at least 100% of total system heating load at design conditions. For locations where the total system cooling load is greater than the heating load, the heat pump system cooling capacity shall be as small as possible to satisfy the cooling load, while minimizing oversizing for the heating function to the extent possible.

**Ground Source Heat Pump (GSHP) system:** An HVAC system comprising one or more heat pumps, ground loops, interior distribution systems and terminal units that enables the air and/or water in buildings to be conditioned by exchanging thermal energy with the ground, ground water, or other natural body of water.

**Gut Rehabilitation (“Rehab”):** A renovation that removes material down to structural load-bearing beam (as defined by the TRM, v10, effective January 1, 2023).

**Heat Pump System:** One or more electric heat pump appliances installed in a building to provide partial or full load heating and cooling to the building's conditioned space. The heat pump appliances and associated components may be centrally or separately controlled. In a multifamily building in which a central heating plant serves more than one apartment, the heat pump system must be designed and



installed to provide heating to all of the individual apartments and common areas otherwise served by the central heating plant.

**Heat Pump Chiller (HPC):** A chiller operating in a mode where a heat sink or source is outside of the building (i.e. well field, air or chilled water loop as source of hot or cold water for the building). Unit provides either heating or cooling but not both at the same time.

**Heat Pump System Heating Capacity:** For buildings whose BHL exceeds BCL, the heat pump system heating capacity shall be as small as possible to satisfy BHL, while minimizing oversizing for the cooling function to the extent possible with available equipment.

**Heat Pump System Cooling Capacity:** The sum of the cooling output of all heat pump appliances in the system, expressed in British Thermal Units per hour (Btu/h), at the cooling design temperature used for the building cooling load (BCL) calculation. For buildings whose BCL exceeds BHL, the heat pump system cooling capacity shall be as small as possible to satisfy BCL, while minimizing oversizing for the heating function to the extent possible with available equipment.

**Heat Pump Water Heater (HPWH):** HPWHs are water heater tanks that heat domestic hot water or process hot water through the use of an onboard air source heat pump that extracts heat from the air in the building surrounding the unit. They use a secondary electric resistance as a back-up to ensure that the water temperature meets the desired setpoint during times of high demand. Air source HPWH models come in two versions (integrated and split-system HPWH) and both versions are eligible for incentives under the program.

**Heat Recovery Chiller (HRC):** A chiller operating in a mode where heat is moved between hot water and chilled water loops within the thermal envelope in buildings requiring simultaneous cooling and heating. Unit provides heating and cooling at the same time.

**Heat Pump Chiller/ Heat Recovery Chiller (HPC+HRC):** A chiller that will operate in both heat pump and heat recovery modes for a project.

**Heat Recovery Ventilator (HRV):** HRVs reduce heating and cooling loads while maintaining required ventilation rates by facilitating both sensible (heat content) and latent (moisture content) heat transfer between outgoing conditioned air and incoming outdoor air. HRVs employ air-to-air heat exchangers to recover energy from exhaust air for the purpose of pre-conditioning outdoor air prior to supplying the conditioned air to the space, either directly or as part of an air-conditioning system.

**Incentive Category:** Grouping in the NYS Clean Heat Program reflecting applicable technology type, system size, customer type, and incentive structure.

**Installer:** Individual or entity that installs a heat pump system. Requirements to be an eligible installer in the NYS Clean Heat Program are described in the NYS Clean Heat Designated Utilities Program Manual.

**Integrated Controls (ICs):** Coordinates the heating operation of heat pump (ducted and ductless) systems with ancillary heating systems such as fossil fuel boilers and furnaces. ICs prioritize operation of the heat pump system as the first stage of heat and rely on the ancillary system as backup or second stage of heat. Integrated Controls eligibility document available at <https://cleanheat.ny.gov/contractor-resources/>

**International Ground-Source Heat Pump Association (IGSHPA):** An association established to advance GSHP technology, which conduct geothermal research and installer training and accreditation.

**Mini-Split Heat Pump (MSHP):** A type of cold climate ASHP or ccASHP that can circulate refrigerant between an outdoor unit containing a variable capacity compressor and one or more indoor air

handlers. MSHPs are often referred to as “ductless mini-splits” because they are typically ductless. These units can also be installed with short duct runs that enable single air handlers to serve more than one room at a time.

**MMBtu of Annual Energy Savings:** Estimation of first-year site energy savings, which accounts for both the decreased fuel and the change in electricity consumed at the site.

**Multifamily:** A residential building with five or more Dwelling Units.

**Nonconformances:** In the field assessment inspection process, specific deviations or work that fails to meet the quality standard established for program requirements, industry standards and quality requirements.

**Partial Load Heating System:** A partial load heating system is a primary, first stage, heat pump system installed alongside a supplemental, second stage, heating system for the purpose of providing heating. The supplemental heating system may be either the existing system or a new system. In this type of system, the total heat pump system heating capacity satisfies <90% of the building’s design heating load (“BHL”) at design conditions.

**Participating Contractor:** ASHP and GSHP designer and installer that is eligible to apply for and receive incentives under the NYS Clean Heat Program. To become a Participating Contractor, an entity must submit a Participating Contractor Application and a Contractor Participation Agreement for each Electric Utility service territory where work will be performed (available at <https://cleanheat.ny.gov/contractors/>). Upon approval, the applicant will receive an approval notification from the Electric Utility and become eligible to apply for incentives in the Program. GSHP drillers must also be approved through this process to become a “Participating Driller,” but are not eligible to submit for and receive incentives. Each GSHP installation must be completed by a Participating Driller. Contractors installing only HPWH do not have to be a Participating Contractor to submit an incentive application on behalf of a customer.

**Participating Distributor:** HPWH distributor that is eligible to offer and receive incentives under the NYS Clean Heat Program. To become a Participating Distributor, an entity must submit a HPWH Distributor Participation Agreement to their Utility Partner. Upon approval, the distributor will become eligible to apply for incentives in the Program.

**Cold Climate Packaged Terminal Heat Pump (ccPTHP):** A packaged terminal heat pump is a wall sleeve and a separate un-encased combination of heating and cooling assemblies specified by the builder and intended for mounting through the wall. It includes a prime source of refrigeration, separable outdoor louvers, forced ventilation, and heating availability by builder's choice of hot water, steam, or electricity. A PTHP utilizes reverse cycle refrigeration as its primary heat source and is equipped with supplementary heating via hot water, steam, or electric resistant heat. To be eligible for the Program, each unit in a PTHP system must be on the NEEP Product List, *i.e.*, be a ccPTHP.

**Prescriptive Incentive Category:** Incentive Categories 2a, 2b, 2c, 2d, 3, and 5.

**PIOL:** Preliminary Incentive Offer Letter

**Single Package Vertical Heat Pump (SPVHP):** A single package vertical heat pump is an air-cooled commercial package air conditioning and heating equipment that is factory-assembled as a single package, has components that are arranged vertically, and is intended for exterior mounting on, adjacent interior to, or through an outside wall. These units may be powered by a single-or 3-phase current and may contain 1 or more separate indoor grilles, outdoor louvers, various ventilation options, indoor free air discharges, ductwork, well plenum or sleeves. SPVHPs utilizes reverse cycle refrigeration

as its primary heat source and may be equipped with supplementary heating via hot water, steam, gas or electric resistant heat.

**Thermal Energy Network:** Shall mean all real estate, fixtures and personal property operated, owned, used or to be used for or in connection with or to facilitate a utility-scale distribution infrastructure project that supplies thermal energy.<sup>85</sup>

**Utility Thermal Energy Network:** All real estate, fixtures and personal property owned and operated by a utility, used or to be used for or in connection with or to facilitate thermal energy network distribution infrastructure projects that supply thermal energy. It may also include thermal energy resource(s) owned by the utility.

**Variable Refrigerant Flow Heat Pump (VRF):** VRF systems circulate refrigerant between a variable capacity compressor and multiple indoor air handlers, each capable of individual zone temperature control. VRF systems can be built with heat recovery and cooling capabilities that allow simultaneously heating to some zones and cooling to other zones. VRF systems may be air-source or ground-source type heat pumps.

---

<sup>85</sup> As defined by Public Service Law §2(29)

# Appendix 1: Calculating Sizing Ratios in the New York State Clean Heat Program Guide

## 1. Cold Climate Air Source Heat Pump / Mini-Splits (<65,000 btu/h cooling capacity)

AHRI Test Method: 210/240

$$\text{Heating Sizing Ratio} = \frac{\text{Max Heating Capacity at Design Temperature, F}}{\text{Calculated Heating Load}}$$

$$\text{Cooling Sizing Ratio, when } BCL > BHL = \frac{\text{Max Cooling Capacity at Design Temperature, F}}{\text{Calculated Cooling Load}}$$

$$\text{Cooling Sizing Ratio, when } BHL > BCL = \frac{\text{Min Cooling Capacity at Design Temperature, F}}{\text{Calculated Cooling Load}}$$

Maximum heating and cooling capacities at design temperatures may be obtained in the following ways:

- a. Download the NEEP certificate for the appropriate make/model heat pump. Linearly interpolate (if necessary) between the known maximum heating capacities at 5 degrees and 17 degrees to obtain the maximum heating heat pump performance at the design temperature. For cooling, linearly interpolate (if necessary) between known maximum cooling capacities at 95 degrees and 82 degrees to obtain the maximum cooling performance at the design temperature. Note that if the BHL>BCL, the cooling size ratio may be calculated using minimum cooling capacity at the design temperature, by extrapolating between known minimum NEEP cooling capacities at 95 degrees and 82 degrees respectively.
- b. Obtain manufacturer-specific performance and capacity data at the design temperature or use manufacturer software that provides equipment performance and capacity at the design temperature.

**Example using NEEP method:** Downstate location with heating design temperature at 12°F.

Heating Design Temperature: 12°F

Proposed Heat Pump Make: Fujitsu

Proposed Heat Pump Model: AOU36RLAVM

Maximum Heating Output at 5°F: 37,900 btu/h

Maximum Heating Output at 17°F: 42,000 btu/h

Heating Load at 12°F: 38,500 btu/h

$$\frac{42,000 \text{ btu/h} - 37,900 \text{ btu/h}}{17 \text{ degree} - 5 \text{ degree}} = \frac{42,000 \text{ btu/h} - x \text{ btu/h}}{17 \text{ degree} - 12 \text{ degree}}$$

$$x = 40,291.67$$

$$\text{Heating Sizing Ratio} = \frac{40,291.67 \text{ btu/h}}{38,500 \text{ btu/h}} = 1.05$$



**FUJITSU J-Series**  
 Multizone All Non-ducted  
 AHRI Cert #: **8693480**  
 Outdoor Unit #: **AOU36RLAVM**  
 Indoor Unit #:

**INFINITE COMFORT**

- 🔥 Maximum Heating Capacity (Btu/hr) @5°F: **37,900**
- 🔥 Rated Heating Capacity (Btu/hr) @47°F: **42,000**
- ❄️ Rated Cooling Capacity (Btu/hr) @95°F: **36,000**

**Information Tables**

<b>Brand</b>	FUJITSU
<b>Series</b>	J-Series
<b>Ducting Configuration</b>	Multizone All Non-ducted
<b>AHRI Certificate No.</b>	8693480
<b>Outdoor Unit #</b>	AOU36RLAVM
<b>Indoor Unit Type</b>	Non-Ducted Indoor Units
<b>Indoor Unit #</b>	
<b>Furnace Unit #</b>	
<b>SEER</b>	19
<b>EER</b>	13.3
<b>HSPF Region IV</b>	11.4
<b>Energy Star</b>	✓
<b>Variable Capacity</b>	✓
<b>Turndown Ratio (Max 5°F/Min 47°F)</b>	2.3
<b>Capacity Maintenance (Max 5°F/Max 47°F)</b>	90%
<b>Capacity Maintenance (Rated 17°F/Rated 47°F)</b>	61%
<b>Capacity Maintenance (Max 5°F/Rated 47°F)</b>	90%
<b>Integration</b>	
<b>Connectivity</b>	
<b>Operational Diagnostics</b>	
<b>Refrigerant(s)</b>	

**Performance Specs**

	Heating /Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max
Heating	-4°F	70°F	Btu/h	12,960	-	-	33,600
			kW	1.13	-	-	3.74
			COP	3.36	-	-	2.63
Heating	5°F	70°F	Btu/h	14,860	-	-	<b>37,900</b>
			kW	1.1	-	-	4.06
			COP	3.96	-	-	2.74
Heating	17°F	70°F	Btu/h	16,460	25,800	-	<b>42,000</b>
			kW	1.2	2.7	-	4.43
			COP	4.02	2.8	-	2.78
Heating	47°F	70°F	Btu/h	16,460	42,000	-	42,000
			kW	0.87	3.2	-	3.2
			COP	5.54	3.85	-	3.85
Cooling	82°F	80°F	Btu/h	18,190	-	-	36,000
			kW	0.95	-	-	2.37
			COP	5.61	-	-	4.45
Cooling	95°F	80°F	Btu/h	18,190	36,000	-	36,000
			kW	1.09	2.71	-	2.71
			COP	4.89	3.89	-	3.89

**Heating/Cooling Capacity Graph**



Figure 1: NEEP Certification ccASHP

## 2. Larger Unitary Heat Pumps (>65,000 btu/h)

AHRI Test Method: 340/360

$$\text{Heating Sizing Ratio} = \frac{\text{Heating Capacity at Design Temperature}}{\text{Calculated Heating Load}}$$

$$\text{Cooling Sizing Ratio} = \frac{\text{Cooling Capacity at Design Temperature}}{\text{Calculated Cooling Load}}$$

Heating and cooling capacities at design temperatures may be obtained in the following ways:

- Download the AHRI certificate for the appropriate make/model heat pump. Extrapolate (if necessary) between the known certified rated heating capacities at 17 degrees and 47 degrees to obtain the heating heat pump performance at the design temperature. For cooling, use AHRI cooling capacity at 95 degrees directly as values cannot be extrapolated from the AHRI certified data.
- Obtain manufacturer specific performance data at the design temperature.

**Example using AHRI method:** Downstate location with heating design temperature 15°F and cooling design temperature 87°F.

Heating Design Temperature: 12°F

Cooling Design Temperature: 87°F

Proposed Heat Pump Make: Daikin

Proposed Heat Pump Model: DPS010AHHE2

Rated Heating Output at 17°F: 62,000 btu/h

Rated Heating Output at 47°F: 105,000 btu/h

Rated Cooling Output at 95°F: 119,000 btu/h

Heating Load at 12°F: 56,000 btu/h

Cooling Load at 17°F: 118,000 btu/h

$$\frac{105,000 \text{ btu/h} - 62,000 \text{ btu/h}}{47 \text{ degree} - 17 \text{ degree}} = \frac{105,000 \text{ btu/h} - x \text{ btu/h}}{47 \text{ degree} - 12 \text{ degree}}$$

$$x = 54,833 \text{ btu/hr}$$

$$\text{Heating Sizing Ratio} = \frac{54,833 \text{ btu/h}}{56,000 \text{ btu/h}} = 0.978$$

$$\text{Cooling Sizing Ratio} = \frac{119,000 \text{ btu/h}}{118,000 \text{ btu/h}} = 1.008$$



# Certificate of Product Ratings

AHRI Certified Reference Number : 5831165

Date : 03-31-2021

Model Status : Active

Brand Name : DAIKIN

Model Number : DPS010AHHE2\*\*-4\*

AHRI Type : HSP-A

Refrigerant Type : R-410A

Hertz : 60

Sold In? : USA, Canada, Outside USA and Canada

Rated as follows in accordance with the latest edition of AHRI 340/360 Performance Rating of Commercial and Industrial Unitary Air-conditioning and Heat Pump Equipment and AHRI 365 and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity 95F/Cooling Capacity 95F at 230v : 119000/119000

EER 95F/EER 95F at 230v : 11.70/11.70

Heating Capacity 47F/Heating Capacity 47F at 230v : 105000/105000

COP 47F/COP 47F at 230v : 3.42/3.42

Heating Capacity 17F/Heating Capacity 17Fat 230v : 62000/62000

COP 17F/COP 17Fat 230v : 2.38/2.38

IEER/IEER at 230v : 18.0/18.0

The following data is for reference only and is not certified by AHRI

Full Load Indoor Coil Air Quantity (scfm) : 3850

Figure 2: AHRI Large Unitary Heat Pump

Note that if interpolation/extrapolation of heating capacities using the AHRI method results in irregularities, reviewers shall request manufacturer specific performance data at the design temperature.

*If product is not AHRI rated, manufacturer performance-specific data may be used. For non-AHRI rated equipment, performance data should be provided at the same rated conditions as the applicable AHRI test method for the purposes of determining eligibility.*

### 3. Air Source Variable Refrigerant Flow

AHRI Test Method: 1230

$$\text{Heating Sizing Ratio} = \frac{\text{Heating Capacity at Design Temperature}}{\text{Calculated Heating Load}}$$

$$\text{Cooling Sizing Ratio} = \frac{\text{Cooling Capacity at Design Temperature}}{\text{Calculated Cooling Load}}$$

Heating and cooling capacities at design temperatures may be obtained in the following ways:

- a. Download the AHRI certificate for the appropriate make/model heat pump. Extrapolate (if necessary) between the known certified rated heating capacities at 17 degrees and 47 degrees to obtain the heating heat pump performance at the design temperature. For cooling, use AHRI cooling capacity at 95 degrees directly as values cannot be extrapolated from the AHRI certified data.
- b. Obtain manufacturer specific performance data at the design temperature

Note that if interpolation/extrapolation of heating capacities using the AHRI method results in irregularities, reviewers shall request manufacturer specific performance data at the design temperature.

Relevant example showing AHRI method is provided in Appendix 1, Section 2 Above.

*If product is not AHRI rated, manufacturer performance specific data may be used. For non-AHRI rated equipment, performance data should be provided at the same rated conditions as the applicable AHRI test method for the purposes of determining eligibility.*

#### 4. Geothermal Heat Pumps (including GSVERFs and console type units)

Heating and cooling capacities at design temperatures may be obtained in the following ways:

- a. Downloading the AHRI certificate for the appropriate make/model heat pump and pulling the certified full load heating and cooling capacities directly from certificates to calculate sizing ratio. Note that if BHL>BCL, the cooling sizing ratio may be calculated using AHRI ground source part load capacity.
- b. Obtain manufacturer specific performance data at the design temperature.

Test Method: ANSI/AHRI/ASHRAE/ISO Standard 13256-1

$$\text{Heating Sizing Ratio} = \frac{\text{Full Load Heating Capacity at Design Temperature}}{\text{Calculated Heating Load}}$$

$$\text{Cooling Sizing Ratio} = \frac{\text{Full Load Cooling Capacity at Design Temperature}}{\text{Calculated Cooling Load}}$$

#### Example:

Make: Ice Air

Model: 8VSHPG12

Full Load Heating Capacity: 9,000 btu/h

Heating Load: 8,000 btu/h

$$\text{Heating Sizing Ratio} = \frac{9,000 \text{ btu/h}}{8,000 \text{ btu/h}} = 1.125$$



# Certificate of Product Ratings

AHRI Certified Reference Number : 205746251

Date : 11-19-2020

Model Status: Active

Old AHRI Reference Number :

Product : Water-to-Air and Brine-to-Air

Model Number : 8VSHPE12\*\*

Brand Name : ICE AIR LLC

Rated as follows in accordance with ANSI/AHRI/ASHARE/ISO Standard 13256-1 Water-toAir and Brine-To-Air Heat Pumps and subject to verification of rating accuracy by AHRI-sponsored, independent third party testing:

	Full Load	Part Load1	Part Load2	Part Load3
Air Flow Rate - Cooling:	500			
Air Flow Rate - Heating:				



*Figure 4: Geothermal AHRI Certificate*

If equipment is being installed in non-standard temperatures, option B should be followed to calculate sizing ratio. The participating contractor will be required to submit manufacturer performance data at the specific design conditions. The AHRI method will apply in most circumstances.

*If product is not AHRI rated, manufacturer performance-specific data may be used. For non-AHRI rated equipment, performance data should be provided at the same rated conditions as the applicable AHRI test method for the purposes of determining eligibility.*

## Appendix 2: Version History and Description of Revisions: Con Edison Clean Heat Program Manual

Date Filed	Version	Topic	Description of Change	Section/ Page
1/12/2023	1	N/A	N/A	N/A
3/1/2023	2	C&I Incentives	Clarification on incentive caps	Section 2.5
3/1/2023	2	New Construction	Clarification that expansion of building square footage will be considered “new construction”	Section 3.6.1
3/1/2023	2	ASHP incentives	Updated launch date for Program offering for previously incentivized partial load systems to convert to full load	Section 4.2.3
3/1/2023	2	System Eligibility for SMB Projects	Included definition of BH/square foot	Section 4.3.3.2
9/1/2023	3	Residential GSHP Incentives	Updated incentive rates for projects located in both DACs and non-DAC’s	Section 2.2
9/1/2023	3	Multifamily Incentives	Updated incentive rates and Category 10 eligibility	Section 2.3
9/1/2023	3	SMB Incentives	Updated incentive rates and caps	Section 2.4
9/1/2023	3	Non-Pipe Solutions Clean Heat Adder Incentives	Adder incentives for projects located within the NPS designated areas	Section 2.6
9/1/2023	3	System sizing	Clarification on full load project criteria & ASHRAE design temperature requirements	Section 3.2.1
9/1/2023	3	Air-to-water heat pumps	Introduction of AWHP incentive offerings	Section 3.2.3.7
9/1/2023	3	Heat recovery and heat pump chillers	Introduction of HRC/HPC incentive offerings	Section 3.2.7
9/1/2023	3	Heat Pump Dedicated Outdoor Air Systems (HP-DOAS)	Introduction of HP-DOAS incentive offerings	Section 3.2.9
9/1/2023	3	Partial load custom project eligibility	Updated eligibility criteria for Category 10 Custom Partial Load Space Heating Applications	Section 3.2.11

Date Filed	Version	Topic	Description of Change	Section/ Page
9/1/2023	3	Energy modeling	Updated modeling report requirements	Section 3.5.2
9/1/2023	3	Non-residential application requirements	Updated design drawing and permitting requirements	Section 4.3
9/1/2023	3	Midstream HPWH Retail Channel	Introduction of Midstream HPWH Retail incentive offerings	Section 4.4.2
9/1/2023	3	Field inspections and oversight	Updated residential inspection disciplinary process	Section 5
3/1/2024	4	Incentive Category Addition	Addition of incentive Category 2e <i>Air-to-Water Heat Pump</i> ("AWHP"), with revisions in numerous sections to reflect this addition	Sections 2-4
3/1/2024	4	Incentive Category Update	Category 5 renamed to Category 5 <i>Midstream HPWH</i> , and clarifications to category specifications	Sections 2-4
3/1/2024	4	Limited-Time 2024 Promotion Incentives	Addition of limited-time promotional incentives for Residential ASHP, Residential GSHP, Multifamily, SMB, and C&I sectors	Sections 2 & 4
3/1/2024	4	Incentive Category Addition	Addition of incentive Category 6a: <i>Prescriptive Domestic Hot Water</i> ("DHW") in the Multifamily sector	Sections 2.3, 4.3.2
3/1/2024	4	Financing	Removal of Con Edison Clean Heat Financing offering	Section 2.9
3/1/2024	4	Financing	Removal of reference to Companion Loans funded by New York Green Bank	Section 2.9.1
3/1/2024	4	Eligibility	Allow projects to receive incentives for replacement of non-cold climate heat pumps or non-full load heat pumps	Section 3.2
3/1/2024	4	Eligibility – Full Load Heating	Update definition of full load heating systems	Sections 3.2.1
3/1/2024	4	Design Temperature Tool	Reference added to new online tool to identify design temperature, available on Contractor Resources webpage.	Section 3.2.1
3/1/2024	4	Program Eligibility	Customers or projects participating in Utility Thermal Energy Network projects are not eligible for Clean Heat Program incentives	Section 3.2.4
3/1/2024	4	Eligibility	Addition of incentives and eligibility criteria for non-residential GSHP Thermal Conductivity Testing	Section 3.2.4
3/1/2024	4	Multifamily Eligibility	Allow buildings with up to 100 units to be eligible for category 2c and buildings of any size to be eligible for partial load custom projects in category 10	Section 4.3.2
3/1/2024	4	Eligibility	Clarification of NEEP listed eligible equipment in non-residential sectors	Sections 4.3.2 - 4.3.4
3/1/2024	4	Program Compliance	Revised SMB Documentation Requirements	Section 4.3.3.5

<b>Date Filed</b>	<b>Version</b>	<b>Topic</b>	<b>Description of Change</b>	<b>Section/ Page</b>
3/1/2024	4	Glossary	Glossary has updates to reflect Program updates.	Section 7