

# ELECTRICAL



MARRIOTT  
NEW YORK  
BROOKLYN BRIDGE

## SPECIAL NOTICE

Electrical equipment and connections must comply with the City of New York Electrical Code (available upon request). The Hotel electricians will correct infractions at prevailing rates.

## WIRING REGULATIONS PER THE ELECTRICAL CODE OF NYC

All electrical apparatus and splices must be installed in a metal enclosure to prevent emission of sparks. All metal raceways, metal lighting fixtures, and metal housing of electrically powered equipment shall be grounded.

All extension cables shall be 3 wire SJ cords or the approved type and not more than 10ft long. One of the wires with green colored insulation is to be used as a ground. The cable must be large enough for the load and have a grounded male plug.

Flexible cords and cables less than #14 Gauge wire will not be permitted. The use of lamp cords or similar devices is not permitted.

Labor not included for special power requirements. Labor will be charged at prevailing rates on a half-hour basis.

The New York Marriott at the Brooklyn Bridge will not be responsible for voltage fluctuations or power failures beyond our control.

## BILLING SUMMARY

EQUIPMENT \_\_\_\_\_

PRICE \$ \_\_\_\_\_ X \_\_\_\_\_ DAYS = \$ \_\_\_\_\_

8.875 % SALES TAX \$ \_\_\_\_\_

**TOTAL \$ \_\_\_\_\_**

## ELECTRICAL REQUEST

EVENT NAME \_\_\_\_\_

COMPANY NAME \_\_\_\_\_

ON-SITE CONTACT \_\_\_\_\_

EVENT MANAGER \_\_\_\_\_

BOOTH NAME/NUMBER \_\_\_\_\_

EXHIBIT DATE/TIME \_\_\_\_\_

INSTALL DATE \_\_\_\_\_

REMOVE DATE \_\_\_\_\_

**IMPORTANT:** This order must be received by the hotel  
at least **10 days prior to the Function date.**

Return to Email: [sharon.moser@marriott.com](mailto:sharon.moser@marriott.com)

## DAILY PRICING

**120 Volts @ \$110.00 each** (Recommended for 1 TO 3 personal computers with monitors or up to 10 Laptops)

1,000 Watts (10A) \_\_\_\_\_ x \$110 each = \_\_\_\_\_

**120 Volts Single Phase @ \$180.00 each**

2,100 Watts (20A) \_\_\_\_\_ x \$180 each = \_\_\_\_\_

**208 Volts Single Phase**

05 – 14 AMPS \_\_\_\_\_ x \$250 each = \_\_\_\_\_

15 – 19 AMPS \_\_\_\_\_ x \$500 each = \_\_\_\_\_

20 – 50 AMPS \_\_\_\_\_ x \$750 each = \_\_\_\_\_

**208 Volts Three Phase**

05 – 50 AMPS \_\_\_\_\_ x \$675 each = \_\_\_\_\_

51 – 99 AMPS \_\_\_\_\_ x \$1,125 each = \_\_\_\_\_

100 – 149 AMPS \_\_\_\_\_ x \$1,575 each = \_\_\_\_\_

150 – 200 AMPS \_\_\_\_\_ x \$2,050 each = \_\_\_\_\_